

GENERAL NOTES:

- NEW WORK IS SOLID LINEWEIGHT, EXISTING IS DASHED. TO BE REMOVED IS HASH MARKED.
- ALL PANELBOARDS SHALL BE DE-ENERGIZED WHEN COVERS ARE REMOVED. IF DE-ENERGIZING A PANELBOARD AFFECTS AREAS OUTSIDE THE DESIGNATED AREA OF WORK, THE DOWNTIME SHALL BE MINIMIZED. CONTRACTORS SHALL COORDINATE WITH THE BUILDING OPERATIONS TWO WEEKS IN ADVANCE LIMITED AS MUCH AS IS FEASIBLE, AND SHALL BE SCHEDULED FOR AFTER HOURS.
- CONTRACTOR TO PLACE COPY OF UPDATED PANEL SCHEDULE IN PANEL DOOR AND PROVIDE NREL WITH ANY REDLINES FOR AS-BUILT DRAWING UPDATES.
- CLOUDED AREAS REPRESENT SCOPE OF WORK FOR THIS PROJECT.

DETAIL NOTES:

- THE EXISTING 115 TRANSFORMER AND 11.5 PANELBOARD SHALL BE UPGRADED TO LARGER UNITS AS SHOWN ON THE ONE-LINE DIAGRAM. COORDINATE POWER SHUTDOWN FOR THIS REPLACEMENT AS TO NOT SHUTDOWN THE 104 COOLER OR SURROUNDING AREAS.

