



CERTIFICATE OF MATERIAL TEST REPORT

3451 Pegasus Drive, Bakersfield,
CA 93308 USA

Purchase order	Client	Design STD	Valve Type	Size	Pressure	QTY	Certificate No.	Serial No.	Certificate Date
14310		API 6D	Ball Valve	2''	150#	200	198711	-	10-01-2020

Shell Test (Water)		Seat Test (Water)		Back Seat Test (Water)		Leakage Test Air		Conclusions
Pressure (Mpa)	Time (Seconds)	Pressure (Mpa)	Time (Seconds)	Pressure (Mpa)	Time (Seconds)	Pressure (Mpa)	Time (Seconds)	ACCEPTED
3.0	300	2.2	120	/	/	0.6	120	

Body	Bonnet	Ball	Stem	Seat
A216 WCB	A216 WCB	304	304	PTFE

Heat No.	Part	C	Si	Mn	P	S	Cr	Ni	Mo	Cu	V	T.S	Y.S	El%	R.A%	Hardness
H1757	BODY	0.188	0.226	0.812	0.021	0.007	0.045	0.016	0.008	0.022	0.030	522	293	30	42	155
H1757	BONNET	0.188	0.226	0.812	0.021	0.007	0.045	0.016	0.008	0.022	0.030	522	293	30	42	155

Notes: 1.All valves are inspected and tested 100% according to the relevant standard;
2.Heat Treatment as per ASTM standards;
3.All the valve are in compliance with the order requirement and applicable drawings;
4.All the calve are tested to be satisfactory and can be delivered.

