

Unbalancing Critical Report

Report Generated : 05-Jul-2026 06:08 PM

2515441-EDSD I ACHNERA

Sub Station	DTR Name	kVA Rating	Unbalancing %	Unbalancing Stat
33/11 KV ACHHNERA	Kachora road Kamal colony 2	100.0	37.77	Critical
33/11 KV ACHHNERA	Cinema hol achhnera	100.0	45.95	Critical
33/11 KV ACHHNERA	Near bus stand dt01	100.0	30.0	Critical
33/11 KV ACHHNERA	Gulab nagar 2nd	100.0	61.35	Critical
33/11 KV ACHHNERA	Kashi ram 2nd colony	100.0	33.07	Critical
33/11 KV ACHHNERA	Balaji traders ke samane dt18	100.0	99.48	Critical
33/11 KV ACHHNERA	Pm Shri pradhikaran vidhyalaya 2nd dt 34	100.0	79.88	Critical
TAJPUR NAGRIA	Pura vale byara DT27	100.0	23.82	Critical
TAJPUR NAGRIA	Jaatav pokhar ke pass	100.0	43.68	Critical
TAJPUR NAGRIA	Byara daulat pani plant DT26	100.0	22.56	Critical
TAJPUR NAGRIA	Kailasi ki aata chakki ke pass	100.0	45.87	Critical
TAJPUR NAGRIA	Kirrya school ke anddr DT09	100.0	50.0	Critical
TAJPUR NAGRIA	Nagriya mandir ke pass DT05	100.0	52.21	Critical
SADHAN	Nagla banjara DT11	100.0	90.7	Critical
SADHAN	Prachin hanuman mandir garhima	100.0	45.37	Critical
KACHAURA	Mai near by airtel tower DT10	100.0	39.32	Critical
KACHAURA	Primary school ke pass a1	100.0	42.61	Critical
SADHAN	Sadhan sarkari hospital 1st DT09	100.0	20.25	Critical
MUBARAKPUR	VEERANGNA AWANTI BAAI SCHOOL KE SAMNE	100.0	38.84	Critical
33/11 KV ACHHNERA	Lohiya aavas colony	250.0	168.03	Critical
33/11 KV ACHHNERA	INDRA SCHOOL KE PASS 2	100.0	50.0	Critical
SADHAN	Prathmik vidyalaya ke pass	100.0	46.5	Critical
SADHAN	Rakesh pandit ke plot ke pass	100.0	88.55	Critical
SADHAN	Talab ke pass khera sandhan 2	100.0	62.13	Critical
SADHAN	Sadhan saver vala DT04	100.0	24.83	Critical
SADHAN	Prathmik vidyalaya ke samne	100.0	44.73	Critical
KACHAURA	Nawab ke plot ke pass nagla kachaura	100.0	20.68	Critical
SADHAN	Kalua thakur ke ghar ke pass	100.0	135.85	Critical
SADHAN	Podina ke khet ke pass gobara	100.0	46.29	Critical
MANDOLI	Gothra panchayat ghr ke pass DT08	100.0	52.51	Critical
SADHAN	Hasela bade talab ke pass	100.0	44.42	Critical

33/11 KV ACHHNERA	INDRA SCHOOL KE PASS	100.0	50.0	Critical
33/11 KV ACHHNERA	SARKARI BUS STAND KE SAMNE	100.0	43.0	Critical
				Total : 33

2515442-EDSD II KIRAWALI

Sub Station	DTR Name	kVA Rating	Unbalancing %	Unbalancing Stat
KIRAWALI	Gopau 4th dt15 Baba ki madi ke pass	100.0	36.6	Critical
KIRAWALI	Ngla bairavathi 6th	100.0	22.01	Critical
KIRAWALI	Nagla bherawati 2nd	100.0	45.59	Critical
33/11 KV KIRAWALI(IPDS)	Indian oil dt 01	100.0	50.49	Critical
33/11 KV KIRAWALI(IPDS)	Kriaoli ramveer ground DT01	100.0	31.46	Critical
33/11 KV KIRAWALI(IPDS)	Old bijli ghar	100.0	129.67	Critical
MIDHAKUR	DREAM CITY-7	250.0	33.2	Critical
33/11 KV KIRAWALI(IPDS)	IN FRONT OF INDIAN OVERSEAS BANK	100.0	27.39	Critical
MIDHAKUR	Nahar pr midakhur	100.0	70.28	Critical
MIDHAKUR	Gdi daulta jatav basti	100.0	182.56	Critical
KIRAWALI	Korai 1st	250.0	200.0	Critical
33/11 KV KIRAWALI(IPDS)	Chaudhary vikram singh cold dt14	315.0	25.0	Critical
KIRAWALI	Parmhunsh aasharm satha	100.0	149.76	Critical
KIRAWALI	Nagla todru	100.0	38.73	Critical
33/11 KV KIRAWALI(IPDS)	Basant Bihar colony	100.0	112.54	Critical
33/11 KV KIRAWALI(IPDS)	Dangal ground	100.0	82.2	Critical
33/11 KV KIRAWALI(IPDS)	Basant vihar kriaoli	100.0	21.07	Critical
MIDHAKUR	Jatav basti dabli DT37	100.0	65.76	Critical
MIDHAKUR	Dawali fauji market pss DT40	100.0	119.71	Critical
KIRAWALI	N S COLD store DT01	400.0	20.68	Critical
KIRAWALI	Sigarpur 2nd samudayik sauchalay	100.0	26.26	Critical
KIRAWALI	Malikpur first	100.0	28.1	Critical
33/11 KV KIRAWALI(IPDS)	Moni dham colony kriaoli	100.0	25.9	Critical
MIDHAKUR	DREAM CITY-4	250.0	80.56	Critical
MIDHAKUR	DREAM CITY -1	250.0	46.46	Critical
MIDHAKUR	DREAM CITY-3	250.0	119.43	Critical
MIDHAKUR	DREAM CITY-6	250.0	42.22	Critical
33/11 KV KIRAWALI(IPDS)	Can vibhag kriaoli	250.0	83.54	Critical
33/11 KV KIRAWALI(IPDS)	Near by kriaoli tahsil	250.0	52.98	Critical
MIDHAKUR	DREAM CITY-5	250.0	44.66	Critical
33/11 KV KIRAWALI(IPDS)	Prakash Colony	100.0	111.28	Critical
MIDHAKUR	Bijli ghar Pokhar ke paas1	100.0	162.67	Critical

KIRAWALI	Nagla hatti	100.0	35.08	Critical
SHEETAL KUND	Nahachani gyani medical store DT23	100.0	98.04	Critical
JAINGARA	SAMUDAYIK SOCHALYA KE SAMNE 1	100.0	62.28	Critical
JAINGARA	Pokhar ke pass	100.0	62.16	Critical
SHEETAL KUND	Nagla bich durgesh ki dukan ke pass DT07	100.0	39.39	Critical
SHEETAL KUND	Chirmoli tuhiram ki dukan ke pass DT03	250.0	27.99	Critical
KIRAWALI	Nagla mansa 3th dt07 chandrama ke ghar ke pass	100.0	79.68	Critical
KIRAWALI	BUDDHA KE PLOT KE PASS	100.0	47.84	Critical
SHEETAL KUND	Nagla mahasukh harvir ke ghr ke pass DT09	100.0	100.67	Critical
KIRAWALI	AMBEDKAR PARK ME	100.0	57.97	Critical
				Total : 42

2515443-EDSD III FATEHPUR SIKRI

Sub Station	DTR Name	kVA Rating	Unbalancing %	Unbalancing Stat
33/11 KV FATEHPUR SIKARI	GULMOHAR RESORT	100.0	36.06	Critical
33/11 KV FATEHPUR SIKARI	GULISTAN PARKING	100.0	75.39	Critical
33/11 KV FATEHPUR SIKARI	NEAR HOSPITAL	100.0	23.06	Critical
33/11 KV FATEHPUR SIKARI	AGRAWAL IRON STORE	100.0	200.0	Critical
33/11 KV FATEHPUR SIKARI	Lal darvaja 1	100.0	32.38	Critical
33/11 KV FATEHPUR SIKARI	PNB BANK	100.0	68.12	Critical
33/11 KV FATEHPUR SIKARI	WINE SHOP	100.0	63.78	Critical
33/11 KV FATEHPUR SIKARI	SARASWATI STUDY CENTER	100.0	200.0	Critical
MADANPURA	Patsal jagdish ke khet pr DT08	100.0	200.0	Critical
MADANPURA	Bacchon ke ghar per dt12	100.0	35.95	Critical
MADANPURA	Sonothi primary school DT16	100.0	34.04	Critical
33/11 KV FATEHPUR SIKARI	Tehra gate	100.0	25.99	Critical
FATEHPUR SIKRI IPDS	Akosh nagriya 1	100.0	24.47	Critical
33/11 KV FATEHPUR SIKARI	(Bhadkaul) DTR 04	250.0	20.29	Critical
MANGOLI KALA	Suresh pandit ji ka khet mangoli khurd	100.0	28.37	Critical
MANGOLI KALA	Nagla haribhkchh DT 14	100.0	93.65	Critical
33/11 KV FATEHPUR SIKARI	Panchayat ghar ke pass	250.0	21.69	Critical
FATEHPUR SIKRI IPDS	Bala g properties	250.0	143.75	Critical
MANGOLI KALA	Nagla jagge 1st DT 15	100.0	110.2	Critical
DOORA	Chandrahans ke plot ke pass	100.0	38.91	Critical
UNDERA	Sikrauda1	100.0	23.85	Critical
DOORA	Nagla param sukh a1	100.0	25.5	Critical
DOORA	Tikari pokhar ke pas DT 07	100.0	37.25	Critical
UNDERA	Nagla har govind d1	100.0	67.96	Critical

FATEHPUR SIKRI IPDS	Ganga prasad ji ke ghar ke pass nagla ramle	100.0	26.21	Critical
UNDERA	Deonari d3	100.0	24.01	Critical
FATEHPUR SIKRI IPDS	Jainpura dt27	100.0	65.89	Critical
DOORA	Jajau 1st sarsa raod DT01	100.0	46.23	Critical
33/11 KV FATEHPUR SIKARI	GULESTHA DUREX COMPLEX	250.0	20.98	Critical
MADANPURA	Mohhmadpur 3rd dauji pandit ji k ghar pr DT24	100.0	103.94	Critical
33/11 KV FATEHPUR SIKARI	Kheda jaat near by petrol pump DT33	250.0	25.71	Critical
33/11 KV FATEHPUR SIKARI	Near chakki new tf tehra Rawat	100.0	58.21	Critical
MADANPURA	Dr. Ambedkar samudayik kendra siroli	100.0	31.94	Critical
33/11 KV FATEHPUR SIKARI	SHIVALAYA MANDIR KE PASS	100.0	108.02	Critical
33/11 KV FATEHPUR SIKARI	Jatav basti 2	100.0	25.24	Critical
33/11 KV FATEHPUR SIKARI	GAURAV KIRANA STORE KE SAMNE	100.0	34.9	Critical
UNDERA	May 2nd pani ki tnki DT 13	100.0	25.85	Critical
UNDERA	Mandi gud mandir ke pass 03	100.0	47.83	Critical
UNDERA	Nagla beech d1	100.0	35.34	Critical
33/11 KV FATEHPUR SIKARI	RAM KISHAN COLONY ME	100.0	21.59	Critical
MADANPURA	Daudpur 8th jangi chauraha DT11	100.0	61.05	Critical
DOORA	Arera 2nd DT20	100.0	198.14	Critical
DOORA	Arera 3rd DT21	100.0	197.7	Critical
33/11 KV FATEHPUR SIKARI	PRATHMIK VIDYALAYA KE BAHAR	100.0	20.98	Critical
FATEHPUR SIKRI IPDS	Ved prakash ke ghar ke pass	100.0	73.55	Critical
33/11 KV FATEHPUR SIKARI	Indra ghati 4th	100.0	33.55	Critical
DOORA	Primary school ke pass sunhara 01	100.0	31.82	Critical
33/11 KV FATEHPUR SIKARI	NEW SURYA CITY COLONY 2	100.0	200.0	Critical
33/11 KV FATEHPUR SIKARI	Ambedkar park ke samne	100.0	50.68	Critical
FATEHPUR SIKRI IPDS	Daru Kara Sarkari school	100.0	200.0	Critical
				Total : 50