Part-4

Testing

(Initial and periodic testing of a new / existing installation up to 1000 V AC and 1500 V DC)

Testing Basics Information

Location Number*:	
Location Name*:	3434
Test Engineer Name:	2323
Date:	2021-08-12
Designation:	2323
Company Name:	232
Details Of Test Instrument:	32323
Continuity:	2323
Insulation Resistance:	232
Impedance:	3232
RCD:	3232

323

Earth Electrode Resistance:

Detailed Testing:

Distribution Board Details:	3232
Referance (name):	3232
Location:	3232
Correct Supply Polarity:	Yes
Number Of Output Circuits - Spare:	2323
Installed Equipment Vulnarable To Testing:	23
Number Of Output Circuits In Use:	2
Ratings In Amps:	23232,3

Nature of supply paramet ers	L1-L2	L2-L3	L1-L3	L1-N	L2-N	L3-N	L1-PE	L2-PE	L3-PE
Incomin g Voltage	NA	NA	NA	NA	NA	NA	23	323	232
Incomin g Zs ()	NA	23	23	32	32	23	232	3	3
Incomin g lpf (Amps)	NA	232	23	NA	2	23	23	2323	32

Circuit details									
Cicuit no	Description	Over current device							
		Standard no	R-N	Rating (A)	Breaking capacity (kA)				
NA	NA	NA	NA	NA	NA				
NA	NA	NA	NA	NA	NA				

Conductor details			Continuity ()			Insulation	resistance	Polarity
Installatio n	cross sectional area (mm2)		Required for final circuits and protective conductor only					
referance method	Live	PE / CPC	Approxim ate length		R2 ()	L-L	L-E	
NA	NA	NA	NA	NA	NA	NA	NA	NA
NA	NA	NA	NA	NA	NA	NA	NA	NA

Voltage(V) note									
L1-L2	L2-L3	L1-L3	L1-N	L2-N	L3-N	L1-PE	L2-PE	L3-PE	
NA	3232.00	23.00	23.00	233.00	23.00	23.00	23.00	23.00	
NA	3.00	23.00	23.00	2.00	23.00	23.00	2.00	23.00	

Fault loop impedance ()									
L1-L2	L2-L3	L1-L3	L1-N	L2-N	L3-N	L1-PE	L2-PE	L3-PE	
232.000	32.000	3.000	32.000	NA	NA	NA	2.000	323.000	
32.000	32.000	32.000	32.000	NA	NA	NA	32.000	32.000	

Actual Short circuit / fault current (Amps)									
L1-L2							L3-PE		
NA	NA	32.00	23.00	32.00	23.00	2.00	NA	NA	
NA	NA	323.00	323.00	2.00	23.00	23.00	NA	NA	

Disconnection time (for a short circuit/fault of negligible impedance) (seconds)									
L1-L2	L2-L3	L1-L3	L1-N	L2-N	L3-N	L1-PE	L2-PE	L3-PE	
23	32	23	NA	NA	NA	NA	NA	NA	
23	23	23	NA	NA	NA	NA	NA	NA	

	Remarks			
Live	Operating time		Test button	
	In (Current)	In	operation	
NA	NA	NA	NA	NA
NA	NA	NA	NA	NA