NP-200 Centrifugal Pump Maintenance Manual, version 1. Scope: NP-200 pump units only. This manual is superseded by version 2.

5.2 Bearing temperature monitoring. The bearing temperature alarm threshold is 75 C. A sustained reading above 75 C requires inspection. Observe the trend for 30 minutes.

6.1 Vibration limits. Vibration RMS above 4.5 mm/s indicates an abnormal mechanical condition. Check coupling alignment and bearing condition.

7.3 Communication alarms. Verify gateway power and network link before replacing any instrument.