NP-300 Feed Pump Maintenance Manual, version 1. Scope: NP-300 pump units only. Do not apply NP-200 procedures to NP-300.

5.2 Bearing temperature monitoring. The NP-300 bearing temperature alarm threshold is 85 C. NP-300 uses a different bearing cartridge.

6.1 Vibration limits. The NP-300 vibration RMS limit is 3.5 mm/s. Confirm the probe range before judging the reading.

7.1 Communication and sampling faults. Missing samples, out-of-order timestamps, or a cleared communication alarm with normal process values indicate a data-path fault, not a mechanical fault. Do not replace mechanical parts based on communication alarms alone.