

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 40

Dated: 11/08/2025

It is certified that an inspection team headed by Satya Prakash AZad

(Name of Officers with designation) from R.W.T.L. Muzaffarpur PHED

inspected the Children's Paradise Public School, Tiyatal Roy Chowk, Shekhar Akharpur, Muzaffarpur

(Name & Address of the school) on 09/08/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 65 dated 12/08/2025

of R.W.T.L. Muzaffarpur (PHED Lab) certified that the

Children's Paradise Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 08/08/2026

Signature with Seal

Name

Designation

Name & Address of the Office / Department

11/8/2025
Executive Engineer
P.H. Division, Muzaffarpur

Mukul Kumar

Executive Engineer

PHED Muzaffarpur

To
Children's Paradise Public
School, Muzaffarpur
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

PUBLIC HEALTH ENGINEERING DEPARTMENT

Water Quality Report

Division Name :- P. H. Division, Muzaffarpur

District Name : Muzaffarpur

Month : August 2025

Name of the School :- CHILDREN'S PARADISE PUBLIC SCHOOL

Sl. No.	Testing Date	Block	Panchayat	Village	Habitation/ Ward	Location of Source	pH	Turb.	Cond.	TDS	TH	Ca	Mg	Cl	Alk	Fe	No ₃	So ₄	F	As	Total Cell	Remarks
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	09.08.2025	Mushahari	Shekhpur	Shekpur Akharaghat	-	Children's Paradise Public School, Jiyalal Roy Chowk, Muzaffarpur	7.12	1.0	204.00	120.00	64.00	16.24	4.21	20.00	110.00	0.3	0.95	10.00	0.2	-	-	
Desirable Limit **							6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	0.01	-	
Permissible Limit* in absence source (IS 10500-2012 - 2nd Revision)							NR	5.0		2000	600	200	100	1000	600	1	NR	400	1.5	NR	-	


CHEMIST
 R.W.T.L. MUZAFFARPUR