Worksheet:


Control tasks

Class:


AU2

Heating control system – Functional description 1&2

Structure of the PLC program



OB100 is executed <u>once</u> <u>only</u> when you change the status of the PLC from STOP to RUN!



Please note the meaning of the following abbreviations:

OB: Organisation Block

FC: **F**unction

Datum: 28.06.12 / © by Roman Moser Datei: AUF3.4.5_HeatingControl1-2_Structure