

## Modbus Registers IQC version 1.3

### Index

COIL STATUS - DISCRETE OUTPUT (1BIT) R/W

**Application control registers .....2**

INPUT STATUS - DISCRETE INPUT (1BIT) READ ONLY

**Switch input registers .....3**

**Alarm register .....3**

INPUT REGISTER - 16 BIT INTEGER REGISTER READ ONLY

**Common identity register .....4**

**Application control registers .....4**

HOLDING REGISTER - 16 BIT INTEGER REGISTER R/W

**Application control registers .....5-12**

### Version history

Version	Date	Author	Changes	IQC Ver.
1.0	2019-10-10	FROS	Initial version 1.0.	1.00 - 1.04
1.1	2019-10-14	FROS	New added register. Restructured Holding register.	1.06 - 1.06j
1.2	2020-06-15	FROS	"Added new registers for new functions in 1.08 4x00032-33: Separate forced fan speed 4x00045: Individual pump alarms 4x00095-98: Duct pressure sensor settings Clarified description of the registers 4x00140-391 "	1.08 - 1.08c
1.3	2022-11-08	FROS	"Added new registers for new functions in 1.09h 4x00007-10, 00114-118, 00122-127, 00132-137: CAV and VAV 4x00042-43: Filter monitor limits 4x00099-108: Flow- and Filter pressure sensor settings"	1.09f - 1.09h

Coil status - Discrete Output (1bit) R/W

**Application control registers**

Modbus	Register Name	Description
0x00001	Unit on	
0x00002	Overpressure mode	
0x00003	Boost mode	
0x00004	Away mode	
0x00005	Clear Alarms	Write 1 to clear alarm, reads always 0
0x00006	Reset filter timer	Write 1 to reset filter timer, reads always 0

## Input status - Discrete Input (1bit) Read only

### Switch input registers

Modbus	Register Name	Description
1x00001	Fire alarm input	D1
1x00002	Boost input	D2
1x00003	Overpressure input	D3
1x00004	Extended operation input	D4
1x00005	Away input	D5
1x00006	Filter input	D6
1x00007	Heater interlock	D7

### Alarm registers

Modbus	Register Name	Description
1x00010	Fire alarm	
1x00011	Rotor alarm	
1x00012	RFU	Readable, value has no meaning
1x00013	Freeze alarm	
1x00014	Low supply alarm	
1x00015	Low rotor temperature alarm	
1x00016	RFU	Readable, value has no meaning
1x00017	RFU	Readable, value has no meaning
1x00018	Temp. sensor open circuit alarm	
1x00019	Temp. sensor short circuit alarm	
1x00020	Pulser alarm	
1x00021	Supply fan alarm	
1x00022	Exhaust fan alarm	
1x00023	Supply filter alarm	
1x00024	Exhaust filter alarm	
1x00025	Filter timer alarm	
1x00026	Freeze protection B level	
1x00027	Freeze protection A level	
1x00028	Startup 1st phase	Damper open, exhaust fan running.
1x00029	Startup 2st phase	Supply fan running, temperature regulation start
1x00030	Heating	
1x00031	Recovery heat/cold	
1x00032	Cooling	
1x00033	CO2 boost	0 = Off 1 = Running
1x00034	RH boost	0 = Off 1 = Running
1x00035	Pump alarm - heating	X4 DI
1x00036	Pump alarm - cooling	X13 DI
1x00037	SNC Active	0 = Off 1 = Running
1x00038	VOC boost	0 = Off 1 = Running
1x00039	RFU	Readable, value has no meaning
1x00040	RFU	Readable, value has no meaning
1x00041	RFU	Readable, value has no meaning
1x00042	RFU	Readable, value has no meaning
1x00043	RFU	Readable, value has no meaning
1x00044	RFU	Readable, value has no meaning
1x00045	RFU	Readable, value has no meaning
1x00046	Pressure deviation alarm - Supply	
1x00047	Pressure deviation alarm - Extract	
1x00048	RFU	Readable, value has no meaning
1x00049	RFU	Readable, value has no meaning
1x00050	RFU	Readable, value has no meaning
1x00051	RFU	Readable, value has no meaning
1x00052	RFU	Readable, value has no meaning
1x00053	Lost com.	Mini expansion
1x00054	RFU	Readable, value has no meaning

Input register - 16 bit integer register Read only

#### Common Identity register

Modbus	Register Name	Min	Max	Unit	Description
3x00001	Component ID				Always 10

#### Application control registers

Modbus	Register Name	Min	Max	Unit	Description
3x00002	Outdoor temperature (unit)				
3x00003	Supply air temperature (unit/duct)				
3x00004	Extract air temperature (unit)				
3x00005	Exhaust air temperature (unit)				
3x00006	Water temperature (coil)				
3x00007	Heat recovery temperature (unit)				
3x00008	Room temperature				
3x00009	RFU				Readable, value has no meaning
3x00010	RFU				Readable, value has no meaning
3x00011	RFU				Readable, value has no meaning
3x00012	Supply pressure - duct (GP1)			Pa	ska inte vara x0.1Pa, bumpas med x10
3x00013	Extract pressure - duct (GP2)			Pa	ska inte vara x0.1Pa, bumpas med x10
3x00014	RFU				Readable, value has no meaning
3x00015	RFU				Readable, value has no meaning
3x00016	RFU				Readable, value has no meaning
3x00017	RFU				Readable, value has no meaning
3x00018	Sensors open				Bit mask. Bit is set if sensor is required and open circuit. See also Sensors shorted.
3x00019	Sensors shorted				Bit mask. Bit is set if sensor is required and shorted. Bit0 = T1 ... Bit6 = T7.
3x00020	Filter days left				Number of days to filter change.
3x00021	Current weektimer program	0	5		0 = none, 1-5 = program 1-5
3x00022	RFU				Readable, value has no meaning
3x00023	Current supply fan step	0	3		0 = Off, 1 = Min, 2 = Std, 3 = Max
3x00024	Current exhaust fan step	0	3		0 = Off, 1 = Min, 2 = Std, 3 = Max
3x00025	Current supply fan power			%	
3x00026	Current exhaust fan power			%	
3x00027	Current supply fan speed			RPM	
3x00028	Current exhaust fan speed			RPM	
3x00029	Current heating power	0	255		255 = 100%
3x00030	Current heat/cold recovery power	0	255		255 = 100%
3x00031	Current cooling power	0	255		255 = 100%
3x00032	Supply fan control voltage	0	100	x0.1V	
3x00033	Exhaust fan control voltage	0	100	x0.1V	
3x00034	Changeover active	0	1		0 = Off, 1 = On
...					
3x00041	Quality sensor 1 - type				0 = None, 1 = RH, 2 = CO2, 3 = VOC
3x00042	Quality sensor 1 - value				"RH: 0-10V=0-100 (%) CO2: 0-10V=0-2000 (PPM) VOC: 0-10V=0-2000 (PPM)"
3x00043	RFU				Readable, value has no meaning
3x00044	RFU				Readable, value has no meaning
3x00045	RFU				Readable, value has no meaning
3x00046	RFU				Readable, value has no meaning

## Holding register - 16 bit integer register R/W (p. 1/4)

## Application control registers

Modbus	Register Name	Min	Max	Unit	Description
4x00001	Temperature setpoint (economy)	15	39*	°C	* Comfort setpoint -1
4x00002	Temperature setpoint (comfort)	15	40*	°C	* or maxlimit (ref. to 4x00048)
4x00003	Supply fan speed, EC	0	100	%	Read only when Fan Reg. Type CPC is used
4x00004	Exhaust fan speed, EC	0	100	%	Read only when Fan Reg. Type CPC is used
4x00005	Min exhaust fan speed, EC	0	100	%	
4x00006	Max exhaust fan speed, EC	0	100	%	
4x00007	Std supply fan airflow setpoint	0	9999	l/s	Only for regulation type CAV
4x00008	Std exhaust fan airflow setpoint	0	9999	l/s	Only for regulation type CAV
4x00009	Min exhaust fan airflow setpoint	0	*	l/s	"Only for regulation type CAV * Std exhaust fan airflow setpoint -1 "
4x00010	Max exhaust fan airflow setpoint	*	9999	l/s	"Only for regulation type CAV * Std exhaust fan airflow setpoint +1 "
4x00011	RFU				Readable, value has no meaning
4x00012	Temperature regulation mode	0	4		"0: Supply, 1: Extract, 2: Room, 3: Extract S/W, 4: Room S/W"
4x00013	Min supply temperature	15	19	°C	Used when Extraxt or Room regulation is set.
4x00014	Max supply temperature	20	40	°C	
4x00015	Supply cold limit A	2	10	°C	
4x00016	Supply cold limit B	5	12	°C	Must be greater than limit A above.
4x00017	Freeze protection limit	5	10	°C	
4x00018	RFU				Readable, value has no meaning
4x00019	SNC enabled	0	1		0 = no, 1 = yes
4x00020	SNC indoor-outdoor diff. limit	10	100	0.1°C	
4x00021	SNC exhaust high limit	18	24	°C	
4x00022	SNC exhaust low limit	19	26	°C	
4x00023	Standby temp evaluation enabled	0	1		0 = no, 1 = yes
4x00024	Interval	1	4	h	
4x00025	Evaluation time	5	15	min	
4x00026	Min. operating time	30	120	min	
4x00027	Boost duration	10	240	min	
4x00028	Overpressure duration	10	60	min	
4x00029	Overpressure offset	5	*	%	*Max value of diff. between EC Min and EC Max
4x00030	Fire sensor type	0	2		"0: None, 1: Normally open (NO), 2: Normally closed (NC)"
4x00031	Fire mode	0	3		"0: Fans off, 1: Exhaust fan only, 2: Supply fan only, 3: Both fans"
4x00032	Forced fanspeed - Supply	20	100	%	Only used when 4x00031 > 0
4x00033	Forced fanspeed - Exhaust	20	100	%	
4x00034	RFU				Readable, value has no meaning
4x00035	RFU				Readable, value has no meaning
4x00036	RFU				Readable, value has no meaning
4x00037	Filter measurement, weekday	0	6		0 = Monday, 1 = Tuesday ... 6 = Sunday.
4x00038	Filter measurement, hour	0	23	h	
4x00039	Filter measurement, minute	0	59	min	
4x00040	Filter speed increase	5	50	%pts	5 to 50 = allowed power increase in %-units. Writing 5 or less equals 5.
4x00041	Filter measurement mode	0	2		0 = Off, 1 = Switch, 2 = Speed inc.
4x00042	Supply filter - Final pressure diff.	20	500	Pa	

4x00043	Extract filter - Final pressure diff.	20	500	Pa	
4x00044	Filter change period	6	12	month	Filter timer in months. 0 = off, 6-12 time in months (30 days). Writing 5 or less equals 6.
4x00045	Alarm classes	0	65535		"Bit mask: (0=A, 1=B) bit 0: - Not used - bit 1: Sensor open bit 2: Sensor shorted bit 3: Overheat protection bit 4: - Not used - bit 5: Supply temperature low bit 6: Rotor temperature low bit 7: Fan failure bit 8: Heat exchanger bit 9: Duct pressure deviation bit 10: Pump alarm - Heating coil bit 11: Pump alarm - Cooler coil bit 12: Filter bit 13: Filter timer"
4x00046	RFU				Readable, value has no meaning
4x00047	RFU				Readable, value has no meaning
4x00048	Setpoint max limit (Comfort)	15	40	°C	Maximum selectable temperature setpoint.
4x00049	Eco. setpoint enabled	0	1		0 = no, 1 = yes
4x00050	RFU				Readable, value has no meaning
4x00051	RFU				Readable, value has no meaning
4x00052	Changeover type	1	3		0 = Temperature, 1 = Date, 2 = External input
4x00053	Supply temperature offset	-10	10	K	
4x00054	Winter start	-40	40	°C	
4x00055	Summer start	-40	40	°C	
4x00056	Time constant	0	1000	h	
4x00057	Winter start date				1102 = 2 Nov, 930 = 30 Sep
4x00058	Summer start date				1102 = 2 Nov, 930 = 30 Sep
4x00059	RFU				Readable, value has no meaning
4x00060	RFU				Readable, value has no meaning
4x00061	Flow direction	0	1		0 = standard, 1 = opposite
4x00062	Damper opening time	30	120	sec	
4x00063	Preheater type	0	1		0 = None, 1 = Electric
4x00064	Preheater enabled	0	1		0 = no, 1 = yes
4x00065	Preheater temperature set-point	-40	40	°C	
4x00066	Heater type	0	2		0 = None, 1 = Water, 2 = Electric
4x00067	Heater enabled	0	1		0 = no, 1 = yes
4x00068	Cooler type	0	1		0 = None, 1 = Water
4x00069	Cooler enabled	0	1		0 = no, 1 = yes
4x00070	RFU				Readable, value has no meaning
4x00071	RFU				Readable, value has no meaning
4x00072	RFU				Readable, value has no meaning
4x00073	RFU				Readable, value has no meaning
4x00074	RFU				Readable, value has no meaning
4x00075	RFU				Readable, value has no meaning
4x00076	RFU				Readable, value has no meaning
4x00077	RFU				Readable, value has no meaning
4x00078	RFU				Readable, value has no meaning
4x00079	RFU				Readable, value has no meaning
4x00080	RFU				Readable, value has no meaning

4x00081	Temp.sensor 1 calibration	-50	50	x0.1°C	Sensor calibration offset
4x00082	Temp.sensor 2 calibration	-50	50	x0.1°C	Sensor calibration offset
4x00083	Temp.sensor 3 calibration	-50	50	x0.1°C	Sensor calibration offset
4x00084	Temp.sensor 4 calibration	-50	50	x0.1°C	Sensor calibration offset
4x00085	Temp.sensor 5 calibration	-50	50	x0.1°C	Sensor calibration offset
4x00086	Temp.sensor 6 calibration	-50	50	x0.1°C	Sensor calibration offset
4x00087	Temp.sensor 7 calibration	-50	50	x0.1°C	Sensor calibration offset
4x00088	RFU				Readable, value has no meaning
4x00089	RFU				Readable, value has no meaning
4x00090	RFU				Readable, value has no meaning
4x00091	Quality sensor 1 limit				"RH: 0-100 (%) CO2: 0-2000 (PPM) VOC: 0-2000 (PPM)"
4x00092	RFU				
4x00093	RFU				
4x00094	RFU				Readable, value has no meaning
4x00095	Duct sensor type	0	1		0 = None, 1 = 0-10V, 2 = Modbus
4x00096	Function	0			0 = Individual (always)
4x00097	"Duct sensor - pressure range (only for 0-10V)"	0	10		"1 = 0..100 Pa, 2 = 0..250 Pa, 3 = 0..300 Pa, 4 = 0..500 Pa, 5 = 0..700 Pa, 6 = 0..1000 Pa, 7 = 0..1250 Pa, 8 = 0..1500 Pa, 9 = 0..2000 Pa, 10 = 0..2500 Pa"
4x00098	Model (only for Modbus)	0	1		0 = QBM 68.2525
4x00099	Flow sensor type	0	1		0 = None, 1 = 0-10V, 2 = Modbus
4x00100	Function	0	1		0 = Individual, 1 = Combined
4x00101	"Flow sensor - pressure range (only for 0-10V)"	0	10		"1 = 0..100 Pa, 2 = 0..250 Pa, 3 = 0..300 Pa, 4 = 0..500 Pa, 5 = 0..700 Pa, 6 = 0..1000 Pa, 7 = 0..1250 Pa, 8 = 0..1500 Pa, 9 = 0..2000 Pa, 10 = 0..2500 Pa"
4x00102	Model (only for Modbus)	0	2		0 = QBM 68.2525
4x00103	K-factor Supply			x100	
4x00104	K-factor Exhaust			x100	
4x00105	Filter sensor type	0	1		0 = None, 1 = 0-10V, 2 = Modbus
4x00106	Function	0	1		0 = Individual, 1 = Combined
4x00107	"Filter sensor - pressure range (only for 0-10V)"	0	10		"1 = 0..100 Pa, 2 = 0..250 Pa, 3 = 0..300 Pa, 4 = 0..500 Pa, 5 = 0..700 Pa, 6 = 0..1000 Pa, 7 = 0..1250 Pa, 8 = 0..1500 Pa, 9 = 0..2000 Pa, 10 = 0..2500 Pa"
4x00108	Model (only for Modbus)	0	1		0 = QBM 68.2525
4x00109	RFU				Readable, value has no meaning
4x00110	Supply setpoint (%)	10	100	%	For fan regulation type: %
4x00111	Exhaust setpoint (%)	10	100	%	
4x00112	Supply setpoint (Pa)	0	999	Pa	For fan regulation type: CPC
4x00113	Exhaust setpoint (Pa)	0	999	Pa	
4x00114	Supply setpoint (l/s)	0	9999	l/s	For fan regulation type: CAV, VAV
4x00115	Exhaust setpoint (l/s)	0	9999	l/s	
4x00116	Supply offset	-999	999	l/s	For fan regulation type: VAV
4x00117	Exhaust offset	-999	999	l/s	

<b>4x00118</b>	Exhaust Startup Setpoint	0	9999	l/s	For fan regulation type: VAV (Exhaust Fan Slave)
<b>4x00119</b>	RFU				Readable, value has no meaning
<b>4x00120</b>	Supply setpoint (%)	0	100	%	For fan regulation type: %
<b>4x00121</b>	Exhaust setpoint (%)	0	100	%	
<b>4x00122</b>	Supply setpoint (Pa)	0	999	Pa	For fan regulation type: VAV
<b>4x00123</b>	Exhaust setpoint (Pa)	0	999	Pa	
<b>4x00124</b>	Supply setpoint (l/s)	0	9999	l/s	For fan regulation type: CAV, VAV
<b>4x00125</b>	Exhaust setpoint (l/s)	0	9999	l/s	
<b>4x00126</b>	Supply offset	-999	999	l/s	For fan regulation type: VAV
<b>4x00127</b>	Exhaust offset	-999	999	l/s	
<b>4x00128</b>	RFU				Readable, value has no meaning
<b>4x00129</b>	RFU				Readable, value has no meaning
<b>4x00130</b>	Supply setpoint (%)	0	100	%	For fan regulation type: %
<b>4x00131</b>	Exhaust setpoint (%)	0	100	%	
<b>4x00132</b>	Supply setpoint (Pa)	0	999	Pa	For fan regulation type: VAV
<b>4x00133</b>	Exhaust setpoint (Pa)	0	999	Pa	
<b>4x00134</b>	Supply setpoint (l/s)	0	9999	l/s	For fan regulation type: CAV, VAV
<b>4x00135</b>	Exhaust setpoint (l/s)	0	9999	l/s	
<b>4x00136</b>	Supply offset	-999	999	l/s	For fan regulation type: VAV
<b>4x00137</b>	Exhaust offset	-999	999	l/s	
...					
<b>4x00140</b>	Week shedule enabled	0	1		0 = No, 1 = Yes. (master for toggle all programs off)
<b>4x00141</b>	WS1 On hour	0	23		
<b>4x00142</b>	WS1 On minute	0	59		
<b>4x00143</b>	WS1 Off hour	0	23		
<b>4x00144</b>	WS1 Off minute	0	59		
<b>4x00145</b>	WS1 Weekdays	0	127		Bit mask: bit 0 = Monday, bit 6 = Sunday.
<b>4x00146</b>	WS1 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00147</b>	WS1 Fan speed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00148</b>	WS1 Program enabled	0	1		0 = Disabled, 1 = Enabled
<b>4x00149</b>	RFU				Readable, value has no meaning
<b>4x00150</b>	RFU				Readable, value has no meaning
<b>4x00151</b>	WS2 On hour	0	23		
<b>4x00152</b>	WS2 On minute	0	59		
<b>4x00153</b>	WS2 Off hour	0	23		
<b>4x00154</b>	WS2 Off minute	0	59		
<b>4x00155</b>	WS2 Weekdays	0	127		Bit mask: bit 0 = Monday, bit 6 = Sunday.
<b>4x00156</b>	WS2 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00157</b>	WS2 Fan speed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00158</b>	WS2 Program enabled	0	1		0 = Disabled, 1 = Enabled
<b>4x00159</b>	RFU				Readable, value has no meaning
<b>4x00160</b>	RFU				Readable, value has no meaning
<b>4x00161</b>	WS3 On hour	0	23		
<b>4x00162</b>	WS3 On minute	0	59		
<b>4x00163</b>	WS3 Off hour	0	23		
<b>4x00164</b>	WS3 Off minute	0	59		
<b>4x00165</b>	WS3 Weekdays	0	127		Bit mask: bit 0 = Monday, bit 6 = Sunday.
<b>4x00166</b>	WS3 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00167</b>	WS3 Fan speed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00168</b>	WS3 Program enabled	0	1		0 = Disabled, 1 = Enabled
<b>4x00169</b>	RFU				Readable, value has no meaning



<b>4x00170</b>	RFU				Readable, value has no meaning
<b>4x00171</b>	WS4 On hour	0	23		
<b>4x00172</b>	WS4 On minute	0	59		
<b>4x00173</b>	WS4 Off hour	0	23		
<b>4x00174</b>	WS4 Off minute	0	59		
<b>4x00175</b>	WS4 Weekdays	0	127		Bit mask: bit 0 = Monday, bit 6 = Sunday.
<b>4x00176</b>	WS4 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00177</b>	WS4 Fan speed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00178</b>	WS4 Program enabled	0	1		0 = Disabled, 1 = Enabled
<b>4x00179</b>	RFU				Readable, value has no meaning
<b>4x00180</b>	RFU				Readable, value has no meaning
<b>4x00181</b>	WS5 On hour	0	23		
<b>4x00182</b>	WS5 On minute	0	59		
<b>4x00183</b>	WS5 Off hour	0	23		
<b>4x00184</b>	WS5 Off minute	0	59		
<b>4x00185</b>	WS5 Weekdays	0	127		Bit mask: bit 0 = Monday, bit 6 = Sunday.
<b>4x00186</b>	WS5 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00187</b>	WS5 Fan speed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00188</b>	WS5 Program enabled	0	1		0 = Disabled, 1 = Enabled
...					
<b>4x00200</b>	Holiday shedule enabled	0	1		0 = No, 1 = Yes. (master for toggle all programs off)
<b>4x00201</b>	HS1 Start year				e.g.2019
<b>4x00202</b>	HS1 Start date				1102 = 2 Nov, 930 = 30 Sep
<b>4x00203</b>	HS1 Start hour	0	23		
<b>4x00204</b>	HS1 Start minute	0	59		
<b>4x00205</b>	HS1 End year				
<b>4x00206</b>	HS1 End date				
<b>4x00207</b>	HS1 End hour	0	23		
<b>4x00208</b>	HS1 End minute	0	59		
<b>4x00209</b>	HS1 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00210</b>	HS1 Fanspeed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00211</b>	HS1 Program enabled	0	1		Bit mask: B0 (1 = On)
...					
<b>4x00221</b>	HS2 Start year				e.g.2019
<b>4x00222</b>	HS2 Start date				1102 = 2 Nov, 930 = 30 Sep
<b>4x00223</b>	HS2 Start hour	0	23		
<b>4x00224</b>	HS2 Start minute	0	59		
<b>4x00225</b>	HS2 End year				
<b>4x00226</b>	HS2 End date				
<b>4x00227</b>	HS2 End hour	0	23		
<b>4x00228</b>	HS2 End minute	0	59		
<b>4x00229</b>	HS2 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00230</b>	HS2 Fanspeed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00231</b>	HS2 Program enabled	0	1		Bit mask: B0 (1 = On)
...					
<b>4x00241</b>	HS3 Start year				e.g.2019
<b>4x00242</b>	HS3 Start date				1102 = 2 Nov, 930 = 30 Sep
<b>4x00243</b>	HS3 Start hour	0	23		
<b>4x00244</b>	HS3 Start minute	0	59		
<b>4x00245</b>	HS3 End year				
<b>4x00246</b>	HS3 End date				

<b>4x00247</b>	HS3 End hour	0	23		
<b>4x00248</b>	HS3 End minute	0	59		
<b>4x00249</b>	HS3 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00250</b>	HS3 Fanspeed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00251</b>	HS3 Program enabled	0	1		Bit mask: B0 (1 = On)
...					
<b>4x00261</b>	HS4 Start year				e.g.2019
<b>4x00262</b>	HS4 Start date				1102 = 2 Nov, 930 = 30 Sep
<b>4x00263</b>	HS4 Start hour	0	23		
<b>4x00264</b>	HS4 Start minute	0	59		
<b>4x00265</b>	HS4 End year				
<b>4x00266</b>	HS4 End date				
<b>4x00267</b>	HS4 End hour	0	23		
<b>4x00268</b>	HS4 End minute	0	59		
<b>4x00269</b>	HS4 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00270</b>	HS4 Fanspeed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00271</b>	HS4 Program enabled	0	1		Bit mask: B0 (1 = On)
...					
<b>4x00281</b>	HS5 Start year				e.g.2019
<b>4x00282</b>	HS5 Start date				1102 = 2 Nov, 930 = 30 Sep
<b>4x00283</b>	HS5 Start hour	0	23		
<b>4x00284</b>	HS5 Start minute	0	59		
<b>4x00285</b>	HS5 End year				
<b>4x00286</b>	HS5 End date				
<b>4x00287</b>	HS5 End hour	0	23		
<b>4x00288</b>	HS5 End minute	0	59		
<b>4x00289</b>	HS5 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00290</b>	HS5 Fanspeed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00291</b>	HS5 Program enabled	0	1		Bit mask: B0 (1 = On)
...					
<b>4x00301</b>	HS6 Start year				e.g.2019
<b>4x00302</b>	HS6 Start date				1102 = 2 Nov, 930 = 30 Sep
<b>4x00303</b>	HS6 Start hour	0	23		
<b>4x00304</b>	HS6 Start minute	0	59		
<b>4x00305</b>	HS6 End year				
<b>4x00306</b>	HS6 End date				
<b>4x00307</b>	HS6 End hour	0	23		
<b>4x00308</b>	HS6 End minute	0	59		
<b>4x00309</b>	HS6 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00310</b>	HS6 Fanspeed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00311</b>	HS6 Program enabled	0	1		Bit mask: B0 (1 = On)
...					
<b>4x00321</b>	HS7 Start year				e.g.2019
<b>4x00322</b>	HS7 Start date				1102 = 2 Nov, 930 = 30 Sep
<b>4x00323</b>	HS7 Start hour	0	23		
<b>4x00324</b>	HS7 Start minute	0	59		
<b>4x00325</b>	HS7 End year				
<b>4x00326</b>	HS7 End date				
<b>4x00327</b>	HS7 End hour	0	23		
<b>4x00328</b>	HS7 End minute	0	59		
<b>4x00329</b>	HS7 Temp.mode	0	1		0 = Comfort, 1 = Economy

<b>4x00330</b>	HS7 Fanspeed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00331</b>	HS7 Program enabled	0	1		Bit mask: B0 (1 = On)
...					
<b>4x00341</b>	HS8 Start year				e.g.2019
<b>4x00342</b>	HS8 Start date				1102 = 2 Nov, 930 = 30 Sep
<b>4x00343</b>	HS8 Start hour	0	23		
<b>4x00344</b>	HS8 Start minute	0	59		
<b>4x00345</b>	HS8 End year				
<b>4x00346</b>	HS8 End date				
<b>4x00347</b>	HS8 End hour	0	23		
<b>4x00348</b>	HS8 End minute	0	59		
<b>4x00349</b>	HS8 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00350</b>	HS8 Fanspeed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00351</b>	HS8 Program enabled	0	1		Bit mask: B0 (1 = On)
...					
<b>4x00361</b>	HS9 Start year				e.g.2019
<b>4x00362</b>	HS9 Start date				1102 = 2 Nov, 930 = 30 Sep
<b>4x00363</b>	HS9 Start hour	0	23		
<b>4x00364</b>	HS9 Start minute	0	59		
<b>4x00365</b>	HS9 End year				
<b>4x00366</b>	HS9 End date				
<b>4x00367</b>	HS9 End hour	0	23		
<b>4x00368</b>	HS9 End minute	0	59		
<b>4x00369</b>	HS9 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00370</b>	HS9 Fanspeed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00371</b>	HS9 Program enabled	0	1		Bit mask: B0 (1 = On)
...					
<b>4x00381</b>	HS10 Start year				e.g.2019
<b>4x00382</b>	HS10 Start date				1102 = 2 Nov, 930 = 30 Sep
<b>4x00383</b>	HS10 Start hour	0	23		
<b>4x00384</b>	HS10 B253Start minute	0	59		
<b>4x00385</b>	HS10 End year				
<b>4x00386</b>	HS10 End date				
<b>4x00387</b>	HS10 End hour	0	23		
<b>4x00388</b>	HS10 End minute	0	59		
<b>4x00389</b>	HS10 Temp.mode	0	1		0 = Comfort, 1 = Economy
<b>4x00390</b>	HS10 Fanspeed	1	4		0 = Standby, 1 = Min, 2 = Std, 3 = Max
<b>4x00391</b>	HS10 Program enabled	0	1		Bit mask: B0 (1 = On)
...					
<b>4x00400</b>	Year				
<b>4x00401</b>	Month	1	12		
<b>4x00402</b>	Day (in month)	1	31		Reading this copies time to read/write buffer.
<b>4x00403</b>	Clock, Hours	0	23		
<b>4x00404</b>	Clock, Minutes	0	59		
<b>4x00405</b>	Clock, Seconds	0	59		Writing this writes time from read/write buffer
...					

4x00901	Modbus-adress	1	255		ID
4x00902	Baudrate	0	7		"0 = 9600, 1 = 14400, 2 = 19200, 3 = 28800, 4 = 38400, 5 = 57600, 6 = 115200, 7 = 230400"
4x00903	Stopbit				0 = Auto, 1 = 1bit, 2 = 2bits
4x00904	Parity				0 = None, 1 = Odd, 2 = Even
...					
4x00920	Exhaust Fan PID, Proportional	0	1000		
4x00921	Exhaust Fan PID, Integral	0	1000		
4x00922	Exhaust Fan PID, Derivative	0	1000		
4x00923	Supply Fan PID, Proportional	0	1000		
4x00924	Supply Fan PID, Integral	0	1000		
4x00925	Supply Fan PID, Derivative	0	1000		
4x00926	Heating PID, Proportional	0	1000		
4x00927	Heating PID, Integral	0	1000		
4x00928	Heating PID, Derivative	0	1000		
4x00929	Recovery PID, Proportional	0	1000		
4x00930	Recovery PID, Integral	0	1000		
4x00931	Recovery PID, Derivative	0	1000		
4x00932	Cooling PID, Proportional	0	1000		
4x00933	Cooling PID, Integral	0	1000		
4x00934	Cooling PID, Derivative	0	1000		
4x00935	Room PID, Proportional	0	1000		
4x00936	Room PID, Integral	0	1000		
4x00937	Room PID, Derivative	0	1000		
4x00938	Rh PID, Proportional	0	1000		
4x00939	Rh PID, Integral	0	1000		
4x00940	Rh PID, Derivative	0	1000		
4x00941	CO2 PID, Proportional	0	1000		
4x00942	CO2 PID, Integral	0	1000		
4x00943	CO2 PID, Derivative	0	1000		
4x00944	VOC PID, Proportional	0	1000		
4x00945	VOC PID, Integral	0	1000		
4x00946	VOC PID, Derivative	0	1000		
*	For units with pressure outlets				