

## ECDC's ENERGY ISOLATION POLICY

Any isolation of energy, mechanical, electrical, process, hydraulic and other systems, cannot proceed unless:


- Methods of isolation and discharge of stored energy are agreed and executed by competent person(s);
- Any stored energy is discharged;
- The system of lockout and tag out is utilized at isolation points
- Test is conducted to ensure the isolation is effective;
- Isolation effectiveness is periodically monitored.

  
**Dr. Mohamed Farouk**  
Managing Director

## سياسة الشركة المصرية الصينية للحفر لعزل الطاقة

لا يمكن الاستمرار في أي عزل للطاقة سواء كان ميكانيكي ، أو كهربائي ، أو معالجة ، أو هيدروليكي أو أي أنظمة أخرى ، إلا إذا:

- الموافقة على طرق عزل وتفريغ الطاقة المخزنة وتنفيذها من قبل شخص (أشخاص) مختصين.
- يتم تفريغ أي طاقة مخزنة.
- يتم استخدام نظام القفل والاشارة في نقاط العزل
- يتم إجراء الاختبار للتأكد من أن العزل فعال.
- يتم مراقبة فعالية العزل بشكل دوري.

  
**Mr. Xu Yong**  
GM and Managing Director