

Aldervale Department of Health

Bureau of Youth Camp Licensing

1400 Lakeview Parkway, Suite 300, Brennon, AV 04210
(555) 300-2200

Report Ref: FIR-TAM-2025

Inspection date: 07/15/2025

Facility Inspection Report - Tamarack Ridge (Residential), 2025 season

Inspected by: D. Castillo, R.S., Environmental Health Specialist. Unannounced operational inspection during the camp season.

Summary

The waterfront was observed in operation with campers present. Water chemistry was tested independently at the time of inspection and compared with the camp's logs. Rotation paperwork, buddy-board practice, safety equipment, signage, sanitation facilities, and deck structures were reviewed. Detailed category findings appear below.

Category findings

Category	Finding	Notes
Water Chemistry	Pass	In order at time of inspection.
Disinfection/Circulation	Pass	In order at time of inspection.
Safety Equipment	Pass	In order at time of inspection.
Signage	Pass	In order at time of inspection.
Sanitation Facilities	Minor	Soap dispenser at the bathhouse empty at time of inspection; restocked.
Drain/Entrapment	Pass	In order at time of inspection.
Staffing/Lifeguard Coverage	Pass	In order at time of inspection.
Recordkeeping	Pass	In order at time of inspection.
Structural/Deck	Pass	In order at time of inspection.

Water chemistry at time of inspection

Independent readings: free chlorine 2.4 ppm, pH 7.4, combined chlorine 0.1 ppm, cyanuric acid 38 ppm, water temperature 76 F - all within the ranges the camp tracks per CDC Model Aquatic Health Code norms. The camp's own log entries for the inspection date were consistent with these readings.

Conclusion

The facility is in substantial compliance with the operational requirements of the licensing regulations. Minor findings above carry no enforcement action. This report addresses facility and operational conditions only; credential and licensing-status matters are handled separately by the Bureau.

Respectfully submitted,

D. Castillo, R.S.
Environmental Health Specialist