

Signature Detectors/Modules Barcode Worksheet

Project: SYNERGY Version: 21.02.11 Cabinet: FACP 3-SSDC1: LOOP_1

2/11/2021 8:25:37 AM

EST3 System Definition Utility Version 05.42.00

Detectors (Loop 1)




<u>Label</u> Device Type	<u>Location</u> Text	<u>Model</u> Base	<u>Device Address</u> Barcode Number	<u>Serial Number</u> Barcode
SD_1_DLR SMOKE	SMOKE DETECTOR L1D1 AT FACP	PS Standard Base	 01020001	3902009904
DD_2_DLR SUPERVISORY	DUCT DETECTOR L1D2 FL 1 ELEC 122	SD Relay Base or remote LED	 01020002	
DD_3_DLR SUPERVISORY	DUCT DETECTOR L1D3 FL 1 TENANT 143	SD Relay Base or remote LED	 01020003	3949140158
DD_4_DLR SUPERVISORY	DUCT DETECTOR L1D4 FL 1 LOBBY 173	SD Relay Base or remote LED	 01020004	3949158931
SD_5_DLR SMOKE	SMOKE DETECTOR L1D5 FL 1 ELEV 1/2 LOBBY	PS Standard Base	 01020005	3901992122
SD_6_DLR SMOKE	SMOKE DETECTOR L1D6 FL 1 ELEV 3 LOBBY	PS Standard Base	 01020006	3902009119
SD_7_DLR SMOKE	SMOKE DETECTOR L1D7 ELEV 1/2 TOP OF SHAFT	PS Standard Base	 01020007	3902010085
HD_8_DLR HEAT	HEAT DETECTOR L1D8 ELEV 1/2 TOP OF SHAFT	HFS Standard Base	 01020008	3682858709

Signature Detectors/Modules Barcode Worksheet





2/11/2021 8:25:37 AM

Project: SYNERGY Version: 21.02.11 Cabinet: FACP 3-SSDC1: LOOP_1

EST3 System Definition Utility Version 05.42.00

SD_65_DLR SMOKE	SMOKE DETECTOR L1D65 FL 5 ELEV 3 LOBBY	PS Standard Base	 01020065	3902000215
DD_66_DLR SUPERVISORY	DUCT DETECTOR L1D66 FL 5 S. OF ELEV 3	SD Relay Base or remote LED	 01020066	3949139756
DD_67_DLR SUPERVISORY	DUCT DETECTOR L1D67 FL 5 RTU-2	SD Relay Base or remote LED	 01020067	3949155404

Modules (Loop 1)

<u>Label</u> Device Type	<u>Location</u> Text	<u>Model</u> Personality	<u>Device Address</u> Barcode Number	<u>Serial Number</u> Barcode
PS_126_DLR PULL	PULL STATION L1M126 AT FACP	278 (1) Alarm - NO latching (Class B)	 01020126	4897971573
WF_127_DLR WATERFLOW	MAIN FLOW L1M127 FIRE RISER ROOM P254	CT2 (1) Alarm - NO latching (Class B)	 01020127	4919104309
EXT_HS_128 MONITOR		CT2 (3) Active - NO nonlatching (Class B)	 01020128	4919104316
SEF1_FAN_CTRL_129 FANFEEDBACK	IO-L1M129 SEF-1 CTRL ON ROOF	IO (37) Active - NO nonlatching input/output	 01020129	4795809039

Signature Detectors/Modules Barcode Worksheet

2/11/2021 8:25:37 AM

Project: SYNERGY Version: 21.02.11 Cabinet: FACP 3-SSDC1: LOOP_1

EST3 System Definition Utility Version 05.42.00

LA_130_DLR SUPERVISORY	Z1 LOW AIR L1D130 FIRE RISER ROOM P254	CT2 (3) Active - NO nonlatching (Class B)	 01020130	4919106204
WF_131_DLR WATERFLOW	Z1 DRY FLOW L1M131 FIRE RISER ROOM P254	CT2 (1) Alarm - NO latching (Class B)	 01020131	4919106211
TS_132_DLR TAMPER	Z1 DRY TAMPER L1M132 FIRE RISER ROOM P254	CT1 (3) Active - NO nonlatching (Class B)	 01020132	4821668517
LA_133_DLR SUPERVISORY	Z2 LOW AIR L1D133 FIRE RISER ROOM P254	CT2 (3) Active - NO nonlatching (Class B)	 01020133	4919421727
WF_134_DLR WATERFLOW	Z2 DRY FLOW L1M134 FIRE RISER ROOM P254	CT2 (1) Alarm - NO latching (Class B)	 01020134	4919421734
TS_135_DLR TAMPER	Z2 DRY TAMPER L1M135 FIRE RISER ROOM P254	CT1 (3) Active - NO nonlatching (Class B)	 01020135	4821668173
WF_136_DLR WATERFLOW	Z3 DRY FLOW L1M136 FIRE RISER ROOM P254	CT1 (1) Alarm - NO latching (Class B)	 01020136	4821641725
TS_137_DLR TAMPER	Z2 DRY TAMPER L1M137 FIRE RISER ROOM P254	CT1 (3) Active - NO nonlatching (Class B)	 01020137	4821671722
TS_138_DLR TAMPER	PUMP TAMPERS L1M138 FIRE RISER ROOM P254	CT1 (3) Active - NO nonlatching (Class B)	 01020138	4822734457