

Service Cockpit · TH-02298

Technical Visit Briefing

Telemetry snapshot: 30 Jul 2026 · Evidence handover

Unit ID	Customer	OEM
TH-02298	Dieter Niehaus	OEM C
Service tier	Region	
Free	80	

Reason for visit


Persistent OEM signal — ALM_HP_LOWFLOW

First observed	Last observed	Persistence
17 Jul 2026	30 Jul 2026	14 reporting days
Meaning not validated.		

Signal history

ALM_HP_LOWFLOW

1 Jul–30 Jul 2026 · Signal occurrence by reporting day



Latest telemetry status

Data state	Latest reading	Reading age
Current	30 Jul 2026	0 days before snapshot
54 / 60 reporting days · 90% coverage		
Telemetry recency, not equipment condition.		

Latest available telemetry

Measurement	Value
Outdoor temperature	21.8 °C
Electrical energy	0.96
Defrost cycles	0
Status	warn
Raw OEM energy / status semantics require validation.	

Service context

Commissioning date
4 Jun 2024

Last service visit
Not provided

Data limitations

Not available in OEM C extract

Return temperature · Thermal energy · Compressor starts

Intermittent in OEM C extract

Flow temperature · DHW temperature · Status

Missing in latest reading

Flow temperature · DHW temperature

Field support: supplied extract only; OEM validation required. OEM energy values are not comparable across vendors.

TH-02298 · Technical Visit Briefing

