



Storm Water Review

Record No. CCSP-26-1

Status Active

Became Active February 2, 2026

Type Approval

Due Date None

Assignee Robert Moore

Record No: CCSP-26-1

City Council Special Permit

Status: Active

Submitted On: 1/9/2026

Applicant



Jony Perez



978-375-0639



@ jony_perez@hotmail.com



121 Merrimack Street
Haverhill, MA 01830

Messages

Robert Moore

February 2, 2026 at 4:14 pm

1. Please provide civil site plan for actual proposed conditions.
2. The Plan of Land prepared by MES shows a CB in the parking lot, just off the NW building corner is connected to the Sanitary Sewer in How Street. Site plan must show the disconnection of this system from the sanitary.
3. Show new parking lot drainage system. New system must meet today's BMP design standards.
4. Design should include stormwater management improvements, such as the collection and recharge of roof runoff through an infiltration gallery. Standard is to design the system to accommodate the 1/2" rain event, with overflow then connecting to the drain main.
5. Site plan must include erosion and sediment control measures for any land disturbance that might be needed, i.e. protection of drainage system during any necessary parking lot reconstruction.
6. Submittal includes a general landscape plan (by G J Design Group, 1-30-26). Additional detail should be added to this sheet to demonstrate compliance with the landscaping requirements under C. 255-6.3. Please add such items as plant species, sizes, seed mixes, playground surface treatment...

@Shaun Burrier

Jony Perez

February 20, 2026 at 12:05 pm

Hi Robert, We are updating the site plan to address these concerns. New site plan should be uploaded next week. Thank you!

Kaitlin Wright  Internal

March 18, 2026 at 10:33 am

@Robert Moore please provide any updates to your review by close of business tomorrow 3/19 as this is coming before council next week.

Robert Moore

March 18, 2026 at 5:12 pm

@Kaitlin Wright @Shaun Burrier I understand this matter is slated for hearing at the March 24th Council meeting. We have not yet received the revised plan that Jony mentions on February 20th. The plan should not only address the departmental comments within this record, but should also demonstrate how the project will comply with the Performance Standards found within the Zoning Code under C. 255, s. 6.3. Should the Council look to move on this application Tuesday night, I would request any motion to

approve be conditioned to require the applicant to address all departmental comments to the satisfaction of the individual departments during the Development Review procedure.

Kaitlin Wright

March 19, 2026 at 8:49 am

@Robert Moore Would you recommend the matter be continued until the applicant provides the requested documents? It would seem that the application is not complete based off the requirements to draft another plan from the in person meeting. @Jacki Byerley can you weigh in?

Jacki Byerley

March 20, 2026 at 10:08 am

I would recommend the Council open the hearing and continue it to a later date until they file for the Site Plan of Section 10.8 and satisfy the comments received.



DPW Review

Record No. CCSP-26-1

Status Active

Became Active February 2, 2026

Type Approval

Due Date None

Assignee Robert Ward

Record No: CCSP-26-1

City Council Special Permit

Status: Active

Submitted On: 1/9/2026

Applicant



Jony Perez



978-375-0639



@ jony_perez@hotmail.com



121 Merrimack Street

Haverhill, MA 01830

Messages

Kaitlin Wright

March 18, 2026 at 10:32 am

@Robert Ward @Robert Kimball Please review as this is coming before Council on March 24th.



Police Department Review

Record No. CCSP-26-1

Status Active

Became Active February 2, 2026

Type Approval

Due Date None

Assignee Kevin Lynch

Record No: CCSP-26-1

City Council Special Permit

Status: Active

Submitted On: 1/9/2026

Applicant



Jony Perez



978-375-0639



@ jony_perez@hotmail.com



121 Merrimack Street
Haverhill, MA 01830

Messages

Kevin Lynch

February 16, 2026 at 12:57 am

The Police Department has concerns regarding the proposed drop-off and pick-up operations for this facility.

The applicant has indicated plans to operate 36 slots for infants and toddlers (birth to 2.9 years old) and one Pre-K classroom serving up to 20 children (2.9 to 5 years old). The facility will employ approximately 18–20 full-time staff members. Based on these numbers, there is concern that the available on-site parking will be insufficient to accommodate the anticipated traffic volume.

The current site plan reflects five designated parking spaces for drop-off and pick-up. However, it appears that the EV charging stations may be located within the same designated drop-off/pick-up area, which could further reduce usable short-term parking availability.

How Street is currently posted "No Parking," and Merrimack Street reflects only one handicap parking space in front of the building. This area is already heavily congested. The Department is concerned about the potential for excessive vehicle stacking and traffic congestion on How Street during peak drop-off (7:45 AM – 8:45 AM) and pick-up hours (4:30 PM – 6:00 PM).

The applicant is requested to provide a detailed written traffic management plan addressing the following:

1. How vehicle flow will be managed during peak drop-off and pick-up times.
2. How the facility will ensure that vehicles do not queue or line up on How Street.
3. What contingency measures will be implemented if vehicle stacking or congestion occurs.
4. How staff parking will be accommodated so as not to interfere with parent drop-off and pick-up operations.

Additionally, with upcoming construction anticipated in the area, there is concern that roadway limitations and temporary disruptions may further complicate traffic flow. The applicant should address how construction impacts will be mitigated within the proposed traffic management plan.

Jony Perez

February 20, 2026 at 11:59 am

Hi Kevin, we just uploaded a plan to address the concerns by the police department. Please advice. Thank you!

Kaitlin Wright  Internal

March 18, 2026 at 10:32 am

@Kevin Lynch please provide any updates to your review by close of business tomorrow 3/19 as this is coming before council next weeeek.



Water/Wastewater Review

Record No. CCSP-26-1

Status Active

Became Active February 2, 2026

Type Approval

Due Date None

Assignee Shaun Burrier

Record No: CCSP-26-1

City Council Special Permit

Status: Active

Submitted On: 1/9/2026

Applicant



Jony Perez



978-375-0639



jony_perez@hotmail.com



121 Merrimack Street

Haverhill, MA 01830

Messages

Shaun Burrier

February 3, 2026 at 8:17 am

Please provide updated civil site plan showing sewer connection details including location, size of connection, materials, and slope.

Please submit water service application to include all fixture counts and any and all fire suppression requirements.

Jony Perez

February 20, 2026 at 12:05 pm

Hi Shaun, We are updating the site plan to address these concerns. New site plan should be uploaded next week. Thank you!

Kaitlin Wright  Internal

March 18, 2026 at 10:33 am

@Shaun Burrier please provide any updates to your review by close of business tomorrow 3/19 as this is coming before council next week.



Building Inspector Review

Record No. CCSP-26-1

Status Active

Became Active February 2, 2026

Type Approval

Due Date None

Assignee Tom Bridgewater

Record No: CCSP-26-1

City Council Special Permit

Status: Active

Submitted On: 1/9/2026

Applicant



Jony Perez



978-375-0639



@ jony_perez@hotmail.com



121 Merrimack Street

Haverhill, MA 01830

Messages

Kaitlin Wright

March 18, 2026 at 10:33 am

@Tom Bridgewater @Richard MacDonald Please review as this is coming before Council on March 24th.