



ISOMETRIC IFC - CHECK LIST


Line Number	021501VT0001_01			Stress CN / Level		Nº EJ	Level: I	
Isometric Number	023A1021501VT0001_01			Process Approval Required		YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/>	
			Intrumentation Approval Required (N/A)		YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>		
Information to be attached:								
Master Copy of PID:	YES <input checked="" type="checkbox"/>	N/A <input type="checkbox"/>	Nº 800124-025-PID-0021-001		Rev. 0 IFC			
PID Modification Sheet:	YES <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>	Nº		Rev.			
Equipment Vendor Dwg. :	YES <input checked="" type="checkbox"/>	N/A <input type="checkbox"/>	Nº 021501TK001		Rev.			
Instrument Dwg. :	YES <input checked="" type="checkbox"/>	N/A <input type="checkbox"/>	Nº		Rev.			
Project By-Pass ⁽⁴⁾ :	YES <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>	Nº		Rev.			
SPO Approved Isometric:	YES <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>	Rev.		Extraction Date:			
SIT Approved Isometric:	YES <input checked="" type="checkbox"/>	N/A <input type="checkbox"/>	Rev.		Extraction Date:			

A VERIFICAR / TO BE CHECKED					* N/A * NO APLICA / NOT APPLICABLE	IFC	REV 0	REV 1	REV 2
Revision By : (D) Designer / (LDG) Design Leader / (ST) Stress Specialist / (LST) Stress Leader / (SP) Supports Specialist / (LSP) Supports leader / (M) Materials / (SL) Spooler / (CHK) Issuer / (L) Discipline Lead						✓	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Revision By : (D) Designer / (LDG) Design Leader						✓	X ⁽¹⁾	1st-Chk ⁽²⁾	2nd-Chk ⁽³⁾
						By: D		By: LDG	
Iso Information	Nº de línea según PID y lista de líneas / Line Nbr. according to PID and line list					✓		✓	
	Datos de la línea según lista de líneas / Line data according to line list					✓		✓	
	Clase de tubería según PID y Lista de Líneas / Piping class according to PID and Line List					✓		✓	
	Vínculo E3D con Diagrams (Process Unit, Temp Operación, Numeracion TODAS válvulas manuales) / Link between E3D and Diagrams (Process Unit, Op Temp, ALL manual valves Tagged)					✓		✓	
	Diámetro de la línea indicado en número de línea en el cajetín / Line diameter indicated in the line number in the title block					✓		✓	
Equipment	Equipo modelado según plano Vendor válido para generar isométrica IFC / Equipment modelled according Vendor drawing valid for Isometric IFC generation					✓		✓	
	Código / Code: 2 <input checked="" type="checkbox"/> 3 <input type="checkbox"/>				✓		✓		
	Nombre de tubuladuras según PID y plano Vendor / Name of nozzle according to PID and Vendor drawing				✓		✓		
	Rating y diámetro de tubuladuras según plano Vendor / Rating and diameter of nozzles according to vendor drawing				✓		✓		
Revision By : (D) Designer / (LDG) Design Leader						By: D		By: LDG	
Line Design	Línea sin colisión (verificación incluyendo la nube de puntos) / Line is clash free (checked including points cloud)				✓		✓		
	Comentarios de SPO a líneas críticas recibidos e implementados antes de extracción final para emisión / Process comments to critical lines received and implemented before final extraction for issuance			✓					
	Verificación contra P&ID y Lista de Líneas / Check Iso vs P&ID and Line List : Correcta referencia de la continuidad de la isométrica en líneas nuevas, líneas existentes u otra hoja de la isométrica en los extremos de línea y sus ramales, incluyendo elevaciones y coordenadas / Correct continuity isometric reference to new lines, existing lines or other isometric sheet in each end of the line and its branches including elevations and coordinates				✓		✓		
	Verificación contra P&ID / Check Iso vs P&ID : Elementos en línea incluidos, secuencia de picajes, pendiente, sentido de flujo, numeración de instrumentos, cambios de especificación, cumplimiento de notas / in-line components included, branch sequence, slope, flow direction, instrument numbering, pipe class breaks, notes accomplishment				✓		✓		
	Verificación contra P&ID / Check Iso vs P&ID : Longitudes requeridas de entrada y/o salida a equipos, distancias y/o elevaciones mínimas o máximas requeridas, formación de condensados / Required inlet and/or outlet lengths to equipments, minimum or maximum distances and/or elevations, condensate generation				✓		✓		
	Comentarios de SIT a recibidos e implementados antes de extracción final para emisión / Instrumentation comments received and implemented before final extraction for issuance			✓			✗	✓	
	Verificación contra Planos de Vendor o Hook-up Instrumentacion / Check Iso vs Instrument Vendor Drawings or Hook-up : Tamaño de las válvulas de control y de seguridad, instalación de acuerdo a hook-up / Size of control valves and safety valves, instrument installation according to hook-up				✓		✓		
	Picajes según tabla de picajes correspondiente / Branch configuration according to correspondent branch table			✓					
	Venteos y drenajes de Procesos según requerimientos de PIDs y de puntos altos y bajos para prueba hidrostática y modelados según "assembly" correspondiente / Process vents and drains according PID requirements and high and low points for hydrostatic test and modelled according proper assembly			✓					
	Verificación de distancia mínima entre soldaduras / Check minimum distance between welds			✓					
	Notas explicativas adicionales incorporadas / Additional clarification notes added			✓					
	Revision By : (ST) Stress Specialist / (LST) Stress Leader					By: ST		By: LST	
Stress	El cálculo de stress disponible no está pendiente de revisión en curso / Available stress calculation is not awaiting for revision								
	Los requisitos según el cálculo de stress están incorporados (si son aplicables) / Stress calculation requirements have been added (if applicable)								
Revision By : (SP) Supports Specialist / (LSP) Supports leader					By: SP		By: LSP		
Supports	La línea está soportada por completo y la lista de soportes rellenada / Line is completely supported and support list updated								
	Concepto de soporte y separación máxima entre soportes / Support concept and support spans								
	Requerimientos de soportes estan de acuerdo al cálculo de stress y ajustados con el especialista de Stress / Support requirements according to stress calculation note are included and adjusted jointly with stress specialist								
	Numeración correcta de los soportes / Supports correctly numbered								
	Código de soportes correctamente indicados (STD - SPC - COM - MRS - PRF) / Support code correctly indicated (STD - SPC - COM - MRS - PRF)								
Revision By : (M) Materials					By: M				
Materials	La Línea pertenece a alguna o varias categorías de Criticidad. La Línea está listada en la Lista de Líneas Críticas de Materiales. Sus isometricas requieren Verificacion exahustiva / The Line belongs to some or several categories of Criticality. The Line is listed in the Critical Material Lines List. The isometrics require exahustive verification			N/A	✓	✓			
	Todos los materiales están identificados en la isométrica y se encuentran listados en el listado de materiales / All materials are identified in the isometric and are listed in the BOM								
	Añadidos elementos especiales de tubería en Línea de acuerdo a PIDs última revisión y lista de especiales de tubería (Verificar en adicional correcta Numeración, criterios de Posicionamiento en diseño si aplican) / Inclusion of special piping elements in line according to PIDs latest review and Special Piping Material List (Verify identification number, piping design location criteria if applicable)			N/A					
	Nº de identificación de válvulas manuales (según PID)/ Identification number of manual valve (according to PID)			N/A					
	Todas las juntas y pernos colocadas según tipo requerido (RF, FF, Bolts, Machine Bolts) / All gaskets and bolts placed according required type (RF, FF, Bolts, Machine Bolts)				✗	✓			
Revision By : (CHK) Issuer					By: CHK				
Final Check					✓	X	✓	X	
	La isométrica verificada por Procesos (SPO) se corresponde a la última revisión / The isometric verified by Process (SPO) corresponds to its last revision			✓					
	La isométrica verificada por Instrumentación (SIT) se corresponde a la última revisión / The isometric verified by Instrumentation (SIT) corresponds to its last revision			✓					
	Las notas a mano están incorporadas en las isométricas / The hand-made annotation is included				✓				
	La revisión de los documentos para la verificación siguen siendo las actuales / Current revision of documents for checking are still the latest available				✓				
	El número de revisión y la fecha son correctos / The revision number and the date are correct				✓				
	Todos los comentarios se han revisado para se incluidos o descartados / All comments have been checked to be included or discarded				✓				
	Holds resueltos o en su defecto By-Pass aprobado / Holds resolved or instead By-Pass approved				✓				


SIGNATURES (Name and date)					
DESIGN LEADER (LD)	REVIEWED By oscar at 1:12 pm, Feb 10, 2021	SUPPORTS LEADER (LSP)		ISSUER (CHK)	REVIEWED By oscar at 9:51 am, Feb 12, 2021
STRESS LEADER (LST)		MATERIALS (M)	REVIEWED By Jose G. Suarez at 10:41 am, Feb 04, 2021	DISCIPLINE LEAD (L)	



NOTES:


[1] If "X" marked, a "HOLD" note should be included in the Holds area for justification.
[2] 1st checking round: Checker to place a (✓) or a (✗) confirming or not Designer verification. A (✓) or a (✗) should also be placed to confirm or reject any (✗) mark placed by the Designer confirming or not the implicit HOLD.
[3] 2nd checking round: Checker to place a (✓) to validate the points that were not confirmed in the 1st round and were corrected by respective Specialist.
[4] If an isometric with HOLD is approved by IFC Leader for issuance, the correspondent By-Pass should be attached.



PT NO	N.S. (MM)	DESCRIPTION	IDENT	QTY
1	80	NM Flat Gk, EN 1514-1, RF as per EN 1092-1, PN 40, IBC Type, Thk=3.2mm, Klingsil C-4430, TA-Luft & EC1935 (D.S. 5101)/ CNAF,	C1MSEAM	1
2	80	GENERIC TRANSMITTER 021501LT001	--	1
3	80	1 Set 8 unit x M16 x 50 MM Heavy Hex Machine Bolt w/ Washer, Full Length Threaded, ISO 4017, ISO 3506-1 Gr.A2-70, -, F.Wash. EN ISO 887, A2, EN ISO 7089	C4A7GTF1	1



NOTES: For pipes < dn50 supporting to be studied and defined by construction contractor before line fabrication and installation.	REFERENCES / DOCUMENTS		SPEC	10SS21
			SYMBOLGY	
	LINE LIST	30201-042-001000-001	Insulated Pipe	Insulated and Traced Pipe
	ISOMETRIC INDEX	30303-042-023000-200		
	PIPING SUPPORT	30207-042-021300-001		





PT NO	N.S. (MM)	DESCRIPTION	IDENT	QTY
1	80	NM Flat Gk, EN 1514-1, RF as per EN 1092-1, PN 40, IBC Type, Thk=3.2mm, Klingsil C-4430, TA-Luft & EC1935 (D.S. 5101)/ CNAF,	C1MSEAM	1
2	80	GENERIC TRANSMITTER 021501LT001	--	1
3	80	1 Set 8 unit x M16 x 50 MM Heavy Hex Machine Bolt w/ Washer, Full Length Threaded, ISO 4017, ISO 3506-1 Gr.A2-70, -, F.Wash. EN ISO 887, A2, EN ISO 7089	C4A7GTF1	1



PIPING DPT.
MATERIALS
CHECKED


By Jose G. Suarez at 3:03 pm, Feb 10, 2021

0	18/02/2021	JPA	LP	OMC	IFC - ISSUED FOR CONSTRUCTION (IV)
REV	DATE	DWN	CHK	APP	DESCRIPTION

ALL dimensions to be checked in field prior to construction. Dimensions and routing shall be field adjusted, it is the piping contractors responsibility to check and verify all closing dimensions to equipment and make adjustments as required in field. All dimensions, elevations and coordinates are in millimeter unless noted otherwise. Fieldwelds and overlengths to be determined by piping contractor. Bolt holes to straddle horizontal and vertical centerline unless shown otherwise. Contractor will provide all necessary pipe supports.

PROJECT DESCRIPTION/LOCATION BUTTERFLY PROJECT/KREFELD		 TechnipFMC			
PROCESS UNIT	DESIGN AREA	LINE NUMBER	TRAIN	SHEET	REV
025	023A1	021501-80-VT-10SS21-0001	01	1 OF 1	0



NOTES: For pipes < dn50 supporting to be studied and defined by construction contractor before line fabrication and installation.	REFERENCES / DOCUMENTS		SPEC	10SS21
			SYMBOLGY	
	LINE LIST	30201-042-001000-001	Insulated Pipe	
	ISOMETRIC INDEX	30303-042-023000-200	Insulated and Traced Pipe	
	PIPING SUPPORT	30207-042-021300-001		




PT NO	N.S. (MM)	DESCRIPTION	IDENT	QTY
1	80	NM Flat Gk, EN 1514-1, RF as per EN 1092-1, PN 40, IBC Type, Thk=3.2mm, Klingsersil C-4430, TA-Luft & EC1935 (D.S. 5101)/ CNAF,	C1MSERAM	1
2	80	GENERIC TRANSMITTER 021501LT001	--	1
3	80	1 Set 8 unit x M16 x 50 MM Heavy Hex Machine Bolt w/ Washer, Full Length Threaded, ISO 4017, ISO 3506-1 Gr.A2-70, -, F.Wash. EN ISO 887, A2, EN ISO 7089	C4A7GTFL	1

PIPING DPT.
DESIGN
CHECKED
By oscar at 1:11 pm, Feb 10, 2021

ALL dimensions to be checked in field prior to construction. Dimensions and routing shall be field adjusted, it is the piping contractors responsibility to check and verify all closing dimensions to equipment and make adjustments as required in field. All dimensions, elevations and coordinates are in millimeter unless noted otherwise. Fieldwelds and overlengths to be determined by piping contractor. Bolt holes to straddle horizontal and vertical centerline unless shown otherwise. Contractor will provide all necessary pipe supports.

NOTES: For pipes < dn50 supporting to be studied and defined by construction contractor before line fabrication and installation.	REFERENCES / DOCUMENTS		SPEC	10SS21	PROJECT DESCRIPTION/LOCATION								
			SYMBOLLOGY		BUTTERFLY PROJECT/KREFELD								
	LINE LIST	30201-042-001000-001	Insulated Pipe		Insulated and Traced Pipe		PROCESS UNIT	DESIGN AREA	LINE NUMBER		TRAIN	SHEET	REV
	ISOMETRIC INDEX	30303-042-023000-200	— — — — —		— — — — —		025	023A1	021501-80-VT-10SS21-0001		01	1 OF 1	0
	PIPING SUPPORT	30207-042-021300-001	— — — — —		— — — — —								




PT NO	N.S. (MM)	DESCRIPTION	IDENT	QTY
1	80	NM Flat Gk, EN 1514-1, RF as per EN 1092-1, PN 40, IBC Type, Thk=3mm, Gore-Gr style R, TA-Luft & EC1935 (D.S. 5103)/ Modified PTFE,	C1NKU6D7	1
2	80	GENERIC TRANSMITTER 021501LT001	--	1
3	80	1 Set 8 unit x M16 x 50 MM Heavy Hex Machine Bolt w/ Washer, Full Length Threaded, ISO 4017, ISO 3506-1 Gr.A2-70, -, F.Wash. EN ISO 887, A2, EN ISO 7089	C4A7GTFL	1

By Jose G. Suarez at 10:41 am, Feb 04, 2021

ALL dimensions to be checked in field prior to construction. Dimensions and routing shall be field adjusted, it is the piping contractors responsibility to check and verify all closing dimensions to equipment and make adjustments as required in field. All dimensions, elevations and coordinates are in millimeter unless noted otherwise. Fieldwelds and overlengths to be determined by piping contractor. Bolt holes to straddle horizontal and vertical centerline unless shown otherwise. Contractor will provide all necessary pipe supports.

EXTRACTION DAY 02 FEB 2021 E3D NAME023A1-021501-80-VT-10SS21-0001_01





PT NO	N.S. (MM)	DESCRIPTION	IDENT	QTY
1	80	NM Flat Gk, EN 1514-1, RF as per EN 1092-1, PN 40, IBC Type, Thk=3mm, Gore-Gr style R, TA-Luft & EC1935 (D.S. 5103)/ Modified PTFE,	C1NKU6D7	1
2	80	GENERIC TRANSMITTER 021501LT001	--	1
3	80	1 Set 8 unit x M16 x 50 MM Heavy Hex Machine Bolt w/ 1 Washer, Full Length Threaded, ISO 4017, ISO 3506-1 Gr.A2-70, -, F.Wash. EN ISO 887, A2, EN ISO 7089	C4A7GTF1	1

By jrblanco at 12:48 pm, Feb 03, 2021

By Joaquin Perez-Alonso at 11:08 am, Feb 02, 2021

ALL dimensions to be checked in field prior to construction. Dimensions and routing shall be field adjusted, it is the piping contractors responsibility to check and verify all closing dimensions to equipment and make adjustments as required in field. All dimensions, elevations and coordinates are in millimeter unless noted otherwise. Fieldwelds and overlengths to be determined by piping contractor. Bolt holes to straddle horizontal and vertical centerline unless shown otherwise. Contractor will provide all necessary pipe supports.

PROJECT DESCRIPTION/LOCATION BUTTERFLY PROJECT/KREFELD			 TechnipFMC				
PROCESS UNIT	DESIGN AREA	LINE NUMBER			TRAIN	SHEET	REV
025	023A1	021501-80-VT-10SS21-0001			01	1 OF 1	0
