




ISOMETRIC IFC - CHECK LIST

Line Number	021403VT0004		Stress CN / Level	Nº EJ	Level: I	<div></div> <div>TechnipFMC – Butterfly Project</div>			
Isometric Number	023A1021403VT0004_01		Process Approval Required	YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/>				
			Intrumentation Approval Required (N/A)	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>				
Information to be attached:						HOLDS			
Master Copy of PID:	YES <input checked="" type="checkbox"/>	N/A <input type="checkbox"/>	Nº 800124-020-PID-0021-001	Rev. 0 IFC		Nº	SHORT DESCRIPTION	RESOLVED (✓)	
PID Modification Sheet:	YES <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>	Nº	Rev.					
Equipment Vendor Dwg. :	YES <input checked="" type="checkbox"/>	N/A <input type="checkbox"/>	Nº 520096-50-02-C02	Rev.					
Instrument Dwg. :	YES <input checked="" type="checkbox"/>	N/A <input type="checkbox"/>	Nº	Rev.					
Project By-Pass ⁽⁴⁾ :	YES <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>	Nº	Rev.					
SPO Approved Isometric:	YES <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>	Rev.	Extraction Date:					
SIT Approved Isometric:	YES <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>	Rev.	Extraction Date:					

A VERIFICAR / TO BE CHECKED		* N/A * NO APLICA / NOT APPLICABLE	IFC	REV 0	REV 1	REV 2
Revision By : (D) Designer / (LDG) Design Leader / (ST) Stress Specialist / (LST) Stress Leader / (SP) Supports Specialist / (LSP) Supports leader / (M) Materials / (SL) Spooler / (CHK) Issuer / (L) Discipline Lead			✓	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Revision By : (D) Designer / (LDG) Design Leader			✓	X ⁽¹⁾	1st-Chk ⁽²⁾	2nd-Chk ⁽³⁾
Iso Information	Nº de línea según PID y lista de líneas / Line Nbr. according to PID and line list		✓		✓	
	Datos de la línea según lista de líneas / Line data according to line list		✓		✓	
	Clase de tubería según PID y Lista de Líneas / Piping class according to PID and Line List		✓		✓	
	Vínculo E3D con Diagrams (Process Unit, Temp Operación, Numeracion TODAS válvulas manuales) / Link between E3D and Diagrams (Process Unit, Op Temp, ALL manual valves Tagged)		✓		✓	
	Diámetro de la línea indicado en número de línea en el cajetín / Line diameter indicated in the line number in the title block		✓		✓	
Equipment	Equipo modelado según plano Vendor válido para generar isométrica IFC / Equipment modelled according Vendor drawing valid for Isometric IFC generation		✓		✓	
	Código / Code: 2 <input checked="" type="checkbox"/> 3 <input type="checkbox"/>		✓		✓	
	Nombre de tubuladuras según PID y plano Vendor / Name of nozzle according to PID and Vendor drawing		✓		✓	
	Rating y diámetro de tubuladuras según plano Vendor / Rating and diameter of nozzles according to vendor drawing		✓		✓	
	Posición y elevación de tubuladuras según plano Vendor / Position and elevation of nozzles according to Vendor drawing		✓		✓	
Revision By : (D) Designer / (LDG) Design Leader			By: D		By: LDG	
Line Design	Línea sin colisión (verificación incluyendo la nube de puntos) / Line is clash free (checked including points cloud)		✓		✓	
	Comentarios de SPO a líneas críticas recibidos e implementados antes de extracción final para emisión / Process comments to critical lines received and implemented before final extraction for issuance	✓				
	Verificación contra P&ID y Lista de Líneas / Check Iso vs P&ID and Line List : Correcta referencia de la continuidad de la isométrica en líneas nuevas, líneas existentes u otra hoja de la isométrica en los extremos de línea y sus ramales, incluyendo elevaciones y coordenadas / Correct continuity isometric reference to new lines, existing lines or other isometric sheet in each end of the line and its branches including elevations and coordinates		✓		✓	
	Verificación contra P&ID / Check Iso vs P&ID : Elementos en línea incluidos, secuencia de picajes, pendiente, sentido de flujo, numeración de instrumentos, cambios de especificación, cumplimiento de notas / in-line components included, branch sequence, slope, flow direction, instrument numbering, pipe class breaks, notes accomplishment		✓		✓	
	Verificación contra P&ID / Check Iso vs P&ID : Longitudes requeridas de entrada y/o salida a equipos, distancias y/o elevaciones mínimas o máximas requeridas, formación de condensados / Required inlet and/or outlet lengths to equipments, minimum or maximum distances and/or elevations, condensate generation		✓		✓	
	Comentarios de SIT a recibidos e implementados antes de extracción final para emisión / Instrumentation comments received and implemented before final extraction for issuance	✓				
	Verificación contra Planos de Vendor o Hook-up Instrumentacion / Check Iso vs Instrument Vendor Drawings or Hook-up : Tamaño de las válvulas de control y de seguridad, instalación de acuerdo a hook-up / Size of control valves and safety valves, instrument installation according to hook-up		✓		✓	
	Picajes según tabla de picajes correspondiente / Branch configuration according to correspondent branch table	✓				
	Venteos y drenajes de Procesos según requerimientos de PIDs y de puntos altos y bajos para prueba hidrostática y modelados según "assembly" correspondiente / Process vents and drains according PID requirements and high and low points for hydrostatic test and modelled according proper assembly	✓				
	Verificación de distancia mínima entre soldaduras / Check minimum distance between welds	✓				
	Notas explicativas adicionales incorporadas / Additional clarification notes added	✓				
	Revision By : (ST) Stress Specialist / (LST) Stress Leader			By: ST		By: LST
Stress	El cálculo de stress disponible no está pendiente de revisión en curso / Available stress calculation is not awaiting for revision					
	Los requisitos según el cálculo de stress están incorporados (si son aplicables) / Stress calculation requirements have been added (if applicable)					
Revision By : (SP) Supports Specialist / (LSP) Supports leader			By: SP		By: LSP	
Supports	La línea está soportada por completo y la lista de soportes rellenada / Line is completely supported and support list updated					
	Concepto de soporte y separación máxima entre soportes / Support concept and support spans					
	Requerimientos de soportes estan de acuerdo al cálculo de stress y ajustados con el especialista de Stress / Support requirements according to stress calculation note are included and adjusted jointly with stress specialist					
	Numeración correcta de los soportes / Supports correctly numbered					
	Código de soportes correctamente indicados (STD - SPC - COM - MRS - PRF) / Support code correctly indicated (STD - SPC - COM - MRS - PRF)					
	Markado de elementos soldados de los soportes en Iso Spool preliminar correspondiente / Mark-up of welded supports components in the correspondent preliminary Iso Spool	N/A	-----	-----	-----	-----
Revision By : (M) Materials			By: M			
Materials	La Línea pertenece a alguna o varias categorías de Criticidad. La Línea está listada en la Lista de Líneas Críticas de Materiales. Sus isometricas requieren Verificacion exahustiva / The Line belongs to some or several categories of Criticality. The Line is listed in the Critical Material Lines List. The isometrics require exahustive verification	N/A				
	Todos los materiales están identificados en la isométrica y se encuentran listados en el listado de materiales / All materials are identified in the isometric and are listed in the BOM		✓			
	Añadidos elementos especiales de tubería en Línea de acuerdo a PIDs última revisión y lista de especiales de tubería (Verificar en adicional correcta Numeración, criterios de Posicionamiento en diseño si aplican) / Inclusion of special piping elements in line according to PIDs latest review and Special Piping Material List (Verify identification number, piping design location criteria if applicable)	N/A				
	Nº de identificación de válvulas manuales (según PID)/ Identification number of manual valve (according to PID)	N/A				
	Todas las juntas y pernos colocadas según tipo requerido (RF, FF, Bolts, Machine Bolts) / All gaskets and bolts placed according required type (RF, FF, Bolts, Machine Bolts)		✓			
	Extensión de volante de válvula modelada y reflejada en lista de materiales de la isométrica / Valves axis extension modelled and reflected in Isometric BOM	N/A				
	Válvulas colocadas según PID y Piping Class / Valves placed according PID an Piping Class	N/A				
Revision By : (CHK) Issuer			By: CHK			
Final Check			1st-Chk ⁽²⁾		2nd-Chk ⁽³⁾	
			✓	X	✓	X
	La isométrica verificada por Procesos (SPO) se corresponde a la última revisión / The isometric verified by Process (SPO) corresponds to its last revision	✓				
	La isométrica verificada por Instrumentación (SIT) se corresponde a la última revisión / The isometric verified by Instrumentation (SIT) corresponds to its last revision		✓			
	Las notas a mano están incorporadas en las isométricas / The hand-made annotation is included		✓			
	La revisión de los documentos para la verificación siguen siendo las actuales / Current revision of documents for checking are still the latest available		✓			
	El número de revisión y la fecha son correctos / The revision number and the date are correct		✓			
	Todos los comentarios se han revisado para se incluidos o descartados / All comments have been checked to be included or discarded		✓			
	Holds resueltos o en su defecto By-Pass aprobado / Holds resolved or instead By-Pass approved		✓			

SIGNATURES (Name and date)					
DESIGN LEADER (LD)	<div>REVIEWED By rvasquezhu at 12:43 pm, Feb 19, 2021</div>	SUPPORTS LEADER (LSP)		ISSUER (CHK)	<div>REVIEWED By oscar at 11:17 am, Feb 20, 2021</div>
STRESS LEADER (LST)		MATERIALS (M)	<div>REVIEWED By Jose G. Suarez at 10:05 am, Feb 20, 2021</div>	DISCIPLINE LEAD (L)	


NOTES:

[1] If "X" marked, a "HOLD" note should be included in the Holds area for justification.

[2] 1st checking round: Checker to place a (✓) or a (X) confirming or not Designer verification. A (✓) or a (X) should also be placed to confirm or reject any (X) mark placed by the Designer confirming or not the implicit HOLD.

[3] 2nd checking round: Checker to place a (✓) to validate the points that were not confirmed in the 1st round and were corrected by respective Specialist.



[4] If an isometric with HOLD is approved by IFC Leader for issuance, the correspondent By-Pass should be attached.






PT NO	N.S. (MM)	DESCRIPTION	IDENT	QTY
1	80	NM Flat Gk, EN 1514-1, RF as per EN 1092-1, PN 40, IBC Type, Thk=3.2mm, Klingsil C-4430, TA-Luft & EC1935 (D.S. 5101)/ CNAF,	C1MSEAM	1
2	80	GENERIC TRANSMITTER 021403LT001	--	1
3	80	1 Set 8 unit x M16 x 50 MM Heavy Hex Machine Bolt w/ Washer, Full Length Threaded, ISO 4017, ISO 3506-1 Gr.A2-70, -, F.Wash. EN ISO 887, A2, EN ISO 7089	C4A7GTF1	1

0	01/03/2021	JPA	LP	OMC	IFC - ISSUED FOR CONSTRUCTION
REV	DATE	DWN	CHK	APP	DESCRIPTION

ALL dimensions to be checked in field prior to construction. Dimensions and routing shall be field adjusted, it is the piping contractors responsibility to check and verify all closing dimensions to equipment and make adjustments as required in field. All dimensions, elevations and coordinates are in millimeter unless noted otherwise. Fieldwelds and overlengths to be determined by piping contractor. Bolt holes to straddle horizontal and vertical centerline unless shown otherwise. Contractor will provide all necessary pipe supports.

PROJECT DESCRIPTION/LOCATION BUTTERFLY PROJECT/KREFELD		 TechnipFMC				
PROCESS UNIT	DESIGN AREA	LINE NUMBER		TRAIN	SHEET	REV
024	023A1	021403-80-VT-10SS21-0004		01	1 OF 1	0

NOTES: For pipes < dn50 supporting to be studied and defined by construction contractor before line fabrication and installation.	REFERENCES / DOCUMENTS		SPEC	10SS21
			SYMBOLGY	
	LINE LIST	30201-042-001000-001	Insulated Pipe	Insulated and Traced Pipe
	ISOMETRIC INDEX	30303-042-023000-200		
	PIPING SUPPORT	30207-042-021300-001		





PT NO	N.S. (MM)	DESCRIPTION	IDENT	QTY
1	80	NM Flat Gk, EN 1514-1, RF as per EN 1092-1, PN 40, IBC Type, Thk=3.2mm, Klingersil C-4430, TA-Luft & EC1935 (D.S. 5101)/ CNAF,	C1MSEAM	1
2	80	GENERIC TRANSMITTER 021403LT001	--	1
3	80	1 Set 8 unit x M16 x 50 MM Heavy Hex Machine Bolt w/ Washer, Full Length Threaded, ISO 4017, ISO 3506-1 Gr.A2-70, -, F.Wash. EN ISO 887, A2, EN ISO 7089	C4A7GTF1	1

PIPING DPT.
MATERIALS
CHECKED
By Jose G. Suarez at 10:11 am, Feb 20, 2021



0	01/03/2021	JPA	LP	OMC	IFC - ISSUED FOR CONSTRUCTION
REV	DATE	DWN	CHK	APP	DESCRIPTION


ALL dimensions to be checked in field prior to construction. Dimensions and routing shall be field adjusted, it is the piping contractors responsibility to check and verify all closing dimensions to equipment and make adjustments as required in field. All dimensions, elevations and coordinates are in millimeter unless noted otherwise. Fieldwelds and overlengths to be determined by piping contractor. Bolt holes to straddle horizontal and vertical centerline unless shown otherwise. Contractor will provide all necessary pipe supports.

PROJECT DESCRIPTION/LOCATION BUTTERFLY PROJECT/KREFELD		 TechnipFMC			
PROCESS UNIT	DESIGN AREA	LINE NUMBER	TRAIN	SHEET	REV
024	023A1	021403-80-VT-10SS21-0004	01	1 OF 1	0

NOTES:

For pipes < dn50 supporting to be studied and defined by construction contractor before line fabrication and installation.

REFERENCES / DOCUMENTS		SPEC	10SS21
		SYMBOLGY	
LINE LIST	30201-042-001000-001	<div>Insulated Pipe</div> 	<div>Insulated and Traced Pipe</div> 
ISOMETRIC INDEX	30303-042-023000-200		
PIPING SUPPORT	30207-042-021300-001		



MATERIAL LIST - ERECTION

PT NO	N.S. (MM)	DESCRIPTION	IDENT	QTY
1	80	NM Flat Gk, EN 1514-1, RF as per EN 1092-1, PN 40, IBC Type, Thk=3.2mm, Klingersil C-4430, TA-Luft & EC1935 (D.S. 5101)/ CNAF,	C1MSERAM	1
2	80	GENERIC TRANSMITTER 021403LT001	--	1
3	80	1 Set 8 unit x M16 x 50 MM Heavy Hex Machine Bolt w/ Washer, Full Length Threaded, ISO 4017, ISO 3506-1 Gr.A2-70, -, F.Wash. EN ISO 887, A2, EN ISO 7089	C4A7GTFL	1

PIPING DPT.
DESIGNED
By Joaquin Perez-Alonso at 11:21 am, Feb 17, 2021

PIPING DPT.
DESIGN
CHECKED
By rvasquezhu at 12:43 pm, Feb 19, 2021

0	01/03/2021	UPA	LP	OMC	IFC - ISSUED FOR CONSTRUCTION
REV	DATE	DWN	CHK	APP	DESCRIPTION
All dimensions to be checked in field prior to construction. Dimensions and routing shall be field adjusted, it is the piping contractors responsibility to check and verify all closing dimensions to equipment and make adjustments as required in field. All dimensions, elevations and coordinates are in millimeter unless noted otherwise. Fieldwelds and overlengths to be determined by piping contractor. Bolt holes to straddle horizontal and vertical centerline unless shown otherwise. Contractor will provide all necessary pipe supports.					

PROJECT DESCRIPTION/LOCATION		TechnipFMC		Cargill			
BUTTERFLY PROJECT/KREFELD							
PROCESS UNIT	DESIGN AREA	LINE NUMBER			TRAIN	SHEET	REV
024	023A1	021403-80-VT-10SS21-0004			01	1 OF 1	0