

GROWATT



WIT 4-25K-XHU Hybrid Inverter

User Manual

Contents

| | |
|---|-----------|
| 1 Notes on this manual | 1 |
| 1.1 Introduction | 1 |
| 1.2 Target Group | 1 |
| 1.3 Product Range | 1 |
| 2 Safety Precautions | 2 |
| 2.1 Safety Instructions | 2 |
| 2.2 Symbol Conventions | 4 |
| 2.3 Label Description | 5 |
| 3 Product Description | 6 |
| 3.1 Overview | 6 |
| 3.2 Basic Data | 7 |
| 3.3 Nameplate | 9 |
| 3.4 WIT 4-25K-XHU Operating Principles | 10 |
| 3.5 Storing the WIT Inverter | 11 |
| 3.6 Supported Grid Types | 11 |
| 3.7 AFCI Function | 11 |
| 3.7.1 AFCI Functional Description | 11 |
| 3.7.2 Clearing the Alarm | 12 |
| 4 Inspection upon delivery | 13 |
| 5 Installation | 15 |
| 5.1 Basic Installation Requirements | 15 |
| 5.2 Installation Environment Requirements | 16 |
| 5.3 Moving the WIT Inverter | 17 |
| 5.4 Wall Mount Bracket Installation | 18 |
| 5.5 Installing the Inverter | 19 |
| 6 Electrical Connections | 21 |
| 6.1 Shell Connecting The Ground Cables | 28 |
| 6.2 Internal Connecting The Ground Cables | 29 |
| 6.3 Connection on the AC Side | 30 |
| 6.4 Connection on the PV Side | 33 |

| | |
|--|------------|
| 6.5 Connection on the Battery Side | 35 |
| 6.5.1 Connecting the Main Power Cable of the Battery | 35 |
| 6.6 Connecting Communications Cables | 37 |
| 6.6.1 COM1/COM2 Connection | 37 |
| 6.6.2 COM3/COM4 Connection (Connecting the signal terminals) | 41 |
| 6.6.3 USB interface | 43 |
| 6.7 Post-installation Checks | 44 |
| 7 Commissioning | 46 |
| 7.1 Commissioning the WIT Inverter..... | 46 |
| 7.1.1 Set the Communication Address | 46 |
| 7.1.2 Set the Time and Date | 46 |
| 7.2 Mode of operation..... | 47 |
| 7.2.1 Waiting Mode | 47 |
| 7.2.2 Operating Mode | 47 |
| 7.2.3 Fault Mode | 53 |
| 7.2.4 Shutdown Mode | 53 |
| 7.3 LED and OLED Display Panel..... | 54 |
| 8 Monitoring | 57 |
| 8.1 Remote Monitoring | 57 |
| 8.1.1 Bluetooth Monitoring on the APP (Shinetools) | 57 |
| 8.1.2 Remote Monitoring on the APP (ShinePhone)..... | 65 |
| 8.1.3 Remote Monitoring on the ShineServer Webpage..... | 89 |
| 9 System Maintenance..... | 117 |
| 9.1 Routine Maintenance..... | 117 |
| 9.1.1 Clean the Chassis..... | 117 |
| 9.1.2 Fan Maintenance..... | 117 |
| 9.2 Troubleshooting | 119 |
| 9.2.1 Warning | 119 |
| 9.2.2 Error..... | 124 |
| 10 Product Specifications | 130 |
| 11 Decommissioning the WIT Inverter | 138 |

| | |
|----------------------------|------------|
| 12 Warranty | 139 |
| 12.1 Conditions | 139 |
| 12.2 Disclaimer | 139 |
| 13 Contact Us | 140 |

1 Notes on this manual

1.1 Introduction

This manual is intended to introduce the WIT 4-25K-XHU Hybrid Inverters manufactured by Shenzhen Growatt New Energy Co., Ltd. (hereinafter referred to as Growatt) in terms of their installation, operation, commissioning, maintenance and troubleshooting. Please read this manual carefully before using the product and keep it in a convenient place for further reference. The content of this manual is continually reviewed and amended, where necessary. Growatt reserves the right to make changes to the material at any time and without notice.

Note:

"WIT" refers to the product name. "4-25K" refers to the power range.

1.2 Target Group

This document is intended for qualified technicians. Only qualified and well-trained technicians are allowed to install and operate the WIT inverter. Should any questions arise during installation, you can visit en.growatt.com to leave a message.

1.3 Product Range

WIT 4-25K-XHU (AC 380V/400V) inverters offering ten power options: 4KW, 5KW, 6KW, 8KW, 10KW, 12KW, 15KW, 17KW, 20KW, and 25KW. In total, there are 10 products available in this series. This manual is valid for the following models:

Table 1.1 WIT 4-25K-XHU series model introduction

| | |
|-------------|---|
| WIT 4K-XHU | 3-Phase Hybrid Inverter with UPS function |
| WIT 5K-XHU | |
| WIT 6K-XHU | |
| WIT 8K-XHU | |
| WIT 10K-XHU | |
| WIT 12K-XHU | |
| WIT 15K-XHU | |
| WIT 17K-XHU | |
| WIT 20K-XHU | |
| WIT 25K-XHU | |

Safety Precautions 2

2.1 Safety Instructions

- 1) Please read this manual carefully before installation. Damages caused by failure to follow the instructions in the manual are beyond the warranty scope.
- 2) Only qualified and trained electrical technicians are allowed to perform operations on the WIT Inverter.
- 3) During installation, please do not touch other parts inside the equipment other than the wiring terminals.
- 4) Ensure that all electrical connections comply with local electrical standards.
- 5) Only designated personnel are permitted to perform maintenance on the inverter.
- 6) Before operating the WIT Inverter in on-grid mode, ensure that you have obtained any permission needed from the local grid operator.

Transportation:

| | |
|---|--|
|  WARNING | <ul style="list-style-type: none">Risk of injury when lifting the WIT Inverter, or injury caused by a falling inverter as it is heavy. Please transport and lift the inverter carefully. |
|---|--|

Installation:

| | |
|---|---|
|  NOTICE | <ul style="list-style-type: none">Please read this manual carefully before installation. Damages caused by failure to observe instructions specified in this manual are not covered under any warranty. |
|  DANGER | <ul style="list-style-type: none">Do not connect any cables before installation. |
|  WARNING | <ul style="list-style-type: none">Please observe the installation instructions specified in this manual, including the installation environment and clearance requirements.Install the WIT Inverter in a dry and well-ventilated location; otherwise, performance de-rate may be initiated due to excessive temperature.Please read the installation instructions and safety precautions carefully before installation. |

Electrical Connections:

| | |
|---|---|
|  DANGER | <ul style="list-style-type: none">• Before connecting cables, ensure that the DC switches of the WIT Inverter are OFF, and turn off the switch and breaker on the AC side and the battery side. Otherwise, high voltages may cause severe injuries.• It must be operated by qualified and trained electrical technicians. Technicians should observe instructions in this manual and local regulations.• High voltages may cause electric shocks and serious injury. Please do not touch the WIT Inverter in operation.• Do not install the inverter in potentially explosive and flammable atmospheres. |
|  WARNING | <ul style="list-style-type: none">• Each WIT Inverter must be equipped with an AC circuit breaker. Multiple WIT Inverters cannot connect to the same AC circuit breaker.• Do not connect the load between the WIT Inverter and the circuit breaker.• If the cable is thick, do not shake the cable terminals after tightening them. Otherwise, the loose connection may cause overheating and device damage. Ensure that the terminals are properly connected before starting the WIT Inverter.• Ensure the correct polarity of the terminals before connecting the PV array to the WIT Inverter. |

Maintenance and replacement:

| | |
|---|--|
|  DANGER | <ul style="list-style-type: none">• It must be operated by qualified and trained electrical technicians. Technicians should observe instructions in this manual and local regulations.• After turning off the DC switches and the AC breakers, wait for at least five minutes before performing any operations to avoid risks.• When the OLED screen indicates "PV Isolation low", do not touch the chassis as a ground fault may have been detected.• Beware of high voltages which may cause electric shocks. |
|  WARNING | <ul style="list-style-type: none">• To ensure good dissipation, clean the fan regularly.• Do not use the air pump to clean the fan. Otherwise, the fan may be damaged. |

Others:

| | |
|---|--|
|  | <ul style="list-style-type: none">Upon receiving the product, check if the contents are intact and complete. If any damage is found or any component is missing, please contact your distributor. |
|  WARNING | <ul style="list-style-type: none">The maximum PV input voltage cannot exceed 1000V. The battery input voltage cannot exceed 800V.For the WIT Inverter that will not be put into operation in the future, you should properly dispose of them by yourself. |

2.2 Symbol Conventions

| Symbol | Description |
|---|--|
|  DANGER | DANGER indicates a hazard with a high level of risk which, if not avoided, will result in death or serious injury. |
|  WARNING | WARNING indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury. |
|  CAUTION | CAUTION indicates a hazard with potential risk which, if not avoided, could result in minor or moderate injury. |
|  NOTICE | NOTICE indicates that under certain circumstances, improper operations could result in property damage. |
|  | Remind operators to check the instructions before installing or operating the WIT Inverter. |

2.3 Label Description

| Symbol | Name | Meaning |
|--|----------------------|--|
|  | High voltage | High voltages exist after the WIT Inverter is powered on. Only qualified and trained electrical technicians are allowed to perform operations. |
|  | Burn warning | Do not touch a running inverter because it generates high temperatures on the shell. |
|  | Grounding | Indicates the position for connecting the PE cable. |
|  5min | Delay discharge mark | Residual voltage exists after the WIT Inverter is powered off. It takes 5 minutes to discharge to the safe voltage. |
|  | Refer to the manual | Remind operators to refer to the manual before installing and operating the WIT Inverter. |
|  | DC | Direct Current. |
|  | AC | Alternating Current. |

Product Description 3



NOTICE

The following figure shows the appearance of the WIT 4-25K-XHU. There are slight differences in the photovoltaic ports at the bottom of WIT 4-6K-XHU, WIT 8-10K-XHU, WIT 12-15K-XHU, and WIT 17-25K-XHU, which are listed separately in the bottom view.

3.1 Overview

Front view:






Fig 3.1 Front view

Bottom view:


WIT 4-6K XHU



WIT 8-10K XHU



WIT 12-15K XHU



WIT 17-25K XHU




Fig 3.2 Bottom view

Left view:




Fig 3.3 Left view

Right view:




Fig 3.4 Right view

Table 3.1 Component description

| NO. | Descriptions | NO. | Descriptions |
|-----|-----------------------------|-----|----------------------------|
| A | Top cover plate | B | Bottom cover plate |
| C | Display screen | D | Network Port Terminal |
| E | Signal terminal | F | BMS AC connection terminal |
| G | GEN connection terminal | H | PE wiring terminal |
| I | Load connection terminal | J | Grid connection terminal |
| K | PV terminal | L | USB interface |
| M | Battery Terminal Blocks | N | PV Switch |
| O | Indicator description label | P | Nameplate |

3.2 Basic Data

Table 3.2 Dimensions and weight

| | Model | Size (mm) | | | Weight (kg) |
|----------------------------------|---------------|-----------|-------|-------|-------------|
| | | Height | Width | Depth | |
| The WIT Inverter without package | WIT 4-25K-XHU | 687 | 465 | 241 | 42 |
| The WIT Inverter with package | WIT 4-25K-XHU | 810 | 650 | 410 | 50 |

unit: mm




Fig 3.5 Inverter Dimensions

unit: mm




Fig 3.6 Package Dimensions

3.3 Nameplate

The figure below shows the nameplate of WIT 25K-XHU as an example. The nameplate figure is for reference only. The actual nameplate prevails. For the specifications, please refer to Section 10 Product Specifications.




Fig 3.7 Nameplate

3.4 WIT 4-25K-XHU Operating Principles

- 1) The hybrid inverter receives DC inputs from PV strings which go through the MPPT routes. The DC power is then converted into AC power through the inverter circuit to power the loads and feed power into the grid;
- 2) The PV strings can supply power to charge the battery through the MPPT routes;
- 3) Convert battery power to AC power supplies for the loads and feeding to the grid;
- 4) Charge the battery from the grid through a rectifier circuit;
- 5) Convert the DC power from PV strings and the battery power into AC power through the inverter circuit to power critical loads;
- 6) When the GEN port is connected to the generator and set to the GEN mode, the generator can supply power to the loads or charge the battery;
- 7) When the GEN port is connected to loads and set to "Smart Load" mode; during on-grid operation, it will supply grid power to the loads connected via the GEN port; during off-grid operation, the power supply to smart loads will be cut off when the battery SOC is below "SOC under secondary load" Set Value.
- 8) When the GEN port is connected to the PV inverter and set to "AC Couple" mode, during on-grid operation, the PV inverter will be connected to the grid and output power; during off-grid operation, the PV inverter will remain connected and generating power together with the WIT inverter.

NOTE:

WIT 4-6K-XHU models have 1 MPPT routes; WIT 8-10K-XHU models have 2 MPPT routes; WIT 12-15K-XHU models have 3 MPPT routes; WIT 17-25K-XHU models have 4 MPPT routes;




Fig 3.8 WIT 4-25K-XHU Grid-connected conceptual diagram

3.5 Storing the WIT Inverter

- 1> Put the WIT Inverter in the original package and place it in a dry and well-ventilated place.
- 2> Keep the storage temperature from -40°C to +70°C and the humidity from 0%-95% RH.
- 3> A maximum of five WIT Inverters can be stacked. Do not stack the inverters without package.
- 4> If the WIT Inverter has been long-term stored, inspections and tests should be conducted by qualified personnel before installation.



Wrong time and date may occur if the WIT Inverter has been stored for over one month. Fix the time and date before connecting the inverter to the grid. For details, see Fig 7.1 Commissioning the WIT Inverter.

3.6 Supported Grid Types

Grid connection modes for WIT 4-25K-XHU Hybrid Inverters are shown in Fig 3.11.




Fig 3.9 380V / 400V system (type Y/△)

3.7 AFCI Function

3.7.1 AFCI function Description

An AFCI, or Arc-Fault Circuit Interrupter, is a solution designed to detect and mitigate the risk of electrical arcing in a photovoltaic (PV) system, supported by intelligent arc detection algorithm. Arcing can occur when there is a high voltage breakdown in the electrical insulation or when conductive materials come into contact with each other. This can pose a fire hazard and damage the system components. The AFCI continuously monitors the system for potential arc faults and, if detected, interrupts the circuit to prevent a fire or other damage. AFCIs are required by the National Electrical Code (NEC) in certain parts of a PV system, such as the DC side of the inverter, to improve safety and reduce the risk of fires.

NOTE:

1. The AFCI Function of the WIT Inverter is disabled by default. If you want to enable the AFCI, please contact Growatt support.
2. Do not connect the Maximum Power Point Trackers (MPPTs) on the DC side in parallel as it might trigger the AFCI mistakenly.

3.7.2 Clearing the Alarm

In the event that the WIT Inverter reports “AFCI Fault” and the PV indicator turns red, an arc fault might have been detected. Please perform the following steps to clear the alarm.

Step 1: Disconnect the WIT inverter from all power sources. Turn off the AC output circuit breaker, then turn the DC switches to the OFF position. Wait until the error message disappears.




Fig 3.10

Step 2: Troubleshooting. Check if the open-circuit of all PV strings are within the permissible range.

Step 3: After the fault is cleared, restart the inverter. Turn on the AC breaker, and turn the DC switch to the ON position. Wait until the system is working properly.




Fig 3.11

If the WIT Inverter passes the AFCI self-test, it will work in the normal mode and the PV indicator will be green. If it fails, the inverter will report “Error 425”. In this case, please reboot the system and perform Step 1 to Step 3. If it failed again, please disconnect all power sources and contact Growatt support.

4 Inspection upon delivery

Unpacking and inspection

- 1> Before unpacking the WIT Inverter, check the shipping box for any externally visible damage. If any damage is found, contact the shipping company as soon as possible.
- 2> After unpacking the WIT Inverter, check if the scope off delivery is intact and complete. If any damage is found or any component is missing, contact your distributor.

Check the following items:




Fig 4 WIT 4-25K-XHU Attachment

Table 4.1 Packing list

| NO. | Descriptions | Quantity | NO. | Descriptions | Quantity |
|-----|---------------------------------|----------|-----|------------------------------|----------|
| A | The WIT Inverter | 1 | J | M6*16 screw | 2 |
| B | Wall mount kit | 1 | K | M8*80 screw | 4 |
| C | PV+(-) connector | 4/4 | L | M4*12 screw | 3 |
| D | PV+(-) metal contact | 4/4 | M | CT (100A/40mA) | 3 |
| E | Battery +(-) connector | 2/2 | N | PV connector disconnect tool | 1 |
| F | PE connector SC4-6 | 1 | O | ShineWiLan-X2 (Optional) | 1 |
| G | BMS AC terminal | 2 | P | Rj45 | 7 |
| H | Communication Crimp Terminal | 14 | Q | Quick Guide | 1 |
| I | AC Side/PE Rail Crimp Terminals | 12/3 | R | User Manual | 1 |

NOTE:

1. Sturdy and durable though the packing carton is, please carry and handle it with caution.
2. Normal use of the machine accessory CT for backflow prevention and other energy flow control, customers do not need to purchase a separate meter and CT, just connect the CT's secondary side wiring to the corresponding terminals of the WIT 4-25K-XHU machine.

5 Installation

5.1 Basic Installation Requirements

- A. The installation location must be suitable for WIT's weight for a long period time. (Refer to Table 3.2 for the weight of the WIT Inverter).
- B. Ensure that the installation position is suitable for the dimensions of the WIT Inverter.
- C. Do not install the WIT Inverter in areas with flammable or non heat-resistant materials.
- D. The WIT Inverter is protected to IP66 and can be installed indoors or outdoors.
- E. Do not expose the WIT Inverter to direct sunlight. Otherwise, excessive temperature may lead to power reduction.
- F. Keep the humidity at 0% to 95% RH.
- G. Keep the ambient temperature at -30°C to 60°C.
- H. The WIT inverter can be installed vertically or backward tilted. Please refer to the figures below:




Fig 5.1

- I. Reserve enough clearance around the WIT Inverter to ensure sufficient space for heat dissipation and operation. Leave a clearance of 0.6 m on both sides, approximate 0.6 m above and below the WIT Inverter, and 1 m in front of the inverter.




Fig 5.2

- J. Keep the WIT Inverter away from strong interference sources.
 K. Ensure that the WIT Inverter is not accessible to children.

5.2 Installation Environment Requirements

- A. Though the WIT Inverter is protected to IP66, do not expose it to direct sunlight, rain and snow. Please refer to the figures below:



Fig 5.3

- B. To reduce the de-rate performance of the inverter and extend inverter's life span, we strongly recommend you install an awning. For the distance between an awning and inverter, please refer to following figure:





Fig 5.4

- C. When you install multiple WIT inverters on one surface, inverters should be installed as following drawing. (Choose one of the two options below).






Fig 5.5

D. Do not place the WIT Inverter in an enclosed and narrow space for operation.




Fig 5.6

5.3 Moving the WIT Inverter



CAUTION

- The inverter is heavy, please move it with care and keep balance to avoid personnel injury.
- Do not place the inverter with its wiring and signal terminals at the bottom contacting with floor or any other object because the terminals are not designed to support the weight of inverter.

- 1> As shown in Fig 5.7, two persons are required to lift the inverter out of the package and transport it to the installation position.
- 2> When you are moving the inverter, please keep the balance.

Note: There will be front and bottom mark on the package.




Fig 5.7

5.4 Wall Mount Bracket Installation

Before installing the inverter, you need install the wall mount bracket so that the inverter can be securely mounted on the wall.

Wall mount bracket (unit: mm):




Fig 5.8

STEP 1: Use the wall mount plate as a template, drill holes into the wall and insert the expansion bolts as Fig 5.9 show.

STEP 2: Tighten the bolts to attach the wall mount bracket onto the wall securely as illustrated below.




Fig 5.9

Note:

- 1> The wall where the expansion bolts are installed should be a solid concrete or brick wall with a thickness of at least 100 mm.
- 2> Ensure that the bracket has been firmly installed before mounting the inverter onto it.

5.5 Installing the Inverter

After verifying that the wall mount bracket has been firmly installed on the wall, mount the inverter onto the bracket.

- 1> The installer uses both hands to lift the machine as shown in Fig 5.10 below.
- 2> Hang the inverter onto the wall mount bracket and install the bolts. Please keep balance when moving the inverter.
- 3> Check if the inverter has been properly mounted and tighten all screws.




Fig 5.10 Wall-mounted installation



Ensure that the wall meets the load-bearing requirements of the equipment. For details about the weight, see Table 3.2.

6 Electrical Connection




Fig 6.1 Wiring diagram of the system with a single
WIT 25K-XHU inverter (Gen mode)

NOTE:

1. Connect the signal wires of the generator and the meter to the relevant positions of the CN10 terminal according to Table 6.6.
2. Set the parameters on the client. Take ShinePhone as an example:
Tap Control > Off grid parameter settings > Related settings for grid connection and off grid> Grid connected/off grid setup> Generator;
(2) Tap Control > Advanced > Microgrid system> Types of Access for GEN Port Devices>Generator and >Generator Enable>Enable, And set other parameters as required.




Fig 6.2 Wiring diagram of the system with a single WIT 25K-XHU inverter
(AC couple mode)

NOTE:

1. Connect the signal wires of the meter to the relevant positions of the CN10 terminal according to Table 6.6.
2. Proform related Settings on the client. Take ShinePhone as an example: Tap Control > Advanced > Microgrid system> Types of Access for GEN Port Devices>Inverter and >AC Couple Enable> Enable, And set other parameters as required.




Fig 6.3 Wiring diagram of the system with single WIT 25K-XHU inverters in smart load mode

NOTE:

1. Connect the signal wires of the meter to the relevant positions of the CN10 terminal according to Table 6.6.
2. Proform related Settings on the client. Take ShinePhone as an example: Tap Control > Advanced > Microgrid system> Types of Access for GEN Port Devices>Smart Load.




Fig 6.4 Wiring diagram of the system with three WIT 25K-XHU inverters connected in parallel

NOTE:

1. Proform related Settings on the client. Take ShinePhone as an example: Tap Control > Parallel parameter setting > Parallel enable> Enable.
2. The wiring methods for different regions are shown in Fig 6.5 below, please select the wiring method according to the local safety regulations.





Fig 6.5 N-PE Wiring in Different Areas




Fig 6.6 Communication network port Detailed information




Fig 6.7 Signal terminal

6.1 Shell Connecting The Ground Cables

- 1) It is essential to connect the ground cable to the WIT inverter before connecting other cables to prevent personal injury or device damage.
- 2) All non-current-carrying metal parts and the enclosures of the devices of the energy storage system, including the rack and the enclosures of the combing box, the distribution panel, the inverter and the battery should be properly grounded.
- 3) For a single WIT inverter, connect a ground cable to the ground point on the chassis shell. For a system with multiple WIT inverters connected in parallel ensure that the enclosures of the WIT Inverters, the metal racks of the modules and the batteries should be connected to the same area to achieve equipotential bonding.
- 4) The position of the ground points of the WIT 4-25K-XHU Hybrid Inverter is shown in Fig 6.8.




Fig 6.8 Protective earthing position

Attention:

1. Keep the lightning protection grounding at the greatest possible distance from the protective grounding.
2. Protect the terminals of the ground cables against rain and do not expose them to open air.
3. Tighten the screws to a torque of 50 kgf·cm.

6.2 Internal Connecting The Ground Cables



DANGER

- Before connecting cables, ensure that the DC switches on the WIT Inverter are OFF. Turn off the switches and breakers on the GRID side, GEN side and the battery side. Otherwise, the high voltages of the WIT Inverter may result in electric shocks.
- Only qualified and trained electrical technicians are allowed to perform operations. Technicians must observe instructions in this manual and local regulations.
- High voltages may cause electric shocks and serious injury. Please do not touch the inverter in operation.
- Do not place inflammable and explosive materials around the WIT Inverter.

The Internal Ground Cables connection steps:

1) Open the lower cover and the cover position is shown in Fig 6.9;




Fig 6.9 Lower cover

- 2) Connect a ground cable to the copper grounding bar. Fig 6.10 shows the position of the grounding bar ;




Fig 6.10 Grounding Schematic

6.3 Connection on the AC Side

| | |
|--------------------|--|
| DANGER | <ul style="list-style-type: none"> Before connecting cables, ensure that the DC switches on the WIT Inverter are OFF. Turn off the switches and breakers on the GRID side, GEN side and the battery side. Otherwise, the high voltages of the WIT Inverter may result in electric shocks. Only qualified and trained electrical technicians are allowed to perform operations. Technicians must observe instructions in this manual and local regulations. High voltages may cause electric shocks and serious injury. Please do not touch the inverter in operation. Do not place inflammable and explosive materials around the WIT Inverter. |
| WARNING | <ul style="list-style-type: none"> Each WIT Inverter must be equipped with a separate AC circuit breaker. Multiple WIT Inverters cannot connect to the same AC circuit breaker (not applicable to off-grid mode). Please do not connect loads between the WIT Inverter and the circuit breaker. If the cable is thick, do not wiggle the cable after tightening the cable terminals. Otherwise, the loose connection may cause overheating that will damage the device. Ensure that the terminals are properly connected before starting the WIT Inverter. Upon completion of the AC wiring, remember to seal the waterproof silicone mat with the fireproof mud in order to ensure good waterproof performance. |

Preparation:

- > Ensure the grid voltage and the grid frequency are within the acceptable range;
- > Disconnect the DC switches and the AC breakers on the grid side, generator side and the battery side.

The circuit breaker on the AC side:

AC circuit breaker needs to be installed on the grid side, ensuring a safe disconnection between the WIT Inverter and the upstream input when an exception occurs.

1. Recommended AC breaker specifications for WIT 4-25K-XHU models

| Device type | Rated voltage of the circuit breaker | Rated current of the circuit breaker |
|-------------------|--------------------------------------|--------------------------------------|
| WIT 4/5/6K-XHU | 400V | 32A |
| WIT 8/10K-XHU | 400V | 63A |
| WIT 12/15K-XHU | 400V | 63A |
| WIT 17/20/25K-XHU | 400V | 125A |

2. Recommended load breaker specifications for WIT 4-25K-XHU models

| Device type | Rated voltage of the circuit breaker | Rated current of the circuit breaker |
|-------------------|--------------------------------------|--------------------------------------|
| WIT 4/5/6K-XHU | 400V | 25A |
| WIT 8/10K-XHU | 400V | 50A |
| WIT 12/15K-XHU | 400V | 50A |
| WIT 17/20/25K-XHU | 400V | 100A |

3. Recommended bypass breaker specifications for WIT 4-25K-XHU models

| Device type | Rated voltage of the circuit breaker | Rated current of the circuit breaker |
|-------------------|--------------------------------------|--------------------------------------|
| WIT 4/5/6K-XHU | 400V | 25A |
| WIT 8/10K-XHU | 400V | 50A |
| WIT 12/15K-XHU | 400V | 50A |
| WIT 17/20/25K-XHU | 400V | 100A |

4. Recommended Gen breaker specifications for WIT 4-15K-HU models

| Device type | Rated voltage of the circuit breaker | Rated current of the circuit breaker |
|-------------------|--------------------------------------|--------------------------------------|
| WIT 4/5/6K-XHU | 400V | 32A |
| WIT 8/10K-XHU | 400V | 63A |
| WIT 12/15K-XHU | 400V | 63A |
| WIT 17/20/25K-XHU | 400V | 125A |

NOTE:

For the PCS to operate in Smart Load mode, select the appropriate AC breaker based on the smart load power.

Recommended power cable specifications:

Recommended AC power cables for WIT 4-25K-XHU models(include bypass)

| Device Type | WIT 4/5/6/8/10K-XHU | WIT 12/15/17/20/25K-XHU |
|--|---------------------|-------------------------|
| Cable specification (Grid/Load/Gen) | 10mm ² | 16mm ² |

AC side connection method:

Connect the main power cables according to the label. Fig 6.11 shows the position of the label and the AC terminals.






Fig 6.11 AC Terminal Wiring Locations and Schematics

Note:


- Determine the stripped length based on the wiring terminal specifications (recommended length: 12-14mm). Crimp the cable and terminal using a crimper as shown below. Loosen the PG type cable gland and route the cables through it. Then connect the cables to the corresponding terminals. Secure the cables by tightening the screws.



(1) Tubular terminal



(2) Core wire



(3) Cable

(4) Crimping plier

Fig 6.12 Schematic diagram of cable crimp terminals

2. Cold-pressed terminals are delivered with the package. Select terminals based on the cable specifications;

| | |
|---|--|
|  WARNING | <ul style="list-style-type: none"> Any device damage caused by failure to seal the output terminal gaps as instructed is beyond the scope of warranty and Growatt shall not be liable for the damage. |
|---|--|

6.4 Connection on the PV Side

| | |
|---|---|
|  DANGER | <ul style="list-style-type: none"> Before connecting cables, ensure that the DC switches of the WIT Inverter are OFF, and turn off the breakers on the AC side and the battery side. Otherwise, the high voltages of the WIT Inverter may cause electric shocks. Only qualified and trained electrical technicians are allowed to perform operations. Technicians must observe instructions in this manual and local regulations. Check the positive and negative terminals before connecting the PV module to the WIT Inverter. High voltages may cause electric shocks and serious injury. Please do not touch the inverter in operation. Please do not place inflammable and explosive materials around the WIT Inverter. |
|  WARNING | <ul style="list-style-type: none"> The maximum open-circuit voltage of each string should not exceed 1000Vdc. Ensure that the following conditions are met; Otherwise, fire hazard or inverter damage may occur. Growatt is not liable for the consequence and it is beyond the warranty scope. |

NOTE:

- When exposed to sunlight, PV modules will generate voltage. High voltages presented in the PV strings connected in series could be fatal. Therefore, shield the PV modules from sunlight before connecting the DO input power cable and ensure that the DC switches on the WIT Inverter are OFF.
- The PV modules connected in series should be of the same model. The maximum short-circuit current of each PV string must be lower than or equal to 50A.
- The total panel power should not exceed twice the WIT inverter input power. For optimal system configuration, it is recommended to connect two DC inputs with an equal number of PV modules.




Fig 6.13 PV Terminal

Procedure for connecting cables on the PV side:

1. Strip 8-10 mm of the insulation layer of the PV cables;
2. Insert the exposed core wires into the crimping area of the wiring terminal and crimp them using a crimping plier;
3. Route the cable through the cable sealing sleeve and insert the insulation sleeve until it snaps. Slightly pull the cable back to ensure that it is securely connected. Then tighten the locking nut;
4. Insert the positive and negative connectors of the PV modules to the corresponding terminals on the inverter. For the maximum input current of different models, please see Table 6.1. For the cable specifications, please see Table 6.2.

Table 6.1 Maximum current of a single MPPT route

| Device type | Max. current of a single MPPT route |
|---------------|-------------------------------------|
| WIT 4-25K-XHU | 40A |

Table 6.2 Cable specifications on the PV side

| Device type | Recommendation cable specifications |
|---------------|-------------------------------------|
| WIT 4-25K-XHU | 4-6mm ² |

NOTE:

- 1) For a single WIT Inverter, connect the ground cable of the inverter. For a system with multiple WIT Inverters connected in parallel, connect the ground cables of all inverters and the metal racks of the PV modules to the same area to ensure equipotential bonding. Before connecting the PV cables, ensure that the ground cables on the PV side are properly connected.
- 2) Use male and female connectors in pair. Ensure the correct polarity before connecting the PV string to the inverter.
- 3) The total current of all strings cannot exceed the WIT Inverter's maximum input current;
- 4) Do not touch the solar panels in operation;
- 5) The wires should be tinned and are not frayed or cracked.

6.5 Connection on the Battery Side

| | |
|--|--|
|  DANGER | <ul style="list-style-type: none">• Before connecting cables, ensure that the DC switches of the WIT Inverter are OFF, and turn off the breakers on the AC side and the battery side. Otherwise, the high voltages of the WIT Inverter may cause electric shocks.• Only qualified and trained electrical technicians are allowed to perform operations. Technicians must observe instructions in this manual and local regulations.• High voltages may cause electric shocks and serious injury. Please do not touch the inverter in operation.• Please do not place inflammable and explosive materials around the WIT Inverter. |
|  WARNING | <ul style="list-style-type: none">• Ensure that all cables are securely connected before powering on the WIT Inverter. Loose connection may cause overheating that will damage the device. |

NOTE:

Recommended battery voltage 512V.


Table 6.3 Cable specifications on the Battery side

| Device type | Recommended Cable Specifications |
|---------------|----------------------------------|
| WIT 4-25K-XHU | 16mm ² |

6.5.1 Connecting the Main Power Cable of the Battery

Preparation:

1. Check if the battery terminals on the machine end are damaged;
 2. Disconnect the DC switch, AC switch, and battery switch of the integrated light storage machine;
 3. Find the matching client battery terminals and battery terminal structural components from the shipping attachments. Please refer to Chapter 4 for the accessory schematic diagram for the terminal pictures.
1. Connect the grounding cable of the battery power line to the PE position, as shown in Figure 6.10;
 2. Peel off the insulation layer of the DC cable, and it is recommended to strip the wire for a length of 12-13mm;
 3. Use a crimping tool to press the battery cable onto the battery terminal, and then tighten the plastic protective shell at the end;
 4. Insert the battery cable of the crimping terminal into the battery terminal of the machine. The complete steps are shown in Figure 6.14.



(1) Battery terminal

(2) Core wire

(3) Cable

(4) Hydraulic pliers

Fig 6.14 Step-by-step diagram of battery terminal wiring

NOTE:

- 1> Connect the ground cable before connecting the battery cable; the ground point is shown in Fig 6.10.
- 2> The length of the battery cable is recommended to be no more than 10m
- 3> BAT1 and BAT2 are connected in parallel internally. It is strictly prohibited to connect two clusters of high-voltage batteries without optimizers with different specifications or inconsistent battery states at the same time, otherwise it may cause equipment damage or danger.

6.6 Connecting Communications Cables

6.6.1 COM1/COM2 Connection

WIT 4-25K-XHU Inverter includes 8 RJ45 ports. It is used for parallel connection via PARA-IN and PARA-OUT communication terminals, battery communication via BMS1 terminals, and external equipment communication via RS485 and DRMS function Connect the communication cables to the corresponding terminals as required. For details, see Table 6.5.




Fig 6.15

1> Unscrew the PG head to remove the rubber plugs according to the number of communication cables, keep the rubber plugs with unused holes, and then pass the communication cables through the PG head. The steps are shown in Step1-4;

2>Crimp the communication cables as shown below.




Fig 6.16

- 3> Connect the communication cable terminals according to the single board silkscreen as shown in Fig 6.17.
4> Tighten the PG head after connecting.

Detailed information of COM1




Fig 6.17 Communication network port

Table 6.5 Communication network port terminal description

| Definition of battery communication terminal | | | |
|--|-----|----------------------|---|
| Silk screen | Pin | Definition of signal | Function and Note |
| BMS1 | 1 | BAT RS485_B | Communication of battery1 (mandatory) |
| | 2 | BAT RS485_A | |
| | 3 | BAT1 DI_1 | |
| | 4 | BAT1 CAN_H | |
| | 5 | BAT1 CAN_L | |
| | 6 | BAT1 DI_2 | |
| | 7 | BAT1 WAKE- | |
| | 8 | BAT1 WAKE+ | |
| RS485_IN | 1 | RS485_1B | RS485_IN: METER2/ShineBus/ ShineMaster (1/4/5) RS485_3: EMS/VPP (7/8) |
| | 2 | GND.S | |
| | 3 | \ | |
| | 4 | RS485_1B | |
| | 5 | RS485_1A | |
| | 6 | \ | |
| | 7 | RS485_3B | |
| | 8 | RS485_3A | |
| RS485_OUT | 1 | RS485_1B | RS485_OUT: METER2/ShineBus/ ShineMaster (1/4/5) RS485_3: EMS/VPP (7/8) |
| | 2 | GND.S | |
| | 3 | \ | |
| | 4 | RS485_1B | |
| | 5 | RS485_1A | |
| | 6 | \ | |
| | 7 | RS485_3B | |
| | 8 | RS485_3A | |

| Definition of battery communication terminal | | | |
|--|-----|----------------------|---|
| Silk screen | Pin | Definition of signal | Function and Note |
| METER | 1 | RS485_2B | RS485_2: METER1 output (export limitation meter wiring port for a single inverter) |
| | 2 | GND.S | |
| | 3 | \ | |
| | 4 | \ | |
| | 5 | RS485_2A | |
| | 6 | \ | |
| | 7 | \ | |
| | 8 | \ | |
| DI | 1 | DRM1/5 | DRMS/RCR/DI function |
| | 2 | DRM2/6 | |
| | 3 | DRM3/7 | |
| | 4 | DRM4/8 | |
| | 5 | REF | |
| | 6 | COM | |
| | 7 | \ | |
| | 8 | \ | |
| PARA-IN | 1 | \ | Parallel input |
| | 2 | \ | |
| | 3 | \ | |
| | 4 | \ | |
| | 5 | \ | |
| | 6 | \ | |
| | 7 | \ | |
| | 8 | \ | |

| Definition of battery communication terminal | | | |
|--|-----|----------------------|-------------------|
| Silk screen | Pin | Definition of signal | Function and Note |
| PARA_OUT | 1 | \ | Parallel output |
| | 2 | \ | |
| | 3 | \ | |
| | 4 | \ | |
| | 5 | \ | |
| | 6 | \ | |
| | 7 | \ | |
| | 8 | \ | |



6.6.2 COM3/COM4 Connection (Connecting the signal terminals)

This terminals is used for generator start/stop, machine emergency stop, battery temperature sampling and external CT access signals.

Terminal Connection Procedure.

- 1) Strip the outer wire skin of the cable by 5~7mm, and then use crimping pliers to crimp the wire and tubular terminal;
- 2) Unscrew the corresponding PG head and remove the rubber bar under the corresponding hole, keep the rubber plug for the unused hole;
- 3) Pass the cable through the PG header and snap it into the corresponding terminal holes of the veneer as shown in Fig 6.18.

NOTE: It is recommended to use the device's original CT and its cables.If extending the CT cable is necessary,do not exceed 20 meters.






Fig 6.18 Signal terminal connections

4) Install the Bottom cover plate after completing all the above steps.




Fig 6.19 Install the Bottom cover plate

Detailed information:




Fig 6.20 Signal Terminal

| Signal Terminal Interface Definition Description | | | |
|--|-----|-------------------|--------------------------|
| Silkscreen | Pin | Signal Definition | Features and Remarks |
| COM3(CN10) | 1 | REPO.WIT | Emergency shutdown input |
| | 2 | GND.S | |
| | 3 | DG_START+ | Oiler start signal |
| | 4 | DG_START- | |
| | 5 | NTC.BAT1 OUT | Battery 1 temperature |
| | 6 | NTC.BAT1 OUT.G | |
| COM4(CN10) | 7 | / | / |
| | 8 | / | |
| | 9 | CT_L1+ (White) | CT Phase L1 |
| | 10 | CT_L1- (Black) | |
| | 11 | CT_L2+ (White) | CT Phase L2 |
| | 12 | CT_L2- (Black) | |
| | 13 | CT_L3+ (White) | CT Phase L3 |
| | 14 | CT_L3- (Black) | |

6.6.3 USB connection

The WIT 4-25K-XHU series inverter is equipped with a USB interface as standard, which can be connected to a USB to WiLAN-X2 monitoring module for remote monitoring. In addition, you can also quickly upgrade the inverter software through the U disk. Steps to install the monitoring module:

- 1> Loosen the waterproof cover of the USB interface and remove it.
- 2> As shown in Fig 6.21, insert the WiLAN-X2 module into the USB interface, and the LED indicator of the WiLAN-X2 module will be on.
- 3> As shown in Fig 6.21, make sure that the is facing frontwards as the inverter has been wall-mounted, insert the monitoring module into the USB interface, and tighten the lock.

Note:

- 1.If a USB to WiLAN-X2 module is installed, please take the module and the data cable away, and tighten the waterproof cover when the operator leaves to prevent water from entering the interface.
- 2.System upgrades will cause power outages on load ports of the WIT.




Fig.6.21 USB Connection

6.7 Post-installation Checks

The following table lists the post-installation items to be checked:

| Position | Item | Check item |
|--------------|---------------------------------------|---|
| housings | Ground cable connected to the chassis | Check the cable specifications; ensure that the cable has been securely fastened |
| PV side | Ground cable on the PV side | Check the cable specifications; ensure that the cable has been securely fastened |
| | PV+, PV- | Check the cable specifications; ensure that the cable has been securely fastened; confirm that the number of PV modules matches the rated power |
| Battery side | Ground cable on the battery side | Check the cable specifications; ensure that the cable has been securely fastened |
| | BAT+, BAT- | Check the cable specifications; ensure that the cable has been securely fastened |
| AC Side | Ground cable on the AC side | Check the cable specifications; ensure that the cable has been securely fastened |
| | Grid side | Check the cable specifications; ensure that the cable has been securely fastened |
| | Load side | Check the cable specifications; ensure that the cable has been securely fastened |

| Position | Item | Check item |
|-------------------------|-----------------------|---|
| AC Side | GEN side | Check the cable specifications; ensure that the cable has been securely fastened |
| | Right cover plate | Re-install the cover and secure it with screws after checking all items on the AC side |
| Communication terminals | Network Port Terminal | Connections are correctly made without loosening and are locked |
| | signal terminal | Connections are correctly made without loosening and are locked |
| | USB | No loosening of the correct insertion, no gaps in the sealing ring |
| bottom cover | bottom cover | Please make sure that the wiring is correct and then cover the lower cover of the machine and lock it tightly |

Note:

After the wiring is completed, please make sure to check that the lower cover plate is installed reliably to ensure that the protection level of the machine is not affected by installation problems.

Commissioning 7

7.1 Commissioning the WIT Inverter

| | |
|---|---|
|  | <ul style="list-style-type: none">The WIT Inverter might show wrong time and date if it has been stored for over a month. You need to set the correct time and date before connecting the WIT Inverter to the grid. |
|  WARNING | <ul style="list-style-type: none">When The WIT is only connected to the battery, the battery switch must be pressed until the battery is fully awakened. |

7.1.1 Set the Communication Address

After the WIT Inverter is powered on, you can set the communication address of the WIT Inverter via RS485 communication or the USB to WiLAN-X2 module. When multiple inverters are connected in parallel with RS485 hand-in-hand communication, each inverter should be set to different communication addresses. For a single inverter, the default communication address is set to 1.

NOTE:


The communication address of the WIT Inverter ranges from 1 to 254. By connecting the WIT Inverter to the host computer through RS458 communication, you can change its communication address via Shinebus. This operation should be performed by professional personnel.

7.1.2 Set the Time and Date

7.1.2.1 Set the time and date on the APP (Shinephone/Shinetools)

Follow the instructions in Section 6.6.3 to connect the datalogger. Take Shinephone APP as an example, When the inverter is powered in, you can set inverter time and date referring to Section 8.1.1.Tap Control > Set Inverter Time, then enter the password "growatt+date".For instance, if the date is Feb. 28, 2024, the password would be "growatt20240228". After that, tap "Yes".

1. Set the correct date, then tap "OK". Proceed to set the time, and tap "OK".



7.1.2.2 Set the Date & Time Automatically

Connect the WIT Inverter to the server following the procedure specified in Section 8.1.2 when the inverter is powered on, then the WIT Inverter will update its date and time automatically.

7.2 Mode of operation

7.2.1 Waiting Mode

When the PV voltage is greater than 150V, the WIT Inverter will be powered on and enters the waiting mode.

In waiting mode, the WIT Inverter performs self-check. If the system is normal and the voltage is greater than or equals to 165V, the WIT Inverter will be powered on.

7.2.2 Operating Mode

7.2.2.1 Operating Mode of WIT 4-25K-XHU

>Load First:

In Load First mode, the WIT inverter prioritizes supplying the solar power and battery energy to the loads. If Export Limitation is disabled, the surplus solar power can be fed to the grid, but the battery energy will not be exported to the grid; if Export Limitation is enabled, neither solar power nor battery energy would be sent to the grid.

Priority of power supplied to the loads:

1. Solar panels;
2. Batteries;
3. Grid.

NOTE: In Load First mode, one meter or three CTs are required.

>Battery First:

In Battery First mode, the solar power is prioritized towards charging the battery until the battery SOC (state of charge) reaches the preset upper threshold. Then it will supply power to the loads. The further excess solar power, if any, can be fed to the grid (Export Limitation disabled). In case that the solar power is insufficient, the WIT inverter will draw power from the grid to charge the battery or supply the loads.

Priority of power directed to charge the battery:

1. Solar panels;
2. Grid.

>Grid First:

In Grid First mode, the WIT inverter prioritizes supplying the solar power to the loads, exports the excess solar power to the grid, and sends the further surplus power to charge the power. If the solar power is insufficient to support the loads, the battery will discharge to supply power to the loads and the surplus battery power will be sent to the grid for revenue.

Priority of power supplied to the loads:

1. Solar panels;
2. Batteries;
3. Grid.

>Solar only backup

In Solar only backup mode, the grid cannot charge the battery, the solar power is prioritizes charging the battery until the SOC of the battery reaches the preset upper threshold, the excess power of solar supplies power to the load. If the excess power of solar is not enough to supply the load, the grid will supplement the power to the load; if the excess power of the solar is greater than the load, the excess power will be exported to the grid(Export Limitation disabled). In Off-grid mode, the PV and battery supply power to the load.

Priority of load power supply:

1. Solar;
2. Grid(On-grid);
3. Battery(Off-grid).

>Idle/Charge from clipped solar

In Idle mode, when the solar power is greater the load, the solar supplies power to load first, and the excess power will be exported to the grid(Export Limitation disabled); when the solar power is less than load, the solar and the grid supply the load together. In this mode, the battery is neither charged nor discharged. In Off-grid mode. if the PV power exceeds the load, the excess PV power will charge the battery.

Priority of load power supply:

1. Solar;
2. Grid(On-grid);
3. Battery(Off-grid).

>PTO

In PTO mode, PV is only used to charge the battery, and the grid can supply power to the load through the bypass. In this mode, there is no energy interaction between DC and AC.

> Grid first(ECO)

In ECO mode, the solar and the battery prioritize the power to meet the load demand, the excess power of the solar will be exported to the grid(Export Limitation disabled), and if there is excess power, it will charge the battery. If the excess power of the solar is not enough to supply the load, the battery will supplement the power to the load. The excess energy of the battery will not be exported to the grid.


Priority of load power supply:

1. Solar;
2. Battery;
3. Grid.

Zero export to meter(or three external CTs):


With Export Limitation enabled, no solar power or battery energy will be fed to the grid in this mode. The inverter output is only supplied to the loads connected before the external meter connection point. A meter is required. For the meter wiring mode, please refer to Fig 6.6 in Chapter 6. The external meter will detect power flowing to the grid and regulate the generated power so that only so much energy is generated as is currently consumed by the primary loads, secondary loads and charging the battery.

NOTE: The arrow at the bottom of the Meter or external CTs should point to The WIT.



Zero export to GRID:

In this mode, there is no output at the inverter's GRID port. The solar and battery power can only be supplied to Primary Loads via the LOAD port. The meter or external CTs is not required.



Smart Load:

Smart loads are connected to the GEN port and the Smart Load mode is set: during on-grid operation, it will supply grid power to smart loads; during off-grid operations, the power supply to smart loads is cut off when the battery SOC is below "SOC under secondary load" Set Value. The wiring method is shown in Chapter 6 Fig 6.3.

AC couple:

The grid-tied inverter is connected to the GEN port and the AC Couple mode is set: during on-grid operation, the grid-tied inverter will be connected to the grid and generate electricity via the GEN port; during off-grid operation, the grid-tied inverter remains connected to the WIT inverter and generating power. The wiring method is shown in Chapter 6 Fig 6.2.


NOTE: Limitations for inverter connected to GEN port

1. Power restriction: The rated power of the inverter shall not exceed the smaller value between the PCS rated power and battery power.
2. Manufacturer requirement: External PV inverter must be manufactured by Growatt.
3. Safety compliance: Safety certification number must be identical to that of the PCS.
4. Communication protocol: In AC Couple mode, the PCS must be connected to lithium batteries equipped with communication functions.

7.2.2.2 System Operating Strategies of WIT 4-25K-XHU

TOU (Time of use):

Configure the system to work in the preset mode during different time segments based on the peak-valley periods and electricity price. Setting items include: the operating mode, enable/disable AC Charging function (charge from grid). During the time not specifically configured, it will operate according to the system settings.




Self-consumption:

The WIT inverter prioritizes supplying the solar power and battery energy to the loads. If Export Limitation is disabled, the surplus solar power can be fed to the grid, but the battery energy will not be exported to the grid; if Export Limitation is enabled, neither solar power nor battery energy would be sent to the grid. In case that the solar power is insufficient, the battery will discharge to power the loads.

Priority of power supplied to the loads:


1. Solar panels;
2. Batteries;
3. Grids.

NOTE: In Load First mode, a meter is required.



Grid Peak Shaving:

Set the forward power flow threshold A: once the load power on the external meter is greater than this value, the inverter will reduce charging power and boost power out until it reaches the maximum operating power of the WIT inverter. Set the reverse power flow threshold B: once the grid feed-in power on the external meter is greater than this value, the inverter will reduce output power and boost charging power until it reaches the maximum operating power of the WIT inverter.



NOTE: The priority of system operation modes should be: Demand management >TOU(Time of use)>Parameter settings.

Micro-grid (PV-ESS-DG Power System):

A generator is connected to the GEN port:


If the grid power is normal, the WIT inverter will work in the grid-tied mode:

1. If the power generated by the grid-tied inverter is sufficient to support the loads, the surplus power will be used to charge the battery;
2. If the power generated by the grid-tied inverter is insufficient, the WIT inverter will supply the solar power to the loads, and direct the surplus power to charge the battery;
3. If the solar power of the WIT inverter is insufficient, the battery will discharge to power the loads;
4. The battery will stop discharging when the SOC is lower than the cutoff threshold and it will draw the grid power to support the loads;

If the grid power is abnormal, the WIT inverter will work in the off-grid mode:

1. The solar power of the WIT inverter is supplied to the loads first, and the surplus power is sent to charge the battery.

- If the solar power of the WIT inverter is insufficient, the battery will discharge to power the loads.
- When the battery SOC is lower than the preset diesel generator startup threshold, the GEN will start automatically to generate power
- If charging from the GEN is enabled, the GEN will charge the battery.
- When the battery SOC is higher than the preset diesel generator shutdown threshold, it will disconnect the GEN, and shut down the GEN



User-defined dry contact:

After enabling the user-defined DI port and inputting the DI signal, it will carry out the AC active power and power factor according to the corresponding DI instructions.

NOTE: 1. The User-defined dry contact and DRMS share the same port.

2. Only one DI signal can be input at the same time.

7.2.3 Fault Mode

The intelligent control system of the WIT Inverter monitors and adjusts the system status in real time. When the WIT Inverter detects an alarm, the corresponding status light will turn red and the OLED will display the alarm. When the WIT Inverter detects a fault, the system status indicator and the corresponding status light will turn red and the OLED will display the fault. After the fault or alarm is cleared, the system recovers and all status indicators will be steady green.

NOTE: For details about faults and alarms, please see 9.2 Troubleshooting.

7.2.4 Shutdown Mode

When the battery SOC is lower than the discharge cutoff SOC and the PV string output power does not meet the requirements for grid-tied power generation, the WIT Inverter will automatically shut down. In shutdown mode, the inverter still consumes a bit energy (PV>Grid>Battery) to wait to start up again when the operating requirements are met.

NOTE: When the PV input voltage is less than 150V or the battery input voltage is less than 120V, the WIT inverter will automatically shut down.

7.3 LED and OLED Displays Panel

The LED and OLED display panel demonstrating the running status of the WIT Inverter is shown in the Fig 7.6. The symbol description is shown in Table 7.1; The user interfaces are shown in Fig 7.7, and the LED indicator description is shown in Table 7.2.




Fig 7.1 Display panel

Table 7.1 Symbol Description

| Position | Description | Note |
|----------|--------------------|---|
| A | OLED screen | Displays the main system information |
| B | System indicator | Displays the system status |
| C | PV indicator | Indicates the operation status on the PV side |
| D | Grid/GEN indicator | Indicates the operation status on the grid side and the GEN port status |
| E | Off-grid indicator | Indicates whether the off-grid mode is enabled |
| F | Battery indicator | Indicates the status of the battery |
| G | Communication | Indicates the communication status and other system faults |
| H | Button | You can switch the information displayed on the OLED by pressing the button |




Fig 7.2 User interfaces

Table 7.2 Indicator description

| | Status | Meaning |
|--|----------------------------------|--|
| | Off | The system is not operating |
| | Steady green | The system is operating properly |
| | Blinking green at long intervals | The system is in standby mode or performing an upgrade |
| | Steady red | System failure |
| | Off | The PV voltage dose not reach the operating voltage |
| | Steady green | The PV voltage reaches the operating voltage |
| | Steady red | A fault or alarm is reported on the PV side |
| | Off | The grid voltage is below the operating voltage |
| | Steady green | Successfully connected to the grid |
| | Steady red | A fault or alarm occurs on the grid side |

| | Status | Meaning |
|--|---|--|
| | Off | Off-grid mode is disabled |
| | Steady green | Off-grid mode is enabled and has no faults or alarms |
| | Steady red | Off-grid mode is enabled and a fault or alarm is reported on the AC side |
| | Off | The battery voltage is below the operating voltage |
| | Steady green | The battery voltage reaches operating voltage |
| | Steady red | SOC (state of charge) is low; A fault or alarm occurs on the battery side |
| | Off | The WIT Inverter has no external communication |
| | Steady green | External communication is normal, such as RS485, WLAN, etc. |
| | Blinking green at long intervals | The WIT Inverter is upgrading or the USB interface is reading and writing data |
| | Steady red | External communication fails or a system fault occurs, such as fan fault |
| | The OLED displays critical system information. Users can call up and switch the interface by tapping the button. When a fault or alarm occurs in the system, the fault or alarm is displayed. | |
| | The OLED will wake up when the button is pressed. The OLED will turn off if there is no operation for 5 minutes. | |

8 Monitoring

8.1 Remote Monitoring

Growatt WIT 4-25K-XHU Hybrid inverters support Bluetooth/remote monitoring, which can be enabled by installing a datalogger. For more information on operation and configuration methods, see the following link.

| Compatible Datalogger | Installation & Operation Guide Linkage |
|-----------------------|---|
| ShineWiLAN-X2 | https://oss-eu.growatt.com/common/knowledgeShareH5No?lang=en&type=159 |

Scan the following QR code or search for "ShinePhone" and "Shinetools" in Google/Apple Store to download and install the mobile APP.



NOTE:

- (1) Download and install the latest version of ShinePhone.
- (2) See <https://server-us.growatt.com/?lang=en> for details.
- (3) Shinephone and Server accounts are universal.

8.1.1 Bluetooth Monitoring on the APP (Shinetools)

1. Open the ShineTools APP. On the login screen, tap "End User" and enter the password, which is in the format of "oss + the current date". E.g. oss20241225. Then tap "Sign in".

You can tap "Automatic log-in" to select whether to Log in automatically, as the figure shows.

ShineTools



End User



O&M User

Please enter the initial password

Automatic Log-in

[Forgot password](#)

[Sign in](#)

I have read and agree [«ShineTools User Agreement»](#) and [«ShineTools Privacy Policy»](#).

[Policy».](#)

正式环境

2.Tap “ShineWiLan-X2”, View connection guide, as the fig shows.

Please select a debugging tool

- Only supports datalogger with version 3.0.0.2 / 3.1.0.2 or above >
- Direct WiFi/Bluetooth
(MIN TL-XH-US , SPH 10000TL-HU- US , WIT-H/H/E/HU-US)
- Microinverter >
- ShineWiFi-X2 >
- ShineMaster-X >
- ShineWiLan-X2 > **Selected**
- ShineUART- BT >

Connection tutorial Jump over

Please confirm your collector type

Built-in Bluetooth collector placed inside the inverter

External Bluetooth collector Independently inserted into the inverter collector entrance

Built-in collector connection tutorial

Step 1/3

Find the location of the serial number on the device. This tutorial is applicable to SPH 10000TL-HU-US, SPH 10000TL-HU models, and SPH 10000TL-HU (AU) models.

Next step

Please scan the barcode below manually enter the collector SN located below the barcode.

当前版本 3.4.8.0(54726)

Step 2/3
Please scan the barcode of the collector SN number, or manually enter the collector SN located below the barcode.



Step 3/3
ShineTools will automatically search and connect the collector Bluetooth. If ShineTools searches for multiple Bluetooth, please select the Bluetooth that is consistent with the SN number of the collector to connect.



External collector connection tutorial

Step 1/2
Please make sure that the Bluetooth of the collector is turned on (the blue light is always on). If not, please short press the button to turn on the Bluetooth.



Step 2/2
Scan the code to connect to the device.



External collector connection tutorial

Step 1/2
Please make sure that the Bluetooth of the collector is turned on (the blue light is always on). If not, please short press the button to turn on the Bluetooth.

Next step




Next step




3. After confirming that the Bluetooth of the Datalogger is enabled, scan the two-dimensional code of the Datalogger for connection, as the figure shows.




4. tap "Connect" after the target Bluetooth device is displayed. After successful connection, the screen is shown in the figure.




5. When the device is successfully connected, tap the Device you want to check in the Device List to view the relevant status information and set relevant parameters as required. the screen as demonstrated below will appear, ensuring that the communication between the WIT inverter and the mobile phone has been established via Bluetooth.




Tap Quick Setting, set time, language, etc., as the figure shows.



Tap System Configuration, you can turn on/off the inverter, set the percentage of active power, etc., as the figure shows.



Tap on the Basic Settings, you can set the baud rate, view the network communication protocol version, as the figure shows.



Tap Grid Code, you can check power factor related parameters, Frequency/Watt, etc., as the figure shows.

| < | Grid Code | Read | < | PF Setting | Read | < | Frequency/Watt | Read |
|-----------------------------------|-----------|------|-----------------------------|----------------------------------|-----------------------------------|-----------------------------|----------------|----------|
| PF Setting | | > | Set PF as 1 | <input checked="" type="radio"/> | Derating Point for Over Frequency | | 50.2Hz > | |
| Frequency/Watt | | > | Default PF Curve | <input type="radio"/> | Delaytime OF derating | | 0ms > | |
| Voltage/Var | | > | Inductive Reactive Power % | | > | OF Derate Recover Point | | 53.0Hz > |
| Normal Gradient | | > | Capacitive Reactive Power % | | > | UnderF Upload Point | | 49.8Hz > |
| AC Voltage Protection | | > | Set power factor | | > | UnderF Upload DelayTime | | 0ms > |
| AC Frequency Protection | | > | PF Curve In/Out Vac | | > | UnderF Upload RateEE | | 50 > |
| Synchronization Range | | > | Limit Point of PF Load % | | > | UnderF Upload Response Time | | 0ms > |
| Protection Value of 10min Avg Vac | 438.1V | > | Limit Point of Power Factor | | > | | | |

Tap EMS, you can set the use time, AC charging enable and other related information, as the figure shows.

| EMS | Read | Time of Use Setting | Read |
|-------------------------|-------------------------------------|---------------------|--------------------------|
| Time of Use Setting | > | power | 100% > |
| Enable AC Charge | <input checked="" type="checkbox"/> | Time Period 4 | <input type="checkbox"/> |
| Charge Power Ratio % | 10% > | 00:00-00:00 | > 11:30-18:00 |
| Battery Charge Stop SOC | 100% > | power | 100% > |
| Discharge Power Ratio % | 100% > | Time Period 5 | <input type="checkbox"/> |
| Stop Discharging SOC | 10% > | 00:00-00:00 | > 18:00-23:00 |
| Battery | > | power | 100% > |
| | | Time Period 6 | <input type="checkbox"/> |
| | | 00:00-00:00 | > 23:00-23:59 |
| | | power | 100% > |
| | | Load First | <input type="checkbox"/> |
| | | Enable | <input type="checkbox"/> |
| | | Disable | |
| | | Yes | |

Tap Peak Shaving to Enable/disable Demand management Enable and set Demand Mange Charge Power Limit as the figure shows.

| < | Peak Shaving | Read |
|--------------------------------|-------------------------------------|------|
| Demand management Enable | <input checked="" type="checkbox"/> | |
| DemandMangeChargePowerLimit | 0.0kW > | |
| DemandMangeDisChargePowerLimit | 0.0kW > | |
| Peak Shaving bBakSocEnable | <input checked="" type="checkbox"/> | |
| Peak Shaving bBakSocEnable | 0% > | |

Tap Device Information, and then select the section you want to know, you can view the relevant content on the screen, as the figure shows.

| < | Device Information | Read |
|------------------------------------|--------------------|------|
| PV Voltage/Current/Power | ▼ | |
| AC Voltage/Frequency/Current/Power | ▼ | |
| Battery Parameter | ▼ | |
| GEN voltage/power | ▼ | |
| temperature | ▼ | |
| Anti-reverse CT current | ▼ | |
| Internal Parameter | ▼ | |
| About Inverter | ▼ | |

| < | Device Information | Read |
|------------------------------------|--------------------|-------|
| PV Voltage/Current/Power | ▼ | |
| PV1 | PV2 | |
| Voltage(V) | 598.8 | 108.4 |
| Current(A) | 0.0 | 0.0 |
| AC Voltage/Frequency/Current/Power | ^ | |
| AC Power(W) | 0 | |
| PF | 1 | |
| AC Frequency(Hz) | 4999 | |
| R Phase Voltage(V) | 1.1 | |
| R Phase Power(W) | 0 | |
| R Phase Current(A) | 0 | |
| S Phase Voltage(V) | 0.4 | |
| S Phase Power(W) | 0 | |
| S Phase Current(A) | 0 | |
| T Phase Voltage(V) | 1.8 | |
| T Phase Power(W) | 0 | |
| T Phase Current(A) | 0 | |
| Battery Parameter | ▼ | |


8.1.2 Remote Monitoring on the APP (ShinePhone)

NOTE:

- (1) Download and install the latest version of ShinePhone.
- (2) See <https://server.growatt.com/?lang=en> for details.
- (3) Shinephone and Server accounts are universal.

Account Registration on ShinePhone

Run the APP and tap “Register” on the login page. Fill in the information as required. Fields marked with * are mandatory. Tick the checkbox to agree to the Privacy Policy. Once the account is successfully registered, you can log in to the home screen. The registration page is shown below:



Add Plant

After logging in to ShinePhone, tap on "Plant" and follow the steps shown. Fill in the information as required. Fields marked with * are mandatory.

Plant list

1 +

Parameters

2 Add Plant

3

Add Plant

* Plant name Enter the Plant name

* Installation date Select the installation date

Plant address

* Other City

Please enter the full address

Longitude Latitude

* Time zone +08

* PV capacity(W) PV capacity

* Plant type

Residential plant Commercial plant Ground-mounted plants

Temperature type

Centigrade(°C) Fahrenheit(°F)

(Conversion is based on 1 kWh power generation)

Fund Revenue USD

PV Plant picture Please select an image to upload

4 Add Plant

Connect the Datalogger to the network on shinephone

Perform operations according to the steps shown in the figure. Note that the Bluetooth of the Datalogger must be enabled, that is, the blue light of the Datalogger is on.

Plant list

1 +

Plant management

2 Add datalogger

Datalogger list

3

Configure datalogger

1 2

Add datalogger

Please scan the QR code of the datalogger/Bar code

3

Datalogger configuration

1 2


Add datalogger

Enter the datalogger serial number and check code

SN JKNDE7Q042


Check code 6D846

4 Confirm



Home Screen of ShinePhone

1. Dashboard: displays the critical information of all power plants under the account, such as the total yield, the total revenue and the status of the device. Please refer to the figures below:



2. Plant: displays the plant list and the basic information about each PV plant, as shown in the figure below. You can select your target plant to view detailed information.

The screenshot shows a 'Plant list' interface with the following data for five entries:


| Plant name | Current Power | PV capacity | Daily Power Gen |
|---------------|---------------|-------------|-----------------|
| 商储系统应用测试 | 0kW | 100kWp | 0.0kWh |
| WIT+ACE+SEM系统 | 0kW | 465kWp | 0.0kWh |
| 商储系统并机测试 | 0kW | 0.2kWp | 0.0kWh |
| test | 0kW | 0.1kWp | 0.0kWh |
| 采集器测试 | 0kW | | 2024-07-25 |

Below the table are navigation icons: Dashboard, Plant, GroHome, Service, and Me.

Detail Page of the WIT Inverter:

To access details about the WIT Inverter or related devices:


- (1) Tap “Plant” and the “Plant List” will be displayed. Select your target plant, then you can access the real-time data and history record of the power plant;
- (2) Select the WIT Inverter marked with its SN from “My device list”. The figures below show QWL0DC3008 as an example;
- (3) On the Detail Page, you can view information about the inverter and related devices. Three sections - “Events”, “Control” and “Edit”, are available at the bottom.



(4) On the “Events” screen, you can view the fault/warning message and suggested trouble-shooting measures.

| Warning list | |
|---------------------|---|
| 2024-09-30 18:12:45 | |
| SN | 1234567891 |
| Plant name | test |
| (419) | DSP software version and Hardware version unmatched |
| 2024-09-30 17:05:47 | |
| SN | 1234567891 |
| Plant name | test |
| (419) | DSP software version and Hardware version unmatched |
| 2024-09-30 15:57:49 | |
| SN | 1234567891 |
| Plant name | test |
| (419) | DSP software version and Hardware version unmatched |
| 2024-09-15 08:50:19 | |
| SN | 1234567891 |
| Plant name | test |
| (444) | No more data |

(5) On the “Control” screen, you can configure the WIT Inverter. The password is in the format of “growatt + the current date”, e.g. growatt20240228.



➤ Set lower frequency limit

Tap Control >Safety parameter setting >UV1/UV2/UV3 Frequency; You can set the lower frequency limit of The WIT.




➤ Set frequency Upper limits

Tap Control > Safety parameter setting > OV1/OV2/OV3 Frequency; You can set the upper frequency limit of The WIT.




➤ Set lower voltage limit

Tap Control > Safety parameter setting > UV1/UV2/UV3 Voltage; You can set the lower voltage limit of The WIT.



➤ Set upper voltage limit

Tap control > Safety parameter setting > OV1/OV2/OV3 Voltage; You can set the upper voltage limit of The WIT.



➤ Grid related settings

Tap Control > Safety parameter setting > Grid related settings, you can set the voltage Over/lower threshold of grid connection and the frequency Over/lower threshold of grid connection, as the figure shows.




➤ Loading, restarting, and unloading rates

Tap Control > Safety parameter setting > Loading, restarting, and unloading rates; you can set Loading, restarting, and unloading rates.




➤ Settings related to OF derating

Tap Control > Safety parameter setting > Loading, restarting, and unloading rates; You can set OF derating.




➤ Settings related to UF increasing

Tap Control > Safety parameter setting > Loading, restarting, and unloading rates; You can set UF derating.




➤ Grid Reconn Wait Time

Tap Control > Safety parameter setting > Grid Reconn Wait Time; You can set Grid Reconn Wait Time.




➤ **Frequency change rate enable**

Tap Control > Safety parameter setting > Frequency change rate enable; You can set Frequency change rate enable.




➤ **Set Inverter On/Off**

Tap Control > General settings > Set Inverter On/Off; you can power on/off the inverter, as the figure shows.




➤ Set the Time of the Inverter

Tap Control > General settings > Setting Time; you can set the local time, as the figure shows.




➤ System Mode

Tap Control > General settings > System Mode; you can set the System Mode, as the figure shows.




➤ Set Reactive Power

Tap Control>General settings> Set reactive power. You can set different reactive power modes; as the figure shows.




➤ Enable the grid side electricity meter

Tap Control > General settings > Enable the grid side electricity meter, you can Enable/Disable grid side electricity meter.




➤ Settings related to AC charging

Tap Control > General settings > Settings related to AC charging, You can set the parameters related to AC charging.



➤ Set the Battery Enable

Tap Control > Battery Setting > BMS1/BMS2/BMS3 Enabled, you can enable/disable Battery_1, Battery_2 and Battery_3, as the figure shows.




Note:

BMS is unnecessary for lead-acid batteries but mandatory for lithium batteries.




➤ Set the Battery

Tap Control > Battery Setting > Battery 1 related settings, you can set the Battery related parameters (the battery capacity, ranging from 0 to 290Ah; the maximum charging/discharging power, ranging from 0 to 25kw; the maximum charging/discharging current, ranging from 0 to 55A; the battery maximum charging voltage, ranging from 120V to 800V; the battery discharge cutoff voltage, ranging from 0 V to 120V), as the figure shows.





➤ Set the Off grid parameter settings

Tap Control > Off grid parameter settings > Related settings for grid connection and off grid. Two options are available: Automatic mode and Manual mode. If the Manual mode is selected, you can set the inverter to work in the on-/off-grid, or generator mode, as the figure shows. The Automatic Mode is recommended as the figure shows.




➤ Set the Off grid related settings

Tap Control > Off grid parameter settings > Off grid Related Setting, you can enable/disable the off-grid mode, set the off-grid frequency (50Hz/60Hz) and the off-grid voltage (220V/230V/ 240V/277V/127V), complying with the safety regulations.as the figure shows.




➤ Single machine anti backflow setting

Tap Control > Single machine anti backflow setting > Single machine anti backflow related settings, You can Enable/Disable the Single machine anti backflow function.




➤ Set the Single phase Export Limitation

Tap Control > Single machine anti backflow setting > Single phase anti backflow enable, you can enable/disable the Single phase anti backflow function, as the figure shows.




➤ Set the Maximum spontaneous self use

Tap Control > Advanced > Maximum spontaneous self use, you can enable/disable the Maximum spontaneous self use function, as the figure shows.



➤ Equipment mode selection and time setting


Tap Control > Advanced > Equipment mode selection and time setting; 6 time segments are configurable. You can set the start and end time of each period, the corresponding working mode, including Load First, Battery First and Grid First,solar only backup、IDLE/Charge From Clipped Solar、PTO and ECO., and whether to enable/disable the selected working mode. Choose the appropriate working mode considering the corresponding electricity rates and power consumption during the specific time period.



➤ Demand Management/Peak Shaving

Tap Control > Advanced > Demand Management/Peak Shaving, you can enable/disable the Demand Management Enablement

Function、Peak Shaving Backup SOC Enable Function and setting PeakinShaving Backup SOC, as the figure shows.



➤ Microgrid system

Tap Control > Advanced > Microgrid system, you can select Types of Access for GEN Port Devices, include “Generator”、 “PV inverter” and “Smart Load” ; Enable/Disable Generator Enable; Generator Rating, ranging from 0 to 1000kW; Off grid oil engine startup SOC, ranging from 0 to 100%; Off grid oil engine stops SOC. ranging from 0 to 100%; Heat up time, ranging from 0 to 3600s; Power limit for oil engine charging, ranging from 0 to 1000kW;

Note:

The type of equipment connected to the GEN port and whether it is enabled need to be configured while the inverter is in standby mode.

Microgrid system

Types of Access for GEN Port Devices

Generator

Generator Enable

Disable

Generator Rating

50.0 kW [0.01000.0]

Off grid oil engine startup SOC

48 % [0.100]

Off grid oil engine stops SOC

60 % [0.100]

Heat up time

-1 s [0.3600]

Power limit for oil engine charging

-1 kW

-1 s [0.5600]

Power limit for oil engine charging

-0.1 kW [0.01000.0]

Electricity Meter 2 Enable

Disable

AC CoupleEnable

Enable

AC Couple Charging Start SOC

-1 % [0.100]

AC Couple Charging Stop SOC

-1 % [0.100]

SOC under secondary load

-1 % [0.100]

Microgrid system

Types of Access for GEN Port Devices

Generator

Generator Enable

Disable

Generator Rating

50.0 kW [0.01000.0]

Off grid oil engine startup SOC

48 % [0.100]

Types of Access for GEN Port Devices

Generator

PV Inverter

Smart Load





Generator Enable

Enable

Disable


➤ Safety function control

Tap Control > Advanced > Safety function control, you can Enable/Disable Low voltage crossing etc.




➤Parallel parameter setting


Tap Control > Advanced > Parallel parameter setting, you can Enable/Disable Parallel parameter setting.




(6) On the “Edit” screen, you can change the device name as the figure shows.




3. GroHome: displays the home energy system, including four sections: "PV linkage", "My device list", "My room" and "My scene"



4. Service: includes the common faults and troubleshooting suggestions, as shown in the figure below. Should you encounter any problem about our product, you can contact the Growatt after-sales support or refer to the related documents




5. Me: You can check the account information, configure the datalogger or view notifications, as shown in the figure below.



8.1.3 Remote Monitoring on the ShineServer Webpage

1. Open the browser, then enter <https://server.growatt.com/login?lang=en> in the address box to access the login page. Click “Register an Account” if you do not have an account.



2. After the Registration Page is displayed, fill in the information as required and click to agree to the Privacy Policy. Fields marked with the “.” icon are mandatory. Click next, it will bring you to the “Add Plant” page. Then click “Back to Login” on the top right corner.

The screenshot shows the 'Register' page for a 'User'. At the top, there are three tabs: 'User' (which is selected and highlighted in red), 'Installer', and 'Distributor'. Below the tabs, there are several input fields with validation messages:

- Country:** [dropdown menu] *
- User Name:** [text input] Not More than 30 Characters *
- Password:** [text input] Not less than 6 Digits *
- Confirm Password:** [text input] Not less than 6 Digits *
- Language:** [dropdown menu] English *
- Phone Number:** [text input]
- E-Mail:** [text input]
- Installer Code:** [text input]

At the bottom of the form, there are two buttons:

- 3 I have read and agree to the (Privacy Policy)
- 4 **Next**


In the top right corner, there is a link: **Back to Login**.

This screenshot shows the second step of the registration process, titled 'Please Fill in the Plant Information'. It includes a 'Skip' button in the top right corner and a 'Back to Login' link. The form contains the following fields:

- Plant Type:** [dropdown menu] Residential Plant (selected) *
- Plant Name:** [text input] Please Enter Plant Name! *
- Installation Date:** [text input] *
- Time Zone:** [dropdown menu] UTC +8 *
- Map Selection:** [button] Map Selection *
- Please Fill in the Plant Information:** [dropdown menu] Singapore *
- Please Select City:** [dropdown menu] *
- Please Enter The Full Address:** [text input]
- PV Total Capacity(kWp):** [text input]
- Selling Price:** [text input] RM800 *

A large blue 'Next' button is located at the bottom center of the form.

3. On the Login screen, enter the username and the password to log in to the home screen.



4. After accessing the home screen, the "Add Plant" window will pop up. Fill in the information as required (marked with "-") and click "Yes". If the plant has been created, you can select the target plant on the home screen.

Installation Information

| | | | | |
|------------|-----------------------------|-------------------|----------------------------------|-----------|
| Plant Type | Residential Plant | Installation Date | PV Total Capacity(kWp) | Installer |
| Plant Name | Example: David 6.24Wp Plant | Temperature type | Centigrade(°C) Fahrenheit(°F) | |

Location Information

| | | | |
|-------------|--|-----------|----------|
| Country | Please Select | City | Address |
| Time Zone | UTC -12 | Longitude | Latitude |
| Plant Image | <input type="file"/> Only support JPG, PNG, JPEG, BMP; the size of no more than 5M <input type="file"/> Only support JPG, PNG, JPEG, BMP; the size of no more than 5M | | |

Set Revenue Formula(Set 1Kwh As The Conversion Standard)

| | |
|-----|--------|
| Yes | Cancel |
|-----|--------|

Total Generation
1.7(MWh)


PV Total Capacity
0.0(kWp)

Total Revenue
1714(¥)

| All Plants | Residential Plant | Commercial Plant | Ground-Mounted Plants | Online | Abnormal | Offline | Power Station Sequencing | Real-time Power Priority | Please Enter Plant Name | Q |
|----------------------|---------------------|----------------------|-----------------------|----------------------|---------------------|----------------------|--------------------------|--------------------------|-------------------------|---|
| | | | | | | | | | <input type="text"/> | |
| 0kw Generation Today | 0kw Real-time Power | 0kw Generation Today | 0kw Real-time Power | 0kw Generation Today | 0kw Real-time Power | 0kw Generation Today | 0kw Real-time Power | 0kw Generation Today | 0kw Real-time Power | |

WIT 15K Test

5. Click the target plant and the detailed page will be displayed, click “Add Data Logger” on the upper right corner to add the datalogger connected to the inverter.
- 1) Enter the serial number (SN) of the datalogger.
2) Select the target power plant. You might need to enter the verification code of the datalogger as prompted.




Data Logger SN

Data Logger Check Code

Assigned Plant ▼

Yes Cancel

6. After adding the datalogger successfully, you can click Dashboard to view details about related devices.



Dashboard:

1. Running status and energy display




- 1) Plant List: select the target plant from the drop-down list
- 2) Device Type: Select the device from the drop-down list
- 3) Input/Search Number: Upon the initial search, enter the serial number of the specific device; If you have searched for it before, you can select the device from the drop-down list
- 4) Data Sources: displays the data source of the selected device: Load First, Battery First and Grid first.
- 5) System Status: displays the running status of the selected device: operating, faulty, standby and off-line
- 6) System Running Graph: displays the power flow between the PV modules, the battery, the generator and the AC side
- 7) Energy: displays today's/total PV generation, power imported from grid, power exported to the grid and the load consumption

2. Energy Trend

- 1) System Production: displays the power for self-consumption and the power exported to the grid
- 2) Date: select a specific date, you can view the energy data in a specific period, day, month or year
- 3) Load Consumption: displays the power for self-consumption and the power drawn from the grid
- 4) Display options: to show/hide the content by clicking the corresponding color circle. By placing the cursor on the specific color circle for a long period, it will display the energy trend of the selected item only



3. Battery Information




- 1) Battery charge and discharge information over the last seven days: it can display the charge and discharge history of the battery clusters over the past seven days.
- 2) Battery rack daily SOC information: displays the battery SOC.

4. My PV devices

This section displays all devices involved in the selected PV plant (online devices are shown first, followed by offline devices).


Energy

1. Parameter comparison



- 1) Device type: Select the device type for comparison, such as the WIT inverter or the meter.
- 2) Date: select a specific date, you can view the energy data in a specific period, day, month or year.
- 3) Power curve: Show the power curve of the machine operation.

2. Plant Management



Click Plant Management and you can view all PV plants associated with the current account.

- 1) Edit: Click the "Edit" icon (indicated in the figure above) to modify the PV plant information
- 2) Delete: Click the "Delete" icon (indicated in the figure above) to delete the selected PV plant
- 3) Data: Click the "Data" icon (indicated in the figure above) to view the energy yield and power of the selected plant

Log

On the Log page, you can view the error code and the fault description.

| No. | Device Serial Number | Device Type | Device Model | Fault Status | Time | Recovery time | Event Number | Fault Description | Solution |
|-----|----------------------|-------------|--------------|--------------|---------------------|---------------|--------------|--|--|
| 1 | 0K0Q102R1XNP0001 | Wit | WIT 50K-XHU | WIT | 2024-12-05 15:38:11 | 500 | | SPH failed to communication with lithium battery | 1.Check the lithium battery is open or not.2.if error message still exists,contact manufacturer. |
| 2 | 0K0Q102R1XNP0001 | Wit | WIT 50K-XHU | WIT | 2024-12-03 15:05:10 | 500 | | SPH failed to communication with lithium battery | 1.Check the lithium battery is open or not.2.if error message still exists,contact manufacturer. |
| 3 | 0K0Q102R1XNP0001 | Wit | WIT 50K-XHU | WIT | 2024-12-03 15:32:11 | 500 | | SPH failed to communication with lithium battery | 1.Check the lithium battery is open or not.2.if error message still exists,contact manufacturer. |
| 4 | 0K0Q102R1XNP0001 | Wit | WIT 50K-XHU | WIT | 2024-12-05 15:26:11 | 500 | | SPH failed to communication with lithium battery | 1.Check the lithium battery is open or not.2.if error message still exists,contact manufacturer. |
| 5 | 0K0Q102R1XNP0001 | Wit | WIT 50K-XHU | WIT | 2024-12-05 15:26:11 | 500 | | SPH failed to communication with lithium battery | 1.Check the lithium battery is open or not.2.if error message still exists,contact manufacturer. |
| 6 | 0K0Q102R1XNP0001 | Wit | WIT 50K-XHU | WIT | 2024-12-05 15:26:11 | 500 | | SPH failed to communication with lithium battery | 1.Check the lithium battery is open or not.2.if error message still exists,contact manufacturer. |

Setting

1. Account management

1 Userinfo Modify Please develop the information so that we can better serve you.)

User Name:

Company Name:

Real Name:

E-mail:

Phone Number:

Language:

Agent Code:

API Secret Key token:

2 Modify Password

User Name:

Current Password:

New Password:

Confirm Password:

1) Modify your account information

2) Change the password: you can change the password on this page

2. Download

A range of documents are available for download.

| No. | File Name | File Type | File Size | Update Time | Download |
|-----|---|-----------|-----------|-------------|-------------------------|
| 1 | ShineServer user manual | pdf | 4.1MB | 2015-03-21 | ENGLISH |
| 2 | Grovatt ShineWIFI user manual(ShineWEI™)(EN) | pdf | 4.23MB | 2016-09-18 | ENGLISH |
| 3 | Grovatt Shine3G_ShineGPS_user_manual(Shine3G)(ShineGPS)(CN)(EN) | pdf | 3.72MB | 2016-08-18 | ENGLISH |
| 4 | Android Grovatt APP Module | pdf | 0.26MB | 2016-10-25 | ENGLISH |
| 5 | iOS Grovatt APP Module | pdf | 0.26MB | 2016-10-25 | ENGLISH |
| 6 | Grovatt OM WiFi Update Module | pdf | 0.64MB | 2016-04-25 | ENGLISH |
| 7 | Grovatt Webbox Update Module | pdf | 0.26MB | 2016-04-25 | ENGLISH |
| 8 | Grovatt Webbox Instructions | pdf | 1.27MB | 2017-07-20 | ENGLISH |
| 9 | Grovatt DataLog WIF-XXWIFI-S Instructions | pdf | 1.82MB | 2020-04-21 | ENGLISH |
| 10 | Microinverter Installation Map | pdf | 442KB | 2023-11-13 | ENGLISH |

Device

1. Datalogger

GROWATT Davinci Test

Device

Photovoltaic Device

Current Location: Dashboard>Photovoltaic Device>Data Logger

Power Generation Revenue

Datalogger Inverter WIT Smart meter list Battery

9 Device Serial Number or Alias Search Add

10 Datalogger Setting Delete

1 GPGDB/ITFG (1) Data Logger: GPGDB/ITFG 3 Connection Status: Offline Update Time: 2024-07-31 20:08:03 5
2 User Name: Davinci Test Plant Name: Davinci Test Device Type: ShineWlan-X 6
IP & Port: 219.145.88.114:31505 4 Data Update Interval: 5 Minutes Firmware Version: 3.6.0.2 7

2 GPGDB/IT2 (2) Data Logger: GPGDB/IT2 Connection Status: Offline Update Time: 2024-08-05 16:08:14
User Name: Davinci Test Plant Name: Davinci Test Device Type: ShineWlan-X
IP & Port: 219.145.88.114:24811 Data Update Interval: 5 Minute Firmware Version: 3.6.0.9

11 Datalogger Setting Delete

- 1) Serial number: each datalogger has a specific SN, which can be used to search for the device;
- 2) User name and the PV plant to which the datalogger is connected;
- 3) Connection status: connected or disconnected;
- 4) Data update interval;
- 5) Device type;
- 6) Type of equipment;
- 7) Firmware version;
- 8) Enter the serial number to search for the target datalogger;
- 9) Add a datalogger: enter the serial number to add the datalogger;
- 10) Datalogger settings: you can set the update time for the datalogger.

2. WIT

GROWATT Davinci Test

Device

Photovoltaic Device

Current Location: Dashboard>Photovoltaic Device>Data Logger

Power Generation Revenue

Data Logger Inverter WIT Smart meter list Battery


9 Device Serial Number or Alias Search Add



10 Device List Datalogger Setting Delete

1 JKN0E6COT2 (1) Data Logger: JKN0E6COT2 3 Connection Status: Connected Update Time: 2024-12-04 20:18:52 5
2 User Name: Davinci Test Plant Name: Davinci Test Device Type: ShineWlan-X 6
IP & Port: 10.10.103:24055 4 Data Update Interval: 5 Minutes Firmware Version: 7.6.0.7 7

2 JKN0E7Q064

- 1) Enter the serial number to find the device;
 - 2) Device model;
 - 3) User name and the PV plant to which the device is connected;
 - 4) Daily and monthly energy yield;
 - 5) Serial number of the selected device;
 - 6) Operating status: operating, standby, disconnected or faulty;
 - 7) Serial number of the datalogger connected to the device;
 - 8) Rated power;
 - 9) Current power;
 - 10) Parameter settings.
- 10.1) Setting of safety parameters, including 1st, 2nd and 3rd order underfrequency point, overfrequency point, undervoltage point and overvoltage point.





10.2) High grid voltage limit (voltage upper threshold of grid connection).

Setting X

OV3 Voltage [17.3,762.0]V

Grid related settings ▲

High Grid Voltage Limit [17.3,762.0]V

Low Grid Voltage Limit [17.3,762.0]V

High Grid Frequency Limit ⓘ [50.00,55.00]Hz

Low Grid Frequency Limit ⓘ [45.00,50.00]Hz

Loading, restarting, and unloading rates ▲

Loading rate [1.0,6000.0]%

Restart loading rate [1.0,6000.0]%

Load reduction rate [1.0,6000.0]%

Please Enter Password Yes Advanced Setting Cancel

10.3) Low grid voltage limit (voltage lower threshold of grid connection).

Setting X

OV3 Voltage [17.3,762.0]V

Grid related settings ▲

High Grid Voltage Limit [17.3,762.0]V

Low Grid Voltage Limit [17.3,762.0]V

High Grid Frequency Limit ⓘ [50.00,55.00]Hz

Low Grid Frequency Limit ⓘ [45.00,50.00]Hz

Loading, restarting, and unloading rates ▲

Loading rate [1.0,6000.0]%

Restart loading rate [1.0,6000.0]%

Load reduction rate [1.0,6000.0]%

Please Enter Password Yes Advanced Setting Cancel

10.4) High grid frequency limit (frequency upper threshold of grid connection).

Setting

| | | |
|--|-------|-----------------|
| <input type="radio"/> OV3 Voltage | 517.9 | [17.3,762.0]V |
| Grid related settings ▲ | | |
| <input type="radio"/> High Grid Voltage Limit | 438.2 | [17.3,762.0]V |
| <input type="radio"/> Low Grid Voltage Limit | 338.6 | [17.3,762.0]V |
| <input checked="" type="radio"/> High Grid Frequency Limit ⓘ | 50.1 | [50.00,55.00]Hz |
| <input type="radio"/> Low Grid Frequency Limit ⓘ | 49.5 | [45.00,50.00]Hz |
| Loading, restarting, and unloading rates ▲ | | |
| <input type="radio"/> Loading rate | 300.0 | [1.0,6000.0]% |
| <input type="radio"/> Restart loading rate | 300.0 | [1.0,6000.0]% |
| <input type="radio"/> Load reduction rate | -0.1 | [1.0,6000.0]% |

Please Enter Password

10.5) Low grid frequency limit (frequency lower threshold of grid connection).

Setting

| | | |
|---|-------|-----------------|
| <input type="radio"/> OV3 Voltage | 517.9 | [17.3,762.0]V |
| Grid related settings ▲ | | |
| <input type="radio"/> High Grid Voltage Limit | 438.2 | [17.3,762.0]V |
| <input type="radio"/> Low Grid Voltage Limit | 338.6 | [17.3,762.0]V |
| <input type="radio"/> High Grid Frequency Limit ⓘ | 50.1 | [50.00,55.00]Hz |
| <input checked="" type="radio"/> Low Grid Frequency Limit ⓘ | 49.5 | [45.00,50.00]Hz |
| Loading, restarting, and unloading rates ▲ | | |
| <input type="radio"/> Loading rate | 300.0 | [1.0,6000.0]% |
| <input type="radio"/> Restart loading rate | 300.0 | [1.0,6000.0]% |
| <input type="radio"/> Load reduction rate | -0.1 | [1.0,6000.0]% |

Please Enter Password

10.6) Load, restart load, and down load rate settings.

Setting

| | | |
|--|-------|-----------------|
| <input type="radio"/> High Grid Frequency Limit | 50.1 | [50.00,55.00]Hz |
| <input type="radio"/> Low Grid Frequency Limit | 49.5 | [45.00,50.00]Hz |
| Loading, restarting, and unloading rates | | |
| <input checked="" type="radio"/> Loading rate | 300.0 | [1.0,6000.0]% |
| <input type="radio"/> Restart loading rate | 300.0 | [1.0,6000.0]% |
| <input type="radio"/> Load reduction rate | -0.1 | [1.0,6000.0]% |
| Settings related to OF derating | | |
| <input type="radio"/> Derating Start point(f) | 50.2 | [0.00,66.50]Hz |
| <input type="radio"/> Derating Gradient(f) | 50 | [0,2000] |
| <input type="radio"/> Over-frequency load reduction delay time | 0.0 | [0.0,20.0]s |

Please Enter Password


10.7) Setting the start point of overfrequency load shedding: Load shedding after higher than the set frequency.

Setting


| | | |
|---|------|----------------|
| Settings related to OF derating | | |
| <input checked="" type="radio"/> Derating Start point(f) | 50.2 | [0.00,66.50]Hz |
| <input type="radio"/> Derating Gradient(f) | 50 | [0,2000] |
| <input type="radio"/> Over-frequency load reduction delay time | 0.0 | [0.0,20.0]s |
| <input type="radio"/> Over-frequency load reduction response time | 0.0 | [0.0,40.0]s |
| Settings related to UF increasing | | |
| <input type="radio"/> UF Increasing Enable | On | |
| <input type="radio"/> UF Increasing Start Point | 49.8 | [0.00,66.50]Hz |
| <input type="radio"/> Under-frequency loading slope | 50 | [20,400] |
| <input type="radio"/> Under-frequency loading delay time | 0.0 | [0.0,2.0]s |

Please Enter Password


10.8) Set underfrequency loading enable: you can set whether to allow the underfrequency loading function to be enabled.




10.9) Set the frequency rate of change enable.




10.10) Powering on/off the device: you can power on/off the device remotely.




10.11) Set the time: you can set the time for the device.




10.12) Setting the default working mode of the system: selecting the working mode according to the customer's needs, the working modes are Load Priority, Battery Priority, Grid Priority, Pure PV Energy Storage, Idle Grid Priority for Energy Storage, PTO, Grid Priority (ECO).




10.13) Setting the reactive power: The corresponding PF mode can be set.




10.14) Setting the network side meter enable: you can choose whether to enable the network side meter function or not.




10.15) AC charging: you can set whether to enable the mains charging function or not.




10.16) AC charge power: you can set the AC charge power.




10.17) AC discharging power: you can set the AC discharge power.




10.18) AC stop charging SOC: the battery charge cut-off SOC can be set (100 recommended).




10.19) Discharge stop SOC: you can set the battery discharge cut-off SOC (recommended 10), the discharge cut-off SOC is divided into grid-connected discharge stop SOC and off-grid discharge stop SOC.




10.20) Enable Battery: You can choose to enable or disable battery.




10.21) Battery Settings: Battery related parameters can be set, including battery capacity, maximum charging/ discharging power, maximum charging/ discharging current, maximum battery charging voltage, battery charging cut-off voltage, battery discharging cut-off voltage, off-grid cut-off voltage.




10.22) Mode switching: You can choose to switch the operating mode manually or automatically. In general, it is recommended that you select the "Auto" mode switch.




10.23) Setting off-grid enable: you can set whether or not the inverter operates in off-grid mode.




10.24) Off-grid voltage: 220V/230V can be set.




10.25) Off-grid frequency: two options: 50Hz/60Hz.




10.26) Anti-reverse flow settings: You can enable/disable the anti-reverse flow feature in accordance with applicable local regulations and set the anti-reverse flow power when the feature is enabled.




10.27) Set Parallel Enable: you can set whether to enable the parallel function or not.




10.28) Setting the working mode and time period




10.29) Disable/Enable Demand Management/Peak Shaving



10.30) GEN port access device type: can be set as generator/PV inverter/smart load.



10.31) Generator Enable: Option to enable or disable the GEN.



10.32) Tanker power: Tanker power can be set.

Setting

Microgrid system ▾

Device Type of GEN Port

Generator Enable

Rated power of oil engine [0.0~1000.0]kW

Electricity Meter 2 Enable

AC Couple Enable

SOC under secondary load [0, 100]%


Safety function control ▾

Register Value

Please Select

Start Address End Address

Please Enter Password



10.33) Enable/Disable Electricity Meter 2

Setting

Microgrid system ▾

Device Type of GEN Port

Generator Enable

Rated power of oil engine [0.0~1000.0]kW

Electricity Meter 2 Enable

AC Couple Enable

SOC under secondary load [0, 100]%


Safety function control ▾

Register Value


Please Select

Start Address End Address

Please Enter Password



10.34) AC Couple Enable: you can set whether to enable the AC Couple function.



Wattmeter

Enter the serial number of the meter or Datalogger to search for the desired meter. Once the search is complete, the type of meter, the model of the Datalogger working with the device, the status of the meter, and the serial number of the WIT inverter to which the meter is connected are displayed.

9 System Maintenance

9.1 Routine Maintenance

9.1.1 Clean the Chassis

| | |
|--|--|
|  DANGER | <ul style="list-style-type: none">• Before performing any operation, disconnect the AC and DC power supply and wait for 5 minutes after the system is powered off.• Wipe the dust off the chassis and clean the chassis with a moistened cloth. |
|--|--|

- 1) Check periodically that the humidity is within the acceptable range and keep it away from dust;
- 2) Check the ventilation and heat dissipation of the equipment regularly. For details, see Section 9.1.2.

9.1.2 Fan Maintenance

| | |
|---|---|
|  DANGER | <ul style="list-style-type: none">• Only qualified and trained electrical technicians are allowed to perform operations. Technicians must observe instructions in this manual and comply with local regulations.• Before performing any operation, disconnect all power supplies and wait for 5 minutes until the residual voltage is completely discharged. |
|  WARNING | <ul style="list-style-type: none">• Do not use the air pump to clean the fan. Otherwise, the fan may be damaged. |

Ventilation and heat dissipation is essential to protect the WIT Inverter from performance de-rate due to excess heat. The fan in the WIT Inverter works to cool the components and the heat sink when the temperature is too high. Check the following possible causes and measures when an exception occurs:

- 1> The fan is stuck with foreign objects or there is dust accumulation on the heat sink; clean the fan cover, fan blades and the heat sink.
- 2> The fan is damaged and needs to be replaced.
- 3> The installation position of the WIT Inverter is not well-ventilated. Select an appropriate installation position that meets the basic installation requirements.

Cleaning and replacing the fan:

- 1> Before cleaning or replacing a fan, disconnect the DC and AC power supply and wait for at least 5 minutes.
- 2> Remove the fan fixing plate using a cross-head screwdriver, as shown in Fig 9.1:




Fig 9.1




Fig 9.2 Position of the fan fixing plate

3> Disconnect the fan connector, remove the fan fixing plate with a screwdriver, and remove the fan.

4> Clean the fan cover, fan blades, and the heat sink, or replace the fan.

- (1) Use an air pump to clean the heat sink, and use a brush or wet cloth to clean the fan and its cover;
- (2) Remove the fan for cleaning if necessary;
- (3) Remove the fan that needs to be replaced using a cross-head screwdriver and install a new fan.
- (4) Bind the cables and fix them with a cabletie.
- (5) Reinstall the fan, the fan fixing plate, and the WIT inverter.

9.2 Troubleshooting

| | |
|--|--|
|  DANGER | <ul style="list-style-type: none">• It must be operated by trained and professional electrical technicians. Technicians must observe instructions in this manual and local regulations.• If the WIT Inverter reports the "PV Isolation low" alarm, do not touch the equipment as a ground fault might have occurred.• Beware of high voltages which can cause electric shocks. |
|--|--|

9.2.1 Warning

Warnings indicate abnormal situations of WIT 4-25K-XHU Hybrid Inverters, leading to a reduction in the output power. The warning sign will disappear once the fault is rectified by restarting the inverter or reconfiguring the system. The warning codes are shown in Table 9.1:

Table 9.1 Warning codes

| Warning | Description | Suggestion |
|----------------|--|--|
| Warning 200 | String fault | <ol style="list-style-type: none">1. Check if the PV panels are normal after shutdown.2. If the error message persists, contact Growatt support. |
| Warning 201 | PV string/PID quick-connect terminals abnormal | <ol style="list-style-type: none">1. Check the wiring of the string terminals after shutdown.2. If the error message persists, contact Growatt support. |
| DC SPD Warning | DC SPD function abnormal | <ol style="list-style-type: none">1. Check the DC SPD after shutdown.2. If the error message persists, contact Growatt support. |
| Warning 203 | PV1 or PV2 short circuited | <ol style="list-style-type: none">1. Check if PV1 or PV2 is short circuited.2. If the error message persists, contact Growatt support. |
| Boost Warning | PV Boost driver abnormal | <ol style="list-style-type: none">1. Restart the inverter.2. If the error message persists, contact Growatt support. |
| AC SPD Warning | AC SPD function abnormal | <ol style="list-style-type: none">1. Power off the system and check the fuse.2. If the fault persists, contact Growatt. |

| Warning | Description | Suggestion |
|-------------|---|--|
| Warning 209 | DC input voltage exceeds the upper threshold | 1. Turn off the DC switch immediately and check the DC voltage. 2. If the DC voltage is within the specified range and the error message persists, contact Growatt support. |
| PV Reversed | PV string is reversely connected | 1. Check the polarity of the PV terminals. 2. If the error message persists, contact Growatt support. |
| Warning 220 | PV string disconnected | 1. Check if the PV string is properly connected. 2. If the error message persists, contact Growatt support. |
| Warning 221 | PV string current unbalanced | 1. Check if the PV panels of the corresponding string are normal. 2. If the error message persists, contact Growatt support. |
| Warning 300 | No utility grid connected or utility grid power failure | 1. Check if the grid is down. 2. If the error message persists, contact Growatt support. |
| Warning 301 | Grid voltage is beyond the permissible range | 1. Check if the grid voltage is within the specified range. 2. If the error message persists, contact Growatt support. |
| Warning 302 | Grid frequency is beyond the permissible range | 1. Check if the grid frequency is within the specified range. 2. If the error message persists, contact Growatt support. |
| Warning 303 | Overload | 1. Please reduce the load connected to the EPS output terminal. 2. If the error message persists, contact Growatt support. |
| Warning 308 | Meter disconnected | 1. Check if the meter is properly connected. 2. If the error message persists, contact Growatt support. |

| Warning | Description | Suggestion |
|-------------|--|---|
| Warning 309 | Meter is reversely connected | 1. Check if the L line and the N line of the meter are reversely connected. 2. If the error message persists, contact Growatt support. |
| Warning 310 | The voltage difference between the N line and the PE cable is abnormal | 1. Check if the PE cable is reliably connected after shutdown. 2. If the error message persists, contact Growatt support. |
| Warning 311 | Phase sequence error | No operation is required. The PCS will automatically adjust the phase sequence. |
| Warning 400 | Fan failure | 1. Check if the fan is properly connected after shutdown. 2. If the error message persists, contact Growatt support. |
| Warning 401 | Meter abnormal | 1. Check if the meter is turned on. 2. If the meter is correctly connected to the inverter. |
| Warning 407 | Over-temperature | 1. Restart the inverter. 2. If the error message persists, contact Growatt support. |
| Warning 407 | overtemperature alarm | 1. Restart the inverter 2. If the fault message persists, contact the manufacturer |
| Warning 408 | NTC temperature sensor is broken | 1. Restart the inverter. 2. If the error message persists, contact Growatt support. |
| Warning 411 | Sync signal abnormal | 1. Check if the sync cable is abnormal. 2. If the error message persists, contact Growatt support. |

| Warning | Description | Suggestion |
|-------------|---|--|
| Warning 412 | Startup requirements of grid connection are not met | <ul style="list-style-type: none"> 1. Check if the grid voltage is within the specified range and check if the grid-connection startup voltage configuration is correct. 2. Check if the PV voltage is within the specified range. 3. Restart the inverter. If the error message persists, contact Growatt support. |
| Warning 500 | The inverter failed to communicate with the battery | <ul style="list-style-type: none"> 1. Check if the battery is turned on. 2. Check if the battery is correctly and securely connected to the inverter. |
| Warning 501 | Battery disconnected | <ul style="list-style-type: none"> 1. Check if the battery is properly connected. 2. If the error message persists, contact Growatt support. |
| Warning 502 | Battery voltage too high | <ul style="list-style-type: none"> 1. Check if the battery voltage is within the permissible range. 2. Check if the battery is correctly connected. 3. If the error message persists, contact Growatt support. |
| Warning 503 | Battery voltage too low | <ul style="list-style-type: none"> 1. Check if the battery voltage is within the permissible range. 2. Check if the battery is correctly connected. 3. If the error message persists, contact Growatt support. |
| Warning 504 | Battery terminals are reversely connected | <ul style="list-style-type: none"> 1. Check if the positive and negative terminals of the battery are reversely connected. 2. If the error message persists, contact Growatt support. |
| Warning 505 | Temperature sensor of the lead-acid battery is disconnected | <ul style="list-style-type: none"> 1. Check if the temperature sensor of the lead-acid battery is installed or not. 2. Check if the temperature sensor is well-connected. 3. If the error message persists, contact Growatt support. |

| Warning | Description | Suggestion |
|----------------|--|---|
| Warning 506 | Battery temperature is out of range | 1. Check if the ambient temperature of the battery is within the specified range. 2. If the error message persists, contact Growatt support. |
| Warning 507 | BMS reported a fault; both charging and discharging failed | 1. Figure out the cause according to the BMS error code. 2. If the error message persists, contact Growatt support. |
| Warning 508 | Lithium battery overload protection | 1. Check if the power of the load exceeds the BAT rated discharge power. 2. If the error message persists, contact Growatt support. |
| Warning 509 | BMS communication abnormal | 1. Restart the inverter. 2. If the error message persists, contact Growatt support. |
| Warning 510 | BAT SPD function abnormal | 1. Check the BAT SPD after powering off the device. 2. If the error message persists, contact Growatt support. |
| Warning 600 | Output DC component bias abnormality | 1. Restart the inverter 2. If the fault message persists, contact the manufacturer |
| Warning 601 | DC component over high in output voltage | 1. Restart the inverter. 2. If the error message persists, contact Growatt support. |
| Warning 602 | Off-grid output voltage too low | 1. Restart the inverter 2. If the fault message persists, contact the manufacturer |
| Warning 603 | Off-grid output voltage too high | 1. Restart the inverter 2. If the fault message persists, contact the manufacturer |
| Warning 604 | Off-grid output current overcurrent | 1. Detect whether the load is out of specification 2. Restart the inverter, if the fault message still exists, contact the manufacturer |

| Warning | Description | Suggestion |
|-------------|------------------------------|--|
| Warning 605 | Off-grid bus voltage too low | 1. Check if the load power exceeds the upper limit. 2. Restart the inverter. If the error message persists, contact Growatt support. |
| Warning 606 | Off-grid output overload | 1. Detect whether the load is out of specification 2. Restart the inverter, if the fault message still exists, contact the manufacturer |
| Warning 609 | Balanced circuit abnormal | 1. Restart the inverter. 2. If the error message persists, contact Growatt support. |

9.2.2 Error

The error code indicates that the device is damaged or the configurations are abnormal. Only qualified and trained electrical technicians are allowed to rectify the faults. The error message will disappear after the fault is rectified. If the problem persists, please contact Growatt.

Table 9.2 Error codes

| Error Code | Description | Suggestion |
|-----------------|---|--|
| AFCI Fault | An arc fault has been detected | 1. After shutdown, check the connection of the PV string. 2. Restart the inverter. 3. If the error message persists, please contact Growatt support. |
| GFCI High | An excessively high leakage current has been detected | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| PV Voltage High | DC input voltage exceeds the upper threshold | 1. Disconnect the DC switch immediately and check the voltage. 2. If the DC input voltage is within the permissible range and the error message persists, please contact Growatt support. |

| Error Code | Description | Suggestion |
|------------------|--|---|
| PV Isolation Low | PV panels have low insulation resistance | 1. Check if the PV strings are properly grounded. 2. If the error message persists, please contact Growatt support. |
| PV Reversed | PV string reversely connected | 1. After shutdown, check if the PV string is reversely connected to the inverter. 2. Restart the inverter. 3. If the error message persists, please contact Growatt support. |
| AC V Outrange | Grid voltage is beyond the permissible range | 1. Check the grid voltage. 2. If the grid voltage is within the permissible range and the error message persists, please contact Growatt support. |
| No AC | No utility grid connected or utility grid power failure | 1. After shutdown, check the AC wiring. 2. If the error message persists, please contact Growatt support. |
| PE Abnormal | The voltage difference between the N line and the PE cable is abnormal | 1. After shutdown, check if the ground cable is reliably connected. 2. If the error message persists, please contact Growatt support. |
| AC F Outrange | Grid frequency is beyond the permissible range | 1. Check the grid frequency and restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 309 | Grid ROCOF (Rated of Change of Frequency) abnormal | 1. Check the grid frequency and restart the inverter. 2. If the error message persists, please contact Growatt support. |
| NE Fault | Neutral-to-Ground voltage is too low | 1. Check whether the N line on the inverter side with PV negative grounding is short-circuited with the ground cable and whether the output side is isolated with a transformer. 2. If the error message persists, please contact Growatt support. |
| Error 311 | Export limitation fail-safe | 1. After shutdown, check the connection of the CT and the meter. 2. If the error message persists, please contact Growatt support. |

| Error Code | Description | Suggestion |
|------------|-------------------------------------|--|
| Error 400 | DCI bias abnormal | 1. Restart the inverter. 2. If the error message persists, contact Growatt support. |
| Error 402 | High DC component in output current | 1. Restart the inverter. 2. If the error message persists, contact Growatt support. |
| Error 404 | Bus voltage sampling abnormal | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 405 | Relay fault | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 408 | Over-temperature | 1. After shutdown, check the temperature of the inverter and restart the inverter after the temperature is within the acceptable range. 2. If the error message persists, please contact Growatt support. |
| Error 409 | Bus voltage abnormal | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 411 | Internal communication failure | 1. Check the wiring of the communication board after shutdown. 2. If the error message persists, please contact Growatt support. |
| Error 412 | Temperature sensor disconnected | 1. Check the wiring of the communication board after shutdown. 2. If the error message persists, please contact Growatt support. |
| Error 413 | IGBT drive fault | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 414 | EEPROM error | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 415 | Auxiliary power supply abnormal | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 416 | DC/AC overcurrent protection | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |

| Error Code | Description | Suggestion |
|------------|--|---|
| Error 417 | Communication protocol mismatch | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 418 | DSP and COM firmware version mismatch | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 419 | DSP software and hardware version mismatch | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 421 | CPLD abnormal | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 422 | Redundancy sampling inconsistent | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support |
| Error 423 | PWM pass-through signal failure | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 425 | AFCI self-test failure | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 426 | PV current sampling abnormal | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 427 | AC current sampling abnormal | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 429 | BUS softboot failure | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 430 | EPO fault | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 431 | Monitoring chip BOOT verification failed | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |

| Error Code | Description | Suggestion |
|-----------------|--|--|
| Error 500 | BMS failed to communicate with the inverter | <ol style="list-style-type: none"> 1. Check the connection of the RS485 cable between the inverter and the battery. 2. Check if the battery is in the sleep mode. 3. If the error message persists, please contact Growatt support. |
| Error 501 | The BMS reports that the battery failed to charge/discharge | <ol style="list-style-type: none"> 1. Figure out the fault based on the BMS error code. 2. If the error message persists, please contact Growatt support. |
| Bat Voltage Low | The battery voltage is below the lower threshold | <ol style="list-style-type: none"> 1. Check the battery voltage. 2. If the error message persists, please contact Growatt support. |
| Error 503 | The battery voltage exceeds upper threshold | <ol style="list-style-type: none"> 1. Check the battery voltage. If it is within the permissible range, please restart the inverter. If not, please replace the battery. 2. If the error message persists, please contact Growatt support. |
| Error 504 | The battery temperature is beyond the range for charging / discharging | <ol style="list-style-type: none"> 1. Check the temperature of the battery. 2. If the error message persists, please contact Growatt support. |
| Bat Reversed | Battery terminals reversed | <ol style="list-style-type: none"> 1. Check if the battery terminals are reversely connected. 2. If the error message persists, please contact Growatt support. |
| Error 506 | Battery open-circuited | <ol style="list-style-type: none"> 1. Check the wiring of the battery terminals. 2. If the error message persists, please contact Growatt support. |
| Error 507 | Battery overload protection | <ol style="list-style-type: none"> 1. Check if the power of the load exceeds the battery rated discharge power. 2. If the error message persists, please contact Growatt support. |
| Error 508 | BUS2 Volt Abnormal | <ol style="list-style-type: none"> 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |

| Error Code | Description | Suggestion |
|------------------|---|--|
| Error 509 | BAT Charge OCP (Overcurrent Protection) | 1. Check if the PV voltage is oversized. 2. If the error message persists, please contact Growatt support. |
| Error 510 | BAT Discharge OCP (Overcurrent Protection) | 1. Check if the battery discharge current configuration is proper. 2. If the error message persists, please contact Growatt support. |
| Error 511 | BAT soft start failed | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| EPS Output Short | Off-grid output short-circuited | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 601 | Off-grid BUS Volt Low | 1. Check if the battery is working properly or the battery experiences capacity loss. 2. If the error message persists, please contact Growatt support. |
| Error 602 | Abnormal Volt at the off-grid terminal | 1. Check if a voltage is present at the AC port. 2. If the error message persists, please contact Growatt support. |
| Error 603 | Soft start failed | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 604 | Off-grid output voltage abnormal | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 605 | Balanced circuit self-test failed | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 606 | High DC component in output voltage | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| OverLoad | Off-grid output overload | 1. Restart the inverter. 2. If the error message persists, please contact Growatt support. |
| Error 608 | Off-grid parallel signal abnormal | 1. Check if the communication cables are properly connected. 2. If the error message persists, please contact Growatt support. |

Product Specifications 10

Table 10.1 WIT 4/5/6/8/10K-XHU Specifications

| Specifications \ Model | WIT 4K-XHU | WIT 5K-XHU | WIT 6K-XHU | WIT 8K-XHU | WIT 10K-XHU | | | |
|--|--|------------------|--------------------|--------------------|-----------------|--|--|--|
| Input data(PV) | | | | | | | | |
| Max. recommended PV power(for module STC) | 8kW | 10kW | 12kW | 16kW | 20kW | | | |
| Max. DC voltage | 1000V | | | | | | | |
| Start voltage | 160V | | | | | | | |
| Nominal voltage | 620V | | | | | | | |
| MPP voltage range | 150V-850V | | | | | | | |
| Full Load DC Voltage Range | 200V-850V | 250V-850V | 300V-850V | 400V-850V | 500V-850V | | | |
| No. of MPP trackers | 1 | | 2 | | | | | |
| No. of PV strings per MPP tracker | 2 | | 1 | | | | | |
| Max. input current per MPP tracker | 40A | | | | | | | |
| Max. short-circuit current per MPP tracker | 50A | | | | | | | |
| Battery data (DC) | | | | | | | | |
| Battery voltage range | 120-800V | | | | | | | |
| Full load battery voltage range | 455V-800V | | | | | | | |
| Recommended battery voltage | 512V | | | | | | | |
| No. of battery input | 1 (Can parallel 2 channels) | | | | | | | |
| Max. charging / discharging current | 55A | | | | | | | |
| BMS communication | RS485/CAN | | | | | | | |
| AC Input/Output (GRID) | | | | | | | | |
| AC input/output nominal power | 8kW/ 4kW | 10kW/ 5kW | 12kW/ 6kW | 16kW/ 8kW | 20kW/ 10kW | | | |
| Max. AC input/output apparent power | 8.8kVA/ 4.4kVA | 11kVA/ 5.5kVA | 13.2kVA/ 6.6kVA | 17.6kVA/ 8.8kVA | 22kVA/ 11kVA | | | |
| Nominal AC voltage/range | 220V/230V/240V L-N, 380V/400V/415V L-L, -15% ~ 10% | | | | | | | |

| Model Specifications | WIT 4K-XHU | WIT 5K-XHU | WIT 6K-XHU | WIT 8K-XHU | WIT 10K-XHU |
|-----------------------------------|--|--------------------------|--------------------------|----------------------------|----------------------------|
| Nominal AC grid frequency/range | 45~55 Hz/55~65 Hz | | | | |
| Max. input/output current | 13.33A/ 6.67A@ 220V | 16.66A/ 8.3A@ 220V | 20.0A/ 10.0A@ 220V | 26.67A/ 13.33A@ 220V | 33.33A/ 16.67A@ 220V |
| Power factor (@nominal power) | >0.99 | | | | |
| Adjustable power factor | -1...+1 | | | | |
| THDi | <3 | | | | |
| AC grid connection type | 3P3W+PE/3P4W+PE | | | | |
| Input/Output Generator (GEN) | | | | | |
| AC nominal power | 8kW | 10kW | 12kW | 16kW | 20kW |
| Max. input current(GEN/AC Couple) | 12.12A/ 6.06A | 15.15A/ 7.57A | 18.18A/ 9.09A | 24.24A/ 12.12A | 30.30A/ 15.15A |
| Nominal AC voltage | 220V/230V/240V L-N,380V/400V/415V L-L | | | | |
| Nominal AC grid frequency | 50Hz/60Hz | | | | |
| AC connection type | 3P3W+PE/3P4W+PE | | | | |
| Stand alone(Back up) | | | | | |
| AC nominal output power | 4kW | 5kW | 6kW | 8kW | 10kW |
| Max. AC apparent power | 4kVA | 7.5kVA | 9kVA | 12kVA | 15kVA |
| Nominal AC voltage | 220V/230V/240V (L-N) 380V/400V/415V (L-L) | | | | |
| Nominal AC frequency | 50/60HZ | | | | |
| Max. output current | 12.12A | 15.15A | 18.18A | 24.24A | 30.30A |
| Overload Capability | 2x rated power, 10 S | | | | |
| THDv | <3% (Linear full load) | | | | |
| Switch time* | \leq 10ms | | | | |
| Efficiency | | | | | |
| Max. efficiency | 98.10% | | | | |

| Model Specifications | WIT 4K-XHU | WIT 5K-XHU | WIT 6K-XHU | WIT 8K-XHU | WIT 10K-XHU |
|----------------------------------|-------------------------------|---------------|---------------|---------------|----------------|
| European efficiency | 97.2% | | | | |
| MPPT efficiency | 99.90 % | | | | |
| Protection devices | | | | | |
| DC reverse polarity protection | adjuvant | | | | |
| Battery reverse protection | adjuvant | | | | |
| Insulation resistance monitoring | adjuvant | | | | |
| AC/DC surge protection | Type II | | | | |
| AC short-circuit protection | adjuvant | | | | |
| Ground fault monitoring | adjuvant | | | | |
| Grid monitoring | adjuvant | | | | |
| String monitoring | adjuvant | | | | |
| Anti-islanding protection | adjuvant | | | | |
| Residual-current monitoring unit | adjuvant | | | | |
| AFCI protection | selectable | | | | |
| General data | | | | | |
| Dimensions (W / H / D) | 687/465/241mm | | | | |
| Weight | 42kg | | | | |
| Operating temperature range | -30°C - 60°C (>45°C, derated) | | | | |
| Noise emission (typical) | ≤55dB | | | | |
| Altitude | 4000m | | | | |
| Topology | Transformerless | | | | |
| Cooling | Smart air cooling | | | | |
| Protection degree | IP66 | | | | |
| Relative humidity | 0~100% | | | | |
| PV connection | MC2 | | | | |

| Model | WIT 4K-XHU | WIT 5K-XHU | WIT 6K-XHU | WIT 8K-XHU | WIT 10K-XHU |
|-----------------------------------|---|-----------------------|-----------------------|-----------------------|------------------------|
| AC connection | Cable glands +terminals | | | | |
| Battery connection | Quick connect plug | | | | |
| Interfaces | | | | | |
| Display | OLED+LED/APP | | | | |
| RS485/CAN/USB | RS485/CAN/USB | | | | |
| WIFI/4G/LAN | WIFI/LAN | | | | |
| Warranty: 5 / 10 years | Yes/Opt. | | | | |
| Certificates and approvals | | | | | |
| Grid regulation | EN 50549, VDE 4105 | | | | |
| EMC | IEC/EN61000-6-1, IEC/EN61000-6-3 | | | | |
| Safety | IEC/EN62109-1, IEC/EN62109-2, IEC/EN62477-1 | | | | |

Table 10.2 WIT 12/15/17/20/25K-XHU Specifications

| Model Specifications | WIT 12K-XHU | WIT 15K-XHU | WIT 17K-XHU | WIT 20K-XHU | WIT 25K-XHU | | | |
|--|---|-------------------|---------------------|-----------------|-------------------|--|--|--|
| Input data(PV) | | | | | | | | |
| Max. recommended PV power(for module STC) | 24kW | 30kW | 34kW | 40kW | 50kW | | | |
| Max. DC voltage | 1000V | | | | | | | |
| Start voltage | 160V | | | | | | | |
| Nominal voltage | 620V | | | | | | | |
| MPP voltage range | 150V-850V | | | | | | | |
| Full Load DC Voltage Range | 400V-850V | 500V-850V | 425V-850V | 500V-850V | 620V-850V | | | |
| No. of MPP trackers | 2 | | 2 | | | | | |
| No. of PV strings per MPP tracker | 2+1 | | 1 | | | | | |
| Max. input current per MPP tracker | 40A | | | | | | | |
| Max. short-circuit current per MPP tracker | 50A | | | | | | | |
| Battery data (DC) | | | | | | | | |
| Battery voltage range | 120-800V | | | | | | | |
| Full load battery voltage range | 455V-800V | | | | | | | |
| Recommended battery voltage | 512V | | | | | | | |
| No. of battery input | 1 | | | | | | | |
| Max. charging / discharging current | 55A | | | | | | | |
| BMS communication | RS485/CAN | | | | | | | |
| AC Input/Output (GRID) | | | | | | | | |
| AC input/output nominal power | 24kW/ 12kW | 30kW/ 15kW | 34kW/ 17kW | 40kW/ 20kW | 50kW/ 25kW | | | |
| Max. AC input/output apparent power | 26.4kVA /13.2kVA | 33kVA /16.5kVA | 37.4kVA/ 18.7kVA | 44kVA/ 22kVA | 55kVA/ 2.75kVA | | | |
| Nominal AC voltage/range | 220V/230V/240V L-N,380V/400V/415V L-L, -15% ~ 10% | | | | | | | |
| Nominal AC grid frequency/range | 45~55 Hz/55~65 Hz | | | | | | | |

| Model Specifications | WIT 12K-XHU | WIT 15K-XHU | WIT 17K-XHU | WIT 20K-XHU | WIT 25K-XHU |
|-----------------------------------|--|----------------|-------------------|----------------------|----------------------|
| Max. input/output current | 40A/20A @220V | 50A/25A @220V | 56.67A/ 20A @220V | 66.67A/ 33.33A @220V | 83.33A/ 41.67A @220V |
| Power factor (@nominal power) | >0.99 | | | | |
| Adjustable power factor | -1...+1 | | | | |
| THDi | <3 | | | | |
| AC grid connection type | 3P3W+PE/3P4W+PE | | | | |
| Input/Output Generator (GEN) | | | | | |
| AC nominal power | 24kW | 30kW | 34kW | 40kW | 50kW |
| Max. input current(GEN/AC Couple) | 36.36A/ 18.18A | 45.45A/ 22.77A | 51.51A/ 25.75A | 60.61A/ 30.3A | 75.76A/ 37.88A |
| Nominal AC voltage | 220V/230V/240V L-N,380V/400V/415V L-L | | | | |
| Nominal AC grid frequency | 50Hz/60Hz | | | | |
| AC connection type | 3P3W+PE/3P4W+PE | | | | |
| Stand alone(Back up) | | | | | |
| AC nominal output power | 12kW | 15kW | 17kW | 20kW | 25kW |
| Max. AC apparent power | 12kVA | 15kVA | 17kVA | 20kVA | 25kVA |
| Nominal AC voltage | 220V/230V/240V (L-N) 380V/400V/415V (L-L) | | | | |
| Nominal AC frequency | 50/60HZ | | | | |
| Max. output current | 36.36A | 45.45A | 54.55A | 60.61A | 75.76A |
| Overload Capability | 2x rated power, 10 S | | | | |
| THDv | <3% (Linear full load) | | | | |
| Switch time* | ≤10ms | | | | |
| Efficiency | | | | | |
| Max. efficiency | 98.10% | | | | |
| European efficiency | 97.2% | | | | |
| MPPT efficiency | 99.90 % | | | | |

| Model Specifications | WIT 12K-XHU | WIT 15K-XHU | WIT 17K-XHU | WIT 20K-XHU | WIT 25K-XHU |
|----------------------------------|-------------------------------|----------------|----------------|----------------|----------------|
| Protection devices | | | | | |
| DC reverse polarity protection | adjuvant | | | | |
| Battery reverse protection | adjuvant | | | | |
| Insulation resistance monitoring | adjuvant | | | | |
| AC/DC surge protection | Type II | | | | |
| AC short-circuit protection | adjuvant | | | | |
| Ground fault monitoring | adjuvant | | | | |
| Grid monitoring | adjuvant | | | | |
| String monitoring | adjuvant | | | | |
| Anti-islanding protection | adjuvant | | | | |
| Residual-current monitoring unit | adjuvant | | | | |
| AFCI protection | selectable | | | | |
| General data | | | | | |
| Dimensions (W / H / D) | 687/465/241mm | | | | |
| Weight | 42kg | | | | |
| Operating temperature range | -30°C - 60°C (>45°C, derated) | | | | |
| Noise emission (typical) | ≤55dB | | | | |
| Altitude | 4000m | | | | |
| Topology | Transformerless | | | | |
| Cooling | Smart air cooling | | | | |
| Protection degree | IP66 | | | | |
| Relative humidity | 0~100% | | | | |
| PV connection | MC2 | | | | |
| AC connection | Cable glands +terminals | | | | |
| Battery connection | Quick connect plug | | | | |

| Model | WIT 12K-XHU | WIT 15K-XHU | WIT 17K-XHU | WIT 20K-XHU | WIT 25K-XHU |
|----------------------------|---|----------------|----------------|----------------|----------------|
| Specifications | | | | | |
| Interfaces | | | | | |
| Display | OLED+LED/APP | | | | |
| RS485/CAN/USB | RS485/CAN/USB | | | | |
| WIFI/4G/LAN | WIFI/LAN | | | | |
| Warranty: 5 / 10 years | Yes/Opt. | | | | |
| Certificates and approvals | | | | | |
| Grid regulation | EN 50549, VDE 4105 | | | | |
| EMC | IEC/EN61000-6-1, IEC/EN61000-6-3 | | | | |
| Safety | IEC/EN62109-1, IEC/EN62109-2, IEC/EN62477-1 | | | | |

*After enabling high/low voltage ride-through function, the switching time between on-grid and off-grid modes will increase, which may lead to load power loss during abnormal grid conditions.

Decommissioning the WIT 11 Inverter

Handle the WIT Inverter that will not be operated in the future properly.

- 1> Disconnect the external AC circuit breaker and prevent accidental reconnection due to improper operation.
- 2> Set the DC switches to the OFF position.
- 3> Disconnect the upstream battery circuit breaker..
- 4> Wait at least 5 minutes before performing operations on it..
- 5> Disconnect the AC output power cables.
- 6> Disconnect the DC input power cables.
- 7> Remove the inverter from the bracket.
- 8> Dispose of the inverter according to local disposal rules.

12 Warranty

Growatt guarantees maintenance and replacement of the defective product under warranty.

12.1 Conditions

1. Growatt will ask users to provide product information by filling a form before making warranty repairs, including the date of purchase and installation, the serial number of the WIT Inverter, fault description and other information.
2. The defected product shall be returned to Growatt for recycling and disposal.

12.2 Disclaimer

Growatt shall not be liable for any consequences of the following circumstances:

1. Unauthorized removal of the product, such as removing the tamper-proof label and the upper cover of the WIT Inverter.
 2. Damage caused during transportation.
 3. Improper operations during installation and commissioning.
 4. Failure to observe the operation instructions regarding the installation, operation and storage of the WIT Inverter.
 5. Unauthorized modifications or improper maintenance on the WIT Inverter.
 6. Improper use and operation.
 7. Damage caused by storage conditions that do not meet the requirements specified in this manual.
 8. Failure to follow the safety precautions and applicable laws and regulations due to customer's negligence.
 9. Damage due to force majeure, such as lightning, floods, storms, fire.
 10. Power off the PCS before upgrading the firmware; otherwise it will shut down automatically during the upgrade process and supply no power to the loads.
- In the event of a product malfunction or failure caused by the circumstance mentioned above, Growatt can provide paid maintenance services after conducting a fault diagnosis if required.

Contact Us 13

If you have technical problems with our products, please contact Growatt for technical support. To provide you with the necessary assistance, please have the following information ready:

1. Model number of the WIT Inverter
2. Serial number of the WIT Inverte
3. Error code of the WIT Inverter
4. Information indicated on the LED display
5. DC input voltage and AC output voltage of the WIT Inverter
6. Communication method of the WIT Inverter

Shenzhen Growatt New Energy Co., Ltd.

4-13/F, Building A, Sino-German (Europe) Industrial Park,
Hangcheng Blvd, Bao'an District, Shenzhen, China

E service@growatt.com

W en.growatt.com

For local customer support, please visit <https://en.growatt.com/support/contact>



Download
Manual



Growatt New Energy

Shenzhen Growatt New Energy Co., Ltd.

4-13/F, Building A, Sino-German (Europe) Industrial Park,
Hangcheng Blvd, Bao'an District, Shenzhen, China

E service@growatt.com

W en.growatt.com

For local customer support, please visit <https://en.growatt.com/support/contact>

GR-UM-514-A-00 (PN: 044.0151400)