

```
=====
Line Sizing Problem                This information is confidential, and shall
                                   not be reproduced by any means without the
                                   written permission of Viraj Desai.
                                   Page: 1
                                   Proj: 121
                                   By  : VD
                                   Chkd/Apvd: /
CASE 1 NORMAL                      GENERAL                      Date: 30-09-2022
=====
```

FILE NAME : D:\08 Linked In\02 DWSim\00 Plan Personal\24 Line Hydraulics\24 Line Hydraulic.kdf

DEFAULTS : Fitting method = Crane
fT based on steel = Yes
Compressible = Isothermal
Two phase flow = Homogeneous
Acceleration = Homogeneous
Elevation den = Flanigan
Dukler hold-up = Hughmark
Smooth pipe f = No
Sonic velocity = HEMOmega
Two phase orifice = Homogeneous
Two phase valve = Homogeneous
Atmospheric pres = 1.0133 bar abs

VIEW/PRINT SETTINGS:

Font = Courier, Size 7-8
Orientation = Landscape
Margins = 1-2 cm.

RUN MESSAGE: Case 1 Hydraulic solution reached after 2 iterations.

NOTES:

- 1) Close this report before running/viewing next results.
- 2) Report is not automatically saved or printed.
Save the report as rtf file from the Korf menu (Hydraulics | Results | Save Report) or editor menu (File | Save As for MS Word).
After the final run, print the saved report with an editor (MS Word, etc.) for quality assurance purposes.

Line Sizing Problem

This information is confidential, and shall
not be reproduced by any means without the
written permission of Viraj Desai.

Page: 2
Proj: 121
By : VD
Chkd/Apvd: /
Date: 30-09-2022

CASE 1 NORMAL

PRESSURE PROFILE REPORT

Circuit Feed 1

Number	Description	Flow kg/h	Density kg/m3	Visc cP	Dia in	Sch	Length m	dP/L kPa/100m	Velocity m/s	Elev m	dPElev bar	dPin-out bar	Pin barg	Pout barg
F1	Feed									0	0	0	2.00	2.00
L1	Pipe	3,600	997	0.89	4	40	575	0.212	0.122		1.47	1.48	2.00	0.5224
TK1	Product									15	0	0	0.5224	0.5224

NOTES - (1) dPElev and dPin-out represent DRAWING Inlet - Outlet.
(2) dPin-out = dPElev + dPfrictional + dPaccel
(3) Vessel/Tank dPElev represent effect of fluid levels inside vessel.
(4) Elev represent equipment or nozzle (vessel/tank) elevation.

Line Sizing Problem

This information is confidential, and shall
not be reproduced by any means without the
written permission of Viraj Desai.

Page: 3
Proj: 121
By : VD
Chkd/Apvd: /
Date: 30-09-2022

CASE 1 NORMAL

PIPE LINE REPORT

Line number		L1		
Line name		Pipe		
PROCESS DATA				
Temperature	C	AVG	IN	OUT
Pressure	barg	25.0	25.0	25.0
Liq Fraction	wt	1.261	2.00	0.5224
Total-Flow	kg/h	1.0	1.0	1.0
Dens-NS	kg/m3	3,600		
Elev	kg/m3	997	997	997
Visc-NS	cP	997		
Vapor-Flow	kg/h	0.89		
Density	kg/m3	0		
Visc	cP	0	0	0
Mol wt		0	0	0
Z		0	0	0
Cp/Cv		0	0	0
Liquid-Flow (wt)	kg/h	0		
Flow (vol)	m3/h	3,600		
Density	kg/m3	3.61		
Visc	cP	997	997	997
		0.89	0.89	0.89
PIPE DATA				
Material		Steel		
Size	in	4		
Length	m	575		
Schedule		40		
ID Flow/Hydr	m	0.102	/ 0.102	
Roughness (E-3)	m	0.0457		
Safety factor		1.0		
Sum of elev's	m	0		
VELOCITY				
Velocity	m/s	0.122	0.122	0.122
Sonic (Vap)	m/s	5,000		
PRESSURE DROP (In-Out)				
Overall	bar	1.478		
Friction	bar	0.01226		
Accel'n	bar	0		
Static	bar	1.465		
dP/Length	kPa/100m	0.212		
LINE SIZING				
dP/Length	kPa/100m	MAX/LARGER	MIN/SMALLER	
Velocity	m/s	22.6		
VelCoef	m/s	100	0.30	
Size-Larger/Small	in	3.8	0.317	
dP/Length	kPa/100m	6	3	
Velocity	m/s	0.0299	0.781	
		0.0538	0.21	

Line Sizing Problem

This information is confidential, and shall
not be reproduced by any means without the
written permission of Viraj Desai.

Page: 4
Proj: 121
By : VD
Chkd/Apvd: /
Date: 30-09-2022

CASE 1 NORMAL

PIPE LINE REPORT

```
-----  
Line number      | L1  
Line name        | Pipe  
-----  
LIQUID HOLDUP    |  
  Liquid Fraction (vol) | 1.0  
  Liquid Holdup(dP) (vol) | 1.0  
2-PHASE METHOD    | Homogeneous  
FLOW REGIME      |  
  Horizontal (Mandane) | -  
  Horizontal (Dukler)  | -  
  Vertical Up (Fair)   | -  
  Vertical Up (Dukler) | -  
  Vertical Down (Golan) | -  
HOMOGENEOUS/DUKLER/BEGGS |  
  Reynolds No         | 13,990  
  Friction factor      | 0.0291  
  Friction factor (turb) | 0.01627  
  ftp/fns             | 0  
  Dentp/Denns         | 0  
LOCKHART-M/CHENOWETH-M |  
  Liquid-Re           | 0  
    f                 | 0  
    Psi/Psi^2         | 0  
  Vapor-Re            | 0  
    f                 | 0  
    Psi^2             | 0  
  X factor            | 0  
FITTINGS          | TYPE      No   L/D   K  
  Entrance          | 0         0     0    0.50  
  Exit              | 0         0     0    1.0  
  Gate valve        | 0         8.0   0  
  Globe valv        | 0        340   0  
  Check             | 0        50.0  0  
  Stop-check        | 0        400   0  
  Elbow             | 4        20.0  0  
  180 Bend          | 0        50.0  0  
  T-Straight        | 0        20.0  0  
  T-Branch          | 0        60.0  0  
  Other             | 1         0     0  
Fitting K          | 0  
Fitting L/D        | 80.0  
Total Eq Length    m | 579.6
```

NOTES - (1) dPoverall = dPfrictional + dPaccel + dPstatic
(2) NS = No slip or homogenous

```

=====
Line Sizing Problem          This information is confidential, and shall          Page: 5
                             not be reproduced by any means without the      Proj: 121
                             written permission of Viraj Desai.              By   : VD
                                           Chkd/Apvd: /
CASE 1 NORMAL                FEED SUMMARY                                Date: 30-09-2022
=====

```

Number	Description	Elevation m	Density kg/m3	Level m	Rel Elev m	dP loss bar	dP level bar	dP inlet bar	dP total bar	Pres barg
F1	Feed	0	997	0	0	0	0	0	0	2.0

NOTES - (1) dP Inlet for Feed, Products and Vessels represent pressure to velocity conversion only, not friction.

```

=====
Line Sizing Problem                This information is confidential, and shall
                                   not be reproduced by any means without the
                                   written permission of Viraj Desai.
                                   Page: 6
                                   Proj: 121
                                   By  : VD
                                   Chkd/Apvd: /
CASE 1 NORMAL                     PRODUCT SUMMARY
                                   Date: 30-09-2022
=====

```

Number	Description	Elevation m	Density kg/m3	Level m	Rel Elev m	dP loss bar	dP level bar	dP inlet bar	dP total bar	Pres barg
TK1	Product	15.0	997	0	0	0	0	0	0	0.522

NOTES - (1) dP Inlet for Feed, Products and Vessels represent pressure to velocity conversion only, not friction.

```
=====
Line Sizing Problem          This information is confidential, and shall
                             not be reproduced by any means without the
                             written permission of Viraj Desai.
                             Page: 7
                             Proj: 121
                             By  : VD
                             Chkd/Apvd: /
CASE 1 NORMAL                WARNINGS & ERRORS
                             Date: 30-09-2022
=====
```

Warning! Line L1 velocity coef less than minimum (m/s) = 0.3167

End of file