Devices

ID	Name	Protocol	Status	Latency MS	Auto Reconnect	Unit ID	Port	Gateway ID	Last Error	Params JSON
1	MFM 20	modbus	reconnecting	0.0	1	21	502	gw_1771075949405	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:21"}
2	Lighting	modbus	connected	21.0	1	9	502	gw_1771158928169		{}
3	MFM 10	modbus	reconnecting	0.0	1	11	502	gw_1771051169012	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:11"}
4	Nexsine Production	modbus	reconnecting	0.0	1	4	502	gw_1771148626826	TCP_CONNECT_FAILED	{}
5	MFM 3	modbus	reconnecting	0.0	1	4	502	gw_1771051169012	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:04"}
6	MFM 11	modbus	reconnecting	0.0	1	12	502	gw_1771051169012	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:12"}
7	PLC 1	modbus	reconnecting	0.0	1	1	502	gw_1771051169005	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:01"}
8	MFM 4	modbus	reconnecting	0.0	1	5	502	gw_1771051169012	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:05"}
9	Nexsine Incomer	modbus	connected	16.0	1	11	502	gw_1771158928169		{}
10	MFM 12	modbus	reconnecting	0.0	1	13	502	gw_1771051169012	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:13"}
11	Modbus Device TEST	modbus	connected	16.0	1	1	5020	gw_1771012391581		{}
12	Server 1	opcua	reconnecting	0.0	1	0	4840	gw_1771004131086	[Errno -2] Name or	{}

ID	Name	Protocol	Status	Latency MS	Auto Reconnect	Unit ID	Port	Gateway ID	Last Error	Params JSON
									service not known	
13	MFM 5	modbus	reconnecting	0.0	1	6	502	gw_1771051169012	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:06"}
14	MFM 13	modbus	reconnecting	0.0	1	14	502	gw_1771051169012	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:14"}
15	MFM 17	modbus	reconnecting	0.0	1	18	502	gw_1771051169012	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:18"}
16	SN Production	modbus	reconnecting	0.0	1	6	502	gw_1771148626826	TCP_CONNECT_FAILED	{}
17	MFM 6	modbus	reconnecting	0.0	1	7	502	gw_1771051169012	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:07"}
18	Device 1	modbus	connected	38.0	1	1	5020	gw_1771148626826		{}
19	MFM 14	modbus	reconnecting	0.0	1	15	502	gw_1771051169012	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:15"}
20	SN Incomer	modbus	connected	33.0	1	12	502	gw_1771158928169		{}
21	MFM 18	modbus	reconnecting	0.0	1	19	502	gw_1771051169012	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:19"}
22	MFM 7	modbus	reconnecting	0.0	1	8	502	gw_1771051169012	TCP_CONNECT_FAILED	{"mac": "AA:BB:CC:DD:EE:08"}
23	Spare	modbus	reconnecting	0.0	1	5	502	gw_1771148626826	TCP_CONNECT_FAILED	{}

ID	Name	Protocol	Status	Latency MS	Auto Reconnect	Unit ID	Port	Gateway ID	Last Error	Params JSON
24	MFM 15	modbus	reconnecting	0.0	1	16	502	gw_17710511 69012	TCP_CONNE CT_FAILED	{"mac": "AA:BB:CC:D D:EE:16"}
25	MFM 19	modbus	reconnecting	0.0	1	20	502	gw_17710511 69012	TCP_CONNE CT_FAILED	{"mac": "AA:BB:CC:D D:EE:20"}
26	MFM 8	modbus	reconnecting	0.0	1	9	502	gw_17710511 69012	TCP_CONNE CT_FAILED	{"mac": "AA:BB:CC:D D:EE:09"}
27	APFC Incomer	modbus	reconnecting	0.0	1	2	502	gw_17711486 26826	TCP_CONNE CT_FAILED	{}
28	MFM 16	modbus	reconnecting	0.0	1	17	502	gw_17710511 69012		{"mac": "AA:BB:CC:D D:EE:17"}
29	MFM 2	modbus	reconnecting	0.0	1	3	502	gw_17710511 69012	TCP_CONNE CT_FAILED	{"mac": "AA:BB:CC:D D:EE:03"}
30	MFM 9	modbus	reconnecting	0.0	1	10	502	gw_17710511 69012	TCP_CONNE CT_FAILED	{"mac": "AA:BB:CC:D D:EE:10"}
31	Busduct Testing Machine	modbus	reconnecting	0.0	1	2	502	gw_17711486 26826	TCP_CONNE CT_FAILED	{}
32	MFM 1	modbus	reconnecting	0.0	1	2	502	gw_17710511 69012	TCP_CONNE CT_FAILED	{"mac": "AA:BB:CC:D D:EE:02"}