

Caseld: 202045085

Employer: Woodgrove bank

Location: Los Angeles

Event Date: 6/13/2017

Event: Struck by object falling from vehicle or machinery-other than vehicle part

Nature: Cuts, lacerations

Final Narrative	Hospitalized	Amputation	Part Of Body	Source
On June 13, 2017, an employee was performing preventive maintenance on an HVAC unit. The employee had loosened the screws from the access panel cover to the air handler and began to wiggle the panel in an attempt to lift it. The cover gave way and struck the employee's left arm, severely lacerating it.	1	0	Arm(s), unspecified	Caps, lids, covers, n.e.c.