

Frozen-controller transfer verdict and m_s^{RL}/τ

	none	partial	full
hydronic heat pump	FAIL $m_s/\tau = 1.15$	FAIL $m_s/\tau = 1.15$	FAIL $m_s/\tau = 1.15$
hydronic	FAIL $m_s/\tau = 1.04$	FAIL $m_s/\tau = 1.04$	FAIL $m_s/\tau = 1.04$
commercial	COND PASS $m_s/\tau = 0.55$	COND PASS $m_s/\tau = 0.55$	COND PASS $m_s/\tau = 0.55$

identical across surrogate-recalibration regimes: the controller is frozen