

Frozen-controller transfer verdict and m_s^{RL}/τ

(identical across regimes: the controller is frozen, only the surrogate is recalibrated)

hydronic heat pump	FAIL $m_s/\tau=1.15$	FAIL $m_s/\tau=1.15$	FAIL $m_s/\tau=1.15$
hydronic	FAIL $m_s/\tau=1.04$	FAIL $m_s/\tau=1.04$	FAIL $m_s/\tau=1.04$
singlezone commercial hydronic	COND PASS $m_s/\tau=0.55$	COND PASS $m_s/\tau=0.55$	COND PASS $m_s/\tau=0.55$
	none	partial	full
	surrogate recalibration regime		