


HDRL: seasonal hierarchical controller

high-level seasonal gate $k(t)$ routes to one of two low-level PPO setpoint specialists



$\pi(a_t | s_t) = \pi_{k(t)}(a_t | s_t)$: each specialist solves a narrower, better-conditioned control problem.

The low level is already comfort-aware, so the v3.5 temperature sensor over-regularizes it; HDRL is best at $\lambda_T = 0$.