


E2E UI PROJECT 1791417522799 - FACILITY AUDITS REPORT

KMA audited the following facilities:

E2E UI FACILITY 1791417522799..... 2



E2E UI FACILITY 1791417522799



Facility description not available.

E2E UI FACILITY 1791417522799

#	Barrier Statement	Code	Photo	Proposed Mitigation	Cost
1.	The curb ramp is not located on an accessible route. Measurement: 9.5% Location: UI entrance	ADAS 402.2		Rebuild the curb ramp on an accessible route. Quantity: 3 Unit Cost: \$1,250 EA	\$3,750
TOTAL FOR E2E UI FACILITY 1791417522799: \$3,750					