VSR ALTERNATOR REGULATOR

AND OPEN-SOURCED INTELLIGENT ALTERNATOR REGULATOR

Quick Start Guide

For use with 3rd Generation Alternator Regulators

Copyright 2018 - William A. Thomason

TABLE OF CONTENTS

Regulator Installation	1
Regulator Placement	1
Cautionary Note: Overstressing small-frame alternators	1
Connections	2
Example 1: Basic Installation (Most common single engine installation)	4
Example 2: Twin engine Installation	6
Example 3: Basic System Installation (Utilizing remote battery sensor)	7
Example 4: Minimal (Voltage Only) Installation	9
Configuring the Alternator Regulator	10
Built in Charge Profiles	11
Appendix:	12
Suggested battery Profiles	12
Alternator Temperature Probe Location	13
Accessories – probes, cases, shunts, etc	14
Updating Firmware	16
Selecting Equalize mode	16
LED Blink Patterns	16
Maximum limitations of Alternator Regulator	17

This short guide is intended to help assist in the quick and simple installation of the 3rd generator VSR Alternator Regulator connected to 12v, 24v, or 48v alternators / batteries. Please make sure to refer to the `VSR Alternator Regulator Reference Guide' for more details and installation examples beyond the few shown here, as well as guidance for prior generation alternator regulators.

One critical decision when installing the VSR Alternator Regulator is how many wires to hook up. In its simplest form only 5 wires are needed. However adding additional sensing capability will enable features and allow the regulator to provide for the most efficient and safe charging of your battery.

The VSR Alternator Regulator is capable of supporting any battery / alternator voltage from '12v' to '48v', and will automatically adjust its self to support 12v, 24v, or 48v batteries. To enable other battery voltages (example, 32v), please refer to the `VSR Alternator Regulator Reference Guide' for instruction

REGULATOR INSTALLATION

The regulator is a very versatile device with several installation options depending on your goals and objectives. Following is an overview of how to connect and configure the regulator in commonly found situations, from simple to more capable and reliable integrated systems. Additional examples may be found in the `VSR Alternator Regulator Reference Guide'.

In it s simplest form only the Enable, Alt+, Alt- and Field need to connect and the regulator will behave as many voltageonly regulators, abet with a high level of precision. Adding additional sensing capabilities will unlock additional capabilities, up to and including a fully integrated Systems deployment.

REGULATOR PLACEMENT

Place the near the alternator – keeping the Alt+, Alt- and Field wires as short as reasonably practical. Take into consideration ambient temperature as well as any potential for water splashing and consider augmenting the case as needed. The regulator is very efficient and does not need much cooling beyond what is typically found in engine room compartments, but that is not to say one should test its limits!

CAUTIONARY NOTE: OVERSTRESSING SMALL-FRAME ALTERNATORS

The most common alternator found will be a small frame unit, especially if it is the OEM alternator on a motor. These alternators are good reliable units, but may not be up to the demands of delivering large amounts of current over a long period of time. Overstressing alternators can result in damage from burnt out diodes and/or internal heat stress related damage and failures. Such stress conditions are exacerbated by high acceptance battery banks (ala, Lithium, AGM/GEL, or even large capacity standard wet-cell FLA batteries).

The best way to protect a small-frame alternator is to install an alternator temperature sensor, ideally located near or on the Diode pack. This will allow the VSR Alternator Regulator to monitor the alternator and reduce output as its safe temperature limit is approached. In addition it is recommended to select 'Small-Alt Mode' via DIP switch to provide an overall capping of alternator loading. After some run time experience has been had, you can consider turning off Small-Alt mode and see if the alternator is able to handle your specific installation.

CONNECTIONS

The following illustrates connection terminals on the regulator. See the following table for a description of each connection as well as suggested min size.




Figure 1: 3rd Generation connections

VBat+, VBat - Connect <u>directly</u> to the battery via 14g wire protected with a 2A fuse located at the battery. (Do not connect after any busses, shunts, etc..)

Alternatively, on Gen 3 regulators, these may be connected locally to the alternator if the regulator will remotely receive battery voltage via the CAN bus. Refer to "Example 3: Basic System Installation (Utilizing remote battery sensor)" on page 7

Enable: Connect to VBat+ to 'turn on' the regulator. Use min 14g wire and a 2A fuse.

Current Shunt +, Current Shunt -:

(optional) Connect to the Current Shunt using twisted pair 16g or larger wire. The Current Shunt maybe installed in either a ground wire (low shunt), or in the + voltage wire (High Shunt). Do not exceed 80mV difference between CS+ and CS-, nor exceed connect to a shunt more than 72v above ground.

Feature In: (optional) Connect to VBat (6-72v) to enable Equalization mode.

Feature Out: (optional) Open Collector driver, connect to external Alternator LAMP at dash. 0.5A <u>max</u> current

sink capability. See Source Code to enable other optional capabilities.

Alternator +: Connect to + (Bat) terminal of Alternator. Use wire sized to match your expected maximum Field

current draw and protected by an appropriate fuse. (typically 4-12A, depending on alternator size)

(Min 14g – use 12g or 10g for large frame alternators)

Alternator -: Connect to the – (gnd) terminal of Alternator using appropriate wire. (Min 14g)

Stator (optional) Connect to an Alternator Stator pole via 2A fuse and 16g wire.

Used to increase battery voltage measurement accuracy, as well as enable several battery and

alternator protection features in the regulator.

A, B, C, D: Connect to the field per the following table depending on the configuration of your alternator:

	Jumper	Alternator Field
High Drive (P / B-type)	A - B	Field: C
Low Drive (N / A-type)	C - D	Field: B

Use wire of sufficient gauge to carry the expected current, up to 32A (connector limit) (Min 14g).

Bat Temp,

Alt Temp: (Optional) Appropriate NTC temperature sender.

Note that Alt Temp may be OPTIONALLY shorted to enable half-power mode.

Service / USB: Used to initialize and debug the regulator. Generation 3 and greater contain a built in USB

connector while Generation 2 requires the use of an external USB $\leftarrow \rightarrow$ TTL adapter.

CAN: Allows communication of the regulators status as well as and coordination with other devices.

Refer to the 'VSR Alternator Regulator Reference Guide' for a more complete description of the

CAN communications capability, including NMEA2000[™] connection options.

Tach-out: A conditioned signal to help drive alternator sourced tachometers – even at low charging levels.

EXAMPLE 1: BASIC INSTALLATION (MOST COMMON SINGLE ENGINE INSTALLATION)

This is the recommended basic installation of the VSR Alternator Regulator. With this configuration the regulator monitors a current shunt located at the battery as well as battery temperature and voltage to allow for accurate and safe charging. By sensing an amp shunt at the battery the VSR Alternator Regulator is able to account for all other charging sources, as well as potential house loads, when making decisions about charge state transitions – to give a true indication of the status of the battery's needs. Alternator temperature sensing protects the alternator from overheating / overstressing.

Installing the battery voltage sensing wires (Battery+ and Battery -) DIRECTLY to the battery! Do not attach the wires after a battery switch, dual alternator diode separator, the Battery Amp Shunt, or a common 'bus bar'. Instead connect directly to the batteries for best results.




Figure 2 - Basic install, shunt LOW

The shunt may be located on either the ground side of the battery as shown above or positive side of the battery as shown on the next page. It is suggested to use twisted pairs of wires from the shunt to the regulator. If you already have a shunt installed (perhaps for an Amp meter, or an existing battery monitor system) there is no need to install a 2nd shunt, just use the one already in place – the VSR Alternator Regulator is able to share existing shunts. By default, the regulator is calibrated for a 500A/50mV shunt (commonly used on battery monitors); if your shunt has a different rating adjust the system configuration using the \$SCV command (Refer to the 'VSR Alternator Regulator Reference Guide). Any shunt may be used as long as the maximum sensing voltage does not exceed 80mV.

Connecting External Regulator (Focus on Battery – Simple)




Figure 3 - Basic install, shunt HIGH

EXAMPLE 2: TWIN ENGINE INSTALLATION

It is common for many marine applications to have two engines, each with an alternator to charge the batteries. In this case, simply install a regulator on each engine as you would for a single engine installation. Configure the two regulators the same and connect the Enable wire to each respective engine. You may share the same battery current shunt between both regulators. It is best if each regulator has its own Battery + and Battery – sensing wires, and the temperature sensors *cannot* be shared, each will need its own.

Connect a common CAT-5 cable between the two regulators allowing them to communicate and coordinate their charging: balancing the loads between the two engines and working towards the same charging goals as opposed to fighting each other.

System - Dual Engine install To House Loads




Figure 4 - Duel engine install

EXAMPLE 3: BASIC SYSTEM INSTALLATION (UTILIZING REMOTE BATTERY SENSOR)

When installing the VSR Alternator Regulator in a 'system' one of the benefits is simplified wiring. Rather than routing individual sensing wires to the battery for voltage, current, and temperature, that information may be delivered over the CAT-5 communications cable using a technique of remote-instrumentation.

Remote-instrumentation is a very reliable and long used method for reducing the wiring needs in many industrial and transportation applications. By having a device located at the battery sensing the voltage/current/temperature of the battery the wiring burden is reduced to one cable as opposed to several discreet wires. If the installation has more than one charging source (say, twin engines, or an alternator and solar) this reduced wiring benefit becomes even greater.

To take advantage of remote-instrumentation you will first need an OSEnergy compliant monitoring device at the battery which senses battery voltage/current/temperature. Then when installing the VSR Alternator Regulator, you only need to connect sensing wires locally to the alternator saving long wires back to the battery.

At minimum, you need to connect the VBat + and Vbat – wires to the local alternator + and – output. Adding Alternator Temperature sensing and stator sampling allows the Alternator Regulator to fully protect your alternator.

Simple System Install




Figure 5 - Simple System Install

Additional Regulators may be added easily making the connections shown and routing a CAT-5 cable to the additional devices. For example in a twin engine installation as shown here:

System Install – Additional Devices




Figure 6 - Multiple charging sources in a coordinated system

EXAMPLE 4: MINIMAL (VOLTAGE ONLY) INSTALLATION

This example shows the very minimal connections needed when installing the VSR Alternator Regulator; only 4 wires and a few jumpers. In this very basic installation the VSR Alternator Regulator will function in a like way to most Voltage-only regulators, relying on battery voltage and timers to make charge decisions; and with that also brings the same limitations and risks of a voltage/timer regulator.

Connecting External Regulator (Minimal Install) To House Loads "Ignition" Battery + Enable Switch Battery -Bat Temp CSh -CSh + Feature - In Stator Alt Temp Alt+ Feature - Out - A, B, C, D -B Field Drive Configuration C CAN (See text) D

Figure 7 - Minimal Install

Though simple to install, it is not suggested to use this configuration as many of the capabilities of the VSR Alternator Regulator will be disabled. If you do select this installation option take great care with the configuration options (Alternator output capping / limitations, CPE selection of voltages and transition times among a few) to best match your typical operations and assure limited risks due to battery incomplete charging and/or alternator over-stress situations.

Term: 📥

Even with these risks it is helpful to understand this simplest installation as if any of the regulators sensors fail it will 'fall-back' to simpler modes of operation, thereby allowing continued operation, though perhaps in a less efferent manner.

CONFIGURING THE ALTERNATOR REGULATOR

Configure your regulator using the DIP switches. With these you can select one of the default Charge Profile Entries, as well as tell the regulator the size of the battery you have (needed to more accurately decide when the battery is full).

Positi	on	Meaning (Regulator Version 3)
12		Battery ID
		The 'Battery ID' this regulator is attached to. Used in CAN connected systems.
		Suggested settings:
	<1><2>	
	Off, Off	1 = House Battery
	On, Off	2 = Main starter battery
	Off, On	3 = Secondary house battery
	On, On	4 = Other
35		Select Charge profile 18
	<3> <4> <5>	
	Off, Off, Off	1 = Default (Safe) & AGM #1
	On, Off, Off	2 = Flooded Lead Acid #1 (Starter type , etc)
	Off, On, Off	3 = Flooded Lead Acid #2 (HD - Storage type)
	On, On, Off	4 = AGM #2 (Higher charge voltages)
	Off, Off, On	5 = GEL
	On, Off, On	6 = Carbon Foam (Firefly)
	Off, On, On	7 = Custom #1 (Changeable – Preconfigured HD Storage with Overcharge)
	On, On, On	8 = Custom #2 (Changeable – Preconfigured: LiFeP04)
		(See Table for more details)
6,7		Define Battery Capacity as: **
	<6><7>	
	Off, Off	1x, – 250Ah
	Off, On	2x, 250Ah – 500Ah
	On, Off	3x, 500Ah – 750Ah
	On, On	4x. 750Ah and above
8		On – Use Small Alternator Mode
		Off – Use Large Alternator Mode
		Small Alternator Mode will restrict the maximum alternator output to 75% of its amperage capability. Large Alt mode limits output to 100%.
		(See \$SCA: command to modify the these values.)

Table 1: DIP switch (3rd Generation Regulator)

Advanced Configuration

The Alternator Regulator contains a rich of configuration capabilities beyond what is possible using the DIP switches. These are accessed via the USB port and a simple computer based text terminal. Refer to the `VSR Alternator Regulator Reference Guide' for more details of the ASCII commands and status strings.

BUILT IN CHARGE PROFILES

	Bulk /		Exit Absorption when either:		Overcharge (Finish Charge)		Float		Equalize		Tomporatura	
Profile #	Battery Type	Battery Absorption Type Target Voltage	Amps drop to % battery capacity	or— Time exceeds	Target Amps	Exit Voltage	Max Time	Regulated Voltage	Regulated Amps	Target Voltage	Max Time	Temperature Compensation (mV / 1c from 25c)
#1	Safe / AGM-1	14.1v	3%	6 Hrs				13.4v				24mV
#2	FLA 1 (Starter)	14.8v	1%	3 Hrs				13.5v				30mV
#3	FLA 2 (GC, L16+)	14.6v	1%	4.5 Hrs				13.2v		15.3v	3 Hrs	30mV
#4	AGM-2	14.7v	1%	4.5 Hrs				13.4v				24mv
#5	Gel	14.1v	3%	6 Hrs				13.5v				30mV
#5	Firefly	14.4v	1.3%	6 Hrs				13.4v		14.4v	3 Hrs	24mV
#7**	FLA 3 (GC, L16+)	14.4v	3%	6.0 Hrs	3%	15.3v	3 Hrs	13.1v		15.3v	3 Hrs	30mV
#8**	LiFePO4	13.8v	3%	1.0 Hrs				13.36v	0A			n/a

Table 2: Default Charge Profiles

All values assume the Amp shunt is installed at the battery. All Amperage exit values will automatically adjust to match the Battery Capacity as set by DIP switched 6&7

Blanks indicate that feature / mode is disabled.

See `VSR Alternator Regulator Reference Guide' for more details.

APPENDIX:

SUGGESTED BATTERY PROFILES

The following table provides suggested CPEs to select for different battery types. These are guidelines and it is recommended to confirm the charge profiles with your battery manufacture. If needed select a different CPE numer or adjust the CPE entry using the advanced configuration options (reference `VSR Alternator Reference Guide', ASCII Commands)

Manufacture	Туре	Example Model Numbers	Suggested CPE #
Dyno	Starter FLA	8Dc	1
	Industrial FLA	D85-xx, D125xx	3
	Deep Cycle FLA	L16-D350, , L16-2V, 8Dd	3
East Pen / Deka	AGM - Intimidator	8A24, 8A24M, 8A27, 8A27M, 8A31MTD, 8A4D, 8A8D, 8AGC2	1
	GEL - Dominator	8G24M, 8G27M, 8G31DTM, 8GCG2, 8G4D, 8G8D	5
	Industrial FLA	M75-x, M85-x, M100-x,	3
	FLA	24Mx, 27M6, DP24, DP27, DP31DT, DC24, DC27, DC31DT	1
Firefly	Carbon Foam	L-16, 2V900, 4V450, 12VE31, 12VG31	6
General Battery	Industrial FLA	6-85-x, 6-100-x, 6-125-x 12-85-x, 12-100-x, 12-125-x 24-85-x, 24-100-x, 24-125-x	3
Interstate	Cranking / Starting	24M-HD, 24M-XHD, 24M-RD, 27M-XRD	1
	Cranking / Deep Cycle	SRM-24, HD24-DP, SRM-27, SRM-27B, SRM-29, SRM-4D, GC2-XHD	3
Lifeline	AGM		1
Odysses	AGM	All	4
OPTIMA	AGM	Blue, Red, Yellow top	1
Trojan	Deep-cycle	24TM, 27TM	3
	'Golf Cart'	T-105, T-125, T-145	3
	Floor Sweeper	L-16,	3
	AGM Deep cycle	12-AGM, 22-AGM, 24-AGM, 27-AGM, 32-AGM	1
	Industrial FLA	IND9 IND33	3
	GEL	24-GEL, 27-GEL, 31-GEN, 6V-GEL, 8D-GEL	5
Winston	LiFeYPO4	All	8
Sinopoly	LiFeP04	All	8
GBS	LiFeP04	All	8
CALB	LiFeP04	All	8

ALTERNATOR TEMPERATURE PROBE LOCATION

In most cases the diode pack is the critical limitation in alternators and the best point of reference for measurement – however it is best to consult your alternator manufactures for recommended placement - as well as for allowable operation limits. Figure 8 below shows the recommended location for the alternator temperature probe from Leece Neville / Prestotolite -- on the diode pack.




Figure 8 - Example Alt Temperature probe location

ACCESSORIES — PROBES, CASES, SHUNTS, ETC.

To install your regulator you may need some or all of the following. There are many ways to purchase these, and the examples given are only one option.

Temperature probes:

The Alternator Regulator uses NTC temperature probes to optionally monitor battery and/or alternator temperature. There are several sources for NTC probes, do make sure to get ones with these specifications:

• Resistance: 10K Ohms

• Beta: 3950

(Note: It is possible to alter these values (to some extent) by making changes to the Source Code)

There are positions for two sensors, A and B – typically used for Alternator and Battery respectively. Gen 2 regulators use screw connectors, while Gen 3 uses a common JST XH2.54 2P connector. When sourcing for sensors you should be able to find many probes which already have the connector installed.

Searching Ebay or Amazon for "NTC 10K waterproof 3950" will quickly bring up a wide range of suppliers, with cable lengths from 0.5m to 5m. Here is a photo of one bundle of 5x sensors – with attached JST connectors:



You may also add extension wires to temperature probes. There is no + or – to these sensors wires may go to either side of the connector.

Fuse Holders:

It is recommended to install fuses in the locations indicated in the Example Installations. Chose a fuse of appropriate rating. Use a good quality water resistant fuse holder and fuses which you are able to secure easily and locally. Remember, Fuses are primarily intended to protect wires, not the device – with one exception: the Field fuse will also help protect the regulator's field drive circuit – choose a fuse about 50% higher than you expected maximum field draw. For smaller alternators, a 10A fuse should be sufficient, while larger units may need a 15A fuse. If you are driving multiple alternators in parallel from one VSR Alternator Regulator, adjust the fuse size accursedly, but do not exceed 32A maximum rating.

Current Shunts:

Many installations already have a battery current shunt installed, often as part of an existing battery meter. If so simply attach the Current Shunt leads to that existing shunt. The shunt may be located in the + or the – wire with no adjustments needed for your regulator. Do pay attention to the + and – connections (refer to example installation diagrams).

By default, the Alternator Regulator is configured for a 500A/50mV shunt (Common on many battery monitors). If you are using a different shunt, use the \$SCA: command to calibrate the regulator for different shunt value.

CAUTION: Do not use a shunt who's voltage exceeds 80mV, or inaccurate results will occur as well as a potential for damage.

Shunts are known for being less then accurate, and if you find the calibration of the Alternator Regulator is off, you may use the \$SCA: command to adjust for any error.

(Refer to the 'VSR Alternator Regulator Reference Guide' for details of the \$SCO command and how to use it.)

CAT-5 Communications Cable

A common CAT-5 cable is used to connect the Alternator Regulator with other OSEnergy compliant devices to allow monitoring and coordination of a DC System. Any CAT-5 or CAT-5e cable will work, as well as CAT-6 cable. Connect the CAT-5 cable a daisy-chain fashion, making sure the 'Terminator' jumper is on place ONLY on the end of the daily chain (remove the terminator jumper from any devices in-between).

Enclosure:

The VSR Alternator Regulator dissipates very little heat, and no heat-sink is needed – just air flow around the components (PCB standoffs are sufficient). Plastic boxes are suitable, with common NEMA 4x 'Water-proof' boxes available at electrical supplies and/or building supply houses being an attractive low cost option; especially when combined with water-tight bulkhead glands around the cables in and out of the box. Some examples:



Figure 9 - E989PPJ 5" X 5" X 2"Junction Box



Figure 10 - Uxcell® Waterproof Box 200x120x75mm

UPDATING FIRMWARE

A key capability of the VSR Alternator Regulator is the ability to add features and enhancements by updating the firmware. All that is needed is a USB cable and a WindowsTM compatible machine.

Go to this URL: https://github.com/AlternatorRegulator/alt-Binary


Download and unzip the latest firmware as well as installation tools and batch files. Using the instruction connect a USB cable between your PC and the VSR Alternator Regulator and then run the update bat file. Once completed you will have the latest firmware installed in your regulator.

SELECTING EQUALIZE MODE

Equalize Mode (if supported by the battery CPE) is selected by connecting the FEATURE-IN wire to Vbat+ Take great care in this mode, and watch carefully how your battery is responding to the maintenance `equalize' charging cycle. To stop Equalization disconnect the FEATURE-In port from VBat+

LED BLINK PATTERNS

The on-board LED will blink out patterns to inform the user of its current status, errors, and pending actions (e.g., about to restart). Patterns are made up by a combination of blink patterns, and the speed at which they blink. The following table describes the patterns.



The LED will blink GREEN during normal stand-alone operation. If the regulator is linked into a 'system' and following the common guidance the LED will blink YELLOW instead of Green. As an example, in a twin engine installations one VSR Alternator Regulator should blink out GREEN – this is the regulator which will be coordination charging goals, while the other regulator will blink out Yellow indicating it is in sync.

The LED will blink RED if there is a fault condition. Refer to the VSR Alternator Regulator Reference Guide for details on fault codes and LED LED fault blinking patterns.

MAXIMUM LIMITATIONS OF ALTERNATOR REGULATOR

The following table documents maximum allowed values during the operation of the VSR Alternator Regulator. Exceeding any of these values may cause unpredictable operation and/or damage. All voltages are referenced to VBatunless otherwise noted.

Item	Min	Max	Symbol
VBat+		65	Volts
Enable	8.5	65	Volts
CS+	-0.5 **	65	Volts
CS-	-0.5 **	65	Volts
CS+ / CS- Delta	-80	80	mVolts
Feature-In	-0.5	65	Volts
Factorial		65	Volts
Feature-out		0.5	Amps
Alt+		65	Volts
Field (B or C) current		32	Amps
Ambient Temperature	-40	100	Celsius

Table 2 – Maximum Limitations

^{**} Special care should be noted of the Current Shunt lower voltage limitations. If the current shunt is located in the ground line and a distance from the battery (example at the alternator), too small of a ground wire between the shunt and the battery could easily exceed the limits and create a ground-loop. Increasing the size of the ground cable, and/or relocating the Amp Shunt to the Alternator + wire are potential solutions.