

Section	Item	Unit	Required Specification	Schneider Electric	Compliance	Remarks
General	Model No.			P.F: ATV650U75N4 CHW Pump: ATV650D55N4		
	Country of Origin			Designed in France – Assembled in China		
	Standards IEC/UL/CE			comply		
	Warranty	Years		1 Year		
Electrical	Rated Power	kW	P.F 7.5 KW (N.D) CH.W.P 55 KW (N.D)	7.5 KW (ND) 55 KW (ND)		
	Rated Current	A	Light Duty - PF Heavy Duty - CHW Pump	ATV650U75N4 – 16.5 Ampere ATV650D55N4 – 106.0 Ampere		
	Input Voltage	V		380-480		
	Input Frequency	Hz		50 HZ		
	Output Voltage	V		<= power supply voltage		
	Output Frequency	Hz		0.1...500 Hz		
	Efficiency	%		96%		
	Power Factor			96%		
	Overload Capacity	%		110% for 60 seconds every 10 minutes		
Control	V/F Control			Comply		
	Sensorless Vector			Comply		
	Closed Loop Vector			NA		
	PM Motor Support			Comply		
	PID			Comply		
	Flying Start			Comply		
	Auto Restart			Comply		
	Sleep/Wake			Comply		
Protection	Over Current			Comply		
	Over Voltage			Comply		
	Under Voltage			Comply		
	Ground Fault			Comply		
	Phase Loss			Comply		
	Motor Over Temp			Comply through PTC		
	Short Circuit			Comply		
	Stall Protection			Comply		
Harmonics & EMC	Built-in EMC Filter			integrated class A EMC filter		
	DC Choke		It's required	Built in		
	AC Line Reactor Option			Optional		
	THDi (%)		Need to clarify	<48%		
	IEEE-519 Compliance			Optional		
Communication	Modbus RTU			Built in		
	Modbus TCP/IP			Optional		
	BACnet MSTP			Optional		
	BACnet IP			Optional		
	EtherNet/IP			Optional		
Environment	IP Rating		IP54	IP54		
	Ambient Temp	°C	42 °C	Comply without Derating		
	Humidity	%		5...95 % without condensation conforming to IEC 60068-2-3		
	Altitude	m		<= 1000 m without derating		
	Cooling Method			Forced air Ventilation		
Application	Chilled Water Pump			Comply		
	Pressurization Fan			Comply		
Configuration and startup			It's required	Comply by partner		
Certificates			It's required	To be submitted		
Commercial	Delivery	Weeks		4-5 months		
	Local Service			Available		
	Technical Support			Available		
Compliance Sheet			It's required	Submitted		