

# Electric Water Heating System

*AMIT graduation project*

*Amr Hesham*

*Omar Shehab*

*Mahmoud Hamed*

*Mohamed Kamal*

Table of Contents

Introduction..... 3

System overview ..... 4

System Architecture ..... 6

System Flowchart ..... 11

# Introduction

The electric water heating system is an embedded system project, that aims to solve a common problem in factories and big industrial entities, where the main function is to maintain a stable temperature degree to a certain element. It is not a boiler or a cooler. It is a controllable container that is responsible to keep the container content (whether it is industrial or commercial materials) at a preselected temperature degree. This system main job is for turning the heating or the cooling system to keep the container content's desired temperature stable. Also, it allows the user to reset the desired temperature as it suits to his needs.

# System overview

Electric water heating system, this system has been designed and built for low power Atmel AVR eight-bit high-performance RISC architecture microcontroller. The module used in this project is ATmega32 with:

- 32 programmable I/O lines.
- 4.5V - 5.5V operating voltage.
- 0 - 16MHz speed grades.
- 1024 Bytes internal EEPROM.
- Two 8-bit Timer/Counters.
- One 16-bit Timer/Counter.
- 8-channel, 10-bit ADC.
- Byte-oriented Two-wire Serial Interface.
- External and Internal Interrupt Sources.
- Six Sleep Modes: Idle.

And more of which we did not use in this project. As for the interface with the user, A Liquid Crystal Display, two Seven Segments Display, and three Push Button Switches.


An electric water heating system is built from several smaller systems or modules, each with a special purpose, behavior, and specifications that we will describe and discuss in this section. All these systems combined to complete the purpose of the project, and we need to outline the requirements that we met in this project in the bargain of the system reliability, readability, and efficiency of giving a solution to the given problem. Without further `_delay_ms ();`

The electric water heating system's application features encapsulate its serviceability and usability. The ordinary user who has no development background can easily understand the behavior, factuality, and activities of the application. The system has four modes of operation, [STARTING] mode, [ON\_STATE] mode, [SETTING\_STATE] mode, and [OFF\_STATE] mode. When the system is powered up it enters the [STARTING] mode where the system modules are initiated, and a welcome message is displayed on the LCD. Then the user needs to activate the system by pressing the [ON\_OFF\_SWITCH], this action gives the system the command to enter the [ON\_STATE] mode if the user needs to modify the set temperature which is initialized by default to [60 Celsius], the [SETTING\_STATE] mode must be activated by pressing either the control push button switches [UP\_SWITCH] or [DOWN\_SWITCH]. The system is automatically exiting the [SETTING\_STATE] mode to the [ON\_STATE] mode after five seconds [5 sec] of control push button switches not being activated/pressed. Pressing the [ON\_OFF\_SWITCH] during the [ON\_STATE] mode or the [SETTING\_STATE] modeled the system to enter an Idle sleep [OFF\_STATE] mode. The system is being activated back after entering the sleep [OFF\_STATE] mode, by pressing the [ON\_OFF\_SWITCH].


The system during the [ON\_STATE] mode is responsible for sensing the temperature of the liquid inside the container every one-hundred millisecond [100 msec] then displays the average of the last ten readings to the user monitor [SEVEN SEGMENTS and LCD]. If the liquid temperature decreases than the set temperature by five degrees the system turns on the heating system [3d ceramic heater] and the LED system [Heating Element LED] is blinking every one second [1 sec], pending the liquid temperature reaches the set temperature, diversely is the 5 liquid temperature increased than the set temperature by five degrees the system turns on the cooling system [Peltier] and the LED system [Heating Element LED] is turned on pending the liquid temperature reaches the set temperature. Otherwise, if the liquid temperature equals the set temperature, then the heating system [3d ceramic heater], the cooling system [Peltier], and the LED system [Heating Element LED] are turned off. During the [SETTING\_STATE] mode, the set temperature is being displayed in addition to a welcoming message on the LCD, pressing the [UP\_SWITCH] increase the set temperature by five degrees [5 C], while pressing the [DOWN\_SWITCH] decrease the set temperature by five degrees [5 C]. Then the new set temperature is displayed on both the [LCD] and the two [SEVEN SEGMENTS] -which blink every five seconds [5 sec]- and saved in the system memory as the set temperature of operation is updated to be used after the system is turned. Entering the sleeping [OFF\_STATE] mode disables the monitoring systems [LED\_SYSTEM], [LCD], and [SEVEN SEGMENTS]. The system is activated back if the [ON\_OFF\_SWITCH] is pressed during this mode to the [ON\_STATE] mode.

# System Architecture


- SOFTWARE ARCHITECTURE




## • SYSTEM OFF




## • SYSTEM ON



## • Set\_Temp Mode (BLINKING MODEL)




## • INCREASE SET TEMPERATURE







- **DECREASE SET TEMPERATURE**




## ● GETTING READING



## • ABOVE MAX TEMPERATURE



## • BELOW MIN TEMPERATURE



# System Flowchart

