REFERENCE	MAIN DISTRIBUTION BOARD									
COMPARTMENT	2C	1A	1B	1C	1D	2A	2A	2A	2A	
TYPE/ SIZE	80A BS88	63A BS88	63A BS88	63A BS88	63A BS88	10A BS88	4A BS88	4A BS88	4A BS88	
WB REF										
DESCRIPTION	MAINS INCOMER/GEN CHANGEOVER SWITCH	DETENTION TANK LCP	CSO LCP	BUILDING SERVICES DB	SPARE FEEDER	24V SUPPLY	24V SUPPLY	24V SUPPLY	SPARE 24V SUPPLY	TELEMETRY OUTSTATION
TAG										

P — L25NA4000(B2) 4 x 1c x 25mm² 6181-Y — FROM DNO

E — E25NA0002(B2) 1c x 25mm² G&Y — EB — E25NA0001(B2) 1c x 25mm² G&Y — SEE DRAWING 80065564-01-WAB-42056-NA-DR-E-00009

P — L25NA1000(B2) 5c x 10mm² XLPE/SWA BS5467 — TO DRAWING 80065564-01-WAB-42056 -NA-DR-E-00002

P — L25NA2000(B2) 5c x 6mm² XLPE/SWA BS5467 — TO DRAWING 80065564-01-WAB-42056 -NA-DR-E-00003

P — L25NA3000(B2) 5c x 10mm² XLPE/SWA BS5467 — TO DRAWING 80065564-01-WAB-42056 -NA-DR-E-00004

C — CE25NA1000(B1) 2c x 1.5mm² XLPE/SWA BS5467 — TO DRAWING 80065564-01-WAB-42056 -NA-DR-E-00002

C — CE25NA2000(B1) 2c x 1.5mm² XLPE/SWA BS5467 — TO DRAWING 80065564-01-WAB-42056 -NA-DR-E-00003

C — CE25NA1009(B1) 2c x 1.5mm² XLPE/SWA BS5467 — TO DRAWING 80065564-01-WAB-42056 -NA-DR-E-00002 (TO EDM CONTROLLER)

C — CE25NA4001 (B1) 12c x 1.5mm² XLPE/SWA BS5467

C — CE25NA4002 (B1) 1PR x 0.75 XLPE/SWA BS5308

TELEMETRY OUTSTATION

WARD & BURKE

BIM QUALITY SHEET NO:

COPYRIGHT: This drawing is protected by copyright and is not to be reproduced in part or whole form without the prior and written consent of Ward & Burke.

NOTES

REV NO:	DESCRIPTION	DATE	BY
P01	For Information	16/06/25	DG
P02	For Information	11/07/25	DG
C01	For Information	21/04/26	AS

United Utilities
Water for the North West

PROJECT:

Gaskell Street

TITLE:

MDB BCD

DRAWN BY:	CHECKED BY:	DATE:
AS	DG	21/04/2026

SHEET SIZE:	PROJECT NUMBER:
A1	C821 - GASKST

W&B DRAWING No:	REV:
GASKST-WAB-01-XX-DR-W-60104	C01

CLIENT DRAWING No:	SCALE:
80065564-01-WAB-42056-NA-DR-E-00005	NTS

CAD FILE: GASKST-WAB-01-XX-M2-W-60100-BCD

SUITABILITY CODE: CR - Construction Record