Two-minute talk for faculty

Reproducing two RL papers on the official BSM1 benchmark · about 2 minutes read aloud

Good morning. My work is on control of a wastewater treatment plant using reinforcement learning.

SET-UP

I ran both base papers on the official BSM1 benchmark plant, the simulator the papers use, with its official influent data. I followed each paper exactly as printed first, and only then changed anything.

PAPER 1

> Claim: −95% oxygen, −74% nitrate vs PID

Paper 1, by Wang and co-authors, puts two learning agents on top of a PID controller: one holds oxygen, one holds nitrate. They report errors about 95% lower than PID for oxygen and about 74% lower for nitrate.

> As printed: = PID in 180/180 runs

I implemented it exactly as printed, with every value from their Table I, and ran 20 runs per case, as they did. The plant checks out: my PID is within about 30% of their PID numbers. But the algorithm as printed does not learn. In all 180 runs its correction stays near zero, and the result equals the PID. I also tried twelve different starting weights, the one thing the paper leaves open; none reproduces their table. So their results cannot be obtained from the paper alone.

> Our variant: −81% oxygen (dry), 18/20 runs

To see what the idea can do, I built a modified version, with bigger steps, scaled inputs and a safety fallback to the PID. It cuts oxygen error by 81% in dry weather and beats PID in 18 of

20 runs. But that is my variant, not their algorithm, and under noise it is worse than PID.

PAPER 2

> PID ±1% · DDPG-B 10.6% / 7.1% (paper 7.2 / 5.5) · NH_4 over limit 56% vs 21%

Paper 2, by Du and co-authors, lets oxygen float to save aeration energy. They report 7.2% saving in dry weather and 5.5% in rain. On the official plant my PID and fuzzy comparators match their numbers within 1%. My DDPG agent saves 10.6% and 7.1% on average over three training seeds, and one seed lands almost exactly on their result. But the seeds spread widely. Run exactly as published, it shuts the air almost off during training, then recovers to a similar 10.7% saving. I also found what the paper does not report: with that saving, effluent ammonia is above its limit 56% of the week, against 21% under PID.

CONTRIBUTION

> −29 kWh/d at equal violations (rebuilt plant)

My contribution is a better agent for paper 2. It adds an influent forecast and a risk-aware critic, and it treats the limits as constraints. On our rebuilt plant, at the same violation rate, it uses about 29 kWh per day less than paper 2's agent.

CLOSE

In short: paper 2 reproduces in direction, paper 1 does not reproduce as printed, and every number I quoted comes from saved runs in the repository. Thank you.

Grey boxes are glance cues, not to be read aloud. Sources: github.com/Amritha902/water_resource — docs/REPRODUCTION.md (§2.0 paper 1 exact, §3.0 paper 2 official plant).