



CCN Test Procedure

AD-300 - MHWIRTH (DLS)

Change No:

0006

CCN Title/Identification:

AD 300 hamonization update based on Commissioning findings up to AD 303

Application:

DWCS-S PLC Drawworks Control System Safety - PLC

Test Description:

Software upgraded to TIA20
PLC has been replaced with correct type and version
No functional changes performed.

Step by Step Procedure:

Step #	Description / What to do	Acceptance criteria / What to look for	Comments	Passed Site/By/Date
1	Upload SW with correct TIA version.	PLC is in run, IOs are connected, communication towards DWCS is established.	Make sure to back-up the existing SW before starting.	RIG

Test Observations, Comments, etc.:

Administration / Sign Out:

Test Site	Accepted by Customer	Accepted
RIG	☐	☐