



SetSCO Services Pte Ltd
531 Bukit Batok Street 23
Singapore 659547
Tel : (65) 6566 7777
Fax: (65) 6566 7718
www.setsco.com
Business Reg. No. 196900269D

Our Ref: BH-8500258930

3 November 2023

DVA TRADING PTE LTD
60 Paya Lebar Road
#07-54 Paya Lebar Square
Singapore 409051

Dear Mr Fernandez Gary Leon,

**SETSCO CERTIFICATION BODY (SCB) INITIAL ASSESSMENT FOR CERTIFICATE
FSP-2023-1439 (FIRE RATED DUCT SYSTEM) UNDER THE FIRE SAFETY PRODUCTS
CERTIFICATION SCHEME**

I am pleased to inform you that the Certification Committee (CC) for Product Certification Scheme has approved the certification of Fire Rated Duct System to BS 476 Part 4: 1970 and BS 476 Part 24: 1987 for Fire Safety Products (FSP) Certification under SETSCO Certification Body Certificate number FSP-2023-1439. The date issue of the above certificate is 3 November 2023. Please advise us on the best arrangement for your collection of the certificate.

With this certification, the product is accorded the use of the exclusive SETSCO mark subject to the latest Terms and Conditions of Product Certification.

Please note that advanced approval from SCB shall be required, should you plan to use the SETSCO mark in advertising and promotional publications. Such publicity materials should be cleared with SCB and written approval given before they are printed or published.

Should you require clarifications on any matters, please email to certificationadmin@setsco.com or contact Ms Fiona at tel(s): 6566 7777 (ext 371) or fax: 6566 7718.

Yours sincerely,

Fiona Leong (Ms)
Program Manager (SETSCO)