

CERTIFICATE OF CONFORMITY

This Certificate is issued to

DVA TRADING PTE LTD

(UEN No.: 201323993W)

60 Paya Lebar Road, #07-54 Paya Lebar Square, Singapore 409051

For Product Certification Scheme: Type 5

Product : Fire Rated Duct System

Brand : FyreWrap®

Model : Elite™ 1.5 Duct Insulation

Country of Origin : USA

Product Details : A biosoluble ceramic fiber blanket insulation of alkaline earth silicate (AES) chemistry encapsulated in metalized polyester foil satin for masonry or drywall construction. Core Insulation Material: 96 kg/m³ Fire Classification of Insulation Material: Non-Combustible

Duct Type	Integrity (mins)	Insulation (mins)
Duct A (Vertical) Floor/Ceiling Construction	180	180
Duct B (Vertical) Floor/Ceiling Construction	120	120
Duct B (Horizontal) Floor/Ceiling Construction	120	120
Duct A (Horizontal) Drywall Construction	120	120

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

BS 476 Part 4: 1970

BS 476 Part 24: 1987

TEST REPORT(S)


SETSCO Test Report No.: CT-8500275139/THC

Intertek Evaluation Report No.: 102748488SAT-001

Intertek Test Report No.: 101029020SAT-005A,B

BRE Test Report No.: 285248

Detailed configuration and installation shall be referenced to the certified report(s) stated above.


Fiona Leong (Ms)
Program Manager
SETSCO Services Pte Ltd
531 Bukit Batok Street 23,
Singapore 659547

Certificate No

FSP-2023-1439

Date of Issue

03/11/2023

Date of Expiry

02/11/2028

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.