

# EL2450 HOMEWORK 1

Andreas Froderberg - 19880730-4577  
Martin Favre - 19920130-0010

**Q 1:** A gain named Tap exists in the Tank 1 model, what is its function?

**A:** The gain Tap models the openable tap on the upper tank. The value 0 means that it is currently closed. A value of 1 means fully opened.

**Q 2:** Place the poles to give a following step response:

- Rise time less than 6s
- Overshoot less than 35%
- Settling-time less than 30s

**A:** With the parameters set to  $\chi = 0.5$ ,  $\omega_0 = 0.2$  and  $\xi = 0.7$  yields a system with risetime of 3.31 s and a settling time 18.8 s and an overshoot of 22.6%.

**Q 3:** What does the reference signal look like?

**A:** The signal starts at 40 and receives a step by 10 at 100 s which sets it to 50.

**Q 4:** Use the parameter generator to get values.

**A:** Done.

**Q 5:** Use the parameters to get different responses. Which is best?

**A:** The parameters are:

Table 1: Parameter values and performance.

$\chi$	$\zeta$	$\omega_0$	$T_r$	$M$	$T_s$
0.5	0.7	0.1	6.38	6.67	38.1
0.5	0.7	0.2	3.31	22.6	18.8
0.5	0.8	0.2	3.19	20.9	18.4

The last parameter configuration works best. It is the fastest though it has quite significant overshoot, which is still within the given tolerance.