

Regulatory Deadlines per 2028 CAC Chapter 8, Article 1, Section 1.3.2:
March 1, 2028: Deadline to submit construction documents for NPC 6102, NPC 9, Demolition, and Removal of Acute Care Service projects
March 1, 2028: Deadline for permits to be obtained for NPC 6102, NPC 9, Demolition, and Removal of Acute Care Service projects
January 1, 2030: Deadline for all seismic compliance projects to be completed

"Not Approved" indicates that the submitted Compliance Plan has been reviewed and is not approved. While the facility is potentially eligible for a deferral under ADE 802 for having submitted a request to delay system compliance until January 1, 2023, a submitted Compliance Plan does not include 10 critical risk factors and includes compliance timelines that are too long for the given scope of work, and the Office concludes that the schedule is not reasonable. See the following comments. An amended Compliance Plan shall be submitted to and receive these comments, the Office is available to discuss any comments with the facility and to provide support in receiving the outstanding issues. The facility is reporting that it will be non-compliant with the March 1, 2024 deadline. Please note that if the Office determines that the facility is not in compliance with the March 1, 2024 deadline, the facility will be required to submit an amended compliance plan may be determined "Approved with Non-Compliance Notice" which indicates that the submitted Compliance Plan has been reviewed and approved, but that the facility is reporting that it will be non-compliant with one or both NPH regulatory deadlines.

Summary Schedule

[illegible]

Compliance Type Tables - Click to Hide

Compliance Method:

This table lists each building on the hospital's campus and the method the hospital has reported it will use to achieve seismic compliance. Any comments or clarifications provided by HCN are included alongside the hospital's reported information.

Ref ID	Relay Type	Relay Count	Complexity Type (Powered by)	Networks (Powered by) (Enabled)
Relay-000001	Original Relay	2	2	Relay to SPC-00 and SPC-01 and SPC-03
Relay-000002	Original Relay	2	2	Relay to SPC-00 and SPC-03 and SPC-04
Relay-000003	Advanced Relay	2	2	Relay to SPC-01 and SPC-02 and SPC-04
Relay-000004	Advanced Relay	4	2	Relay to SPC-01 and S-03
Relay-000005	Original Relay	6	3	Relay to SPC-01 and S-03
Relay-000006	Original Relay	5	2	Relay to SPC-01 and S-03
Relay-000007	Original Relay	5	2	Relay to SPC-01 and S-03
Relay-000008	Relay Power Point	6	3	Relay to SPC-01 and S-03
Relay-000009	Original Relay	5	2	Relay to SPC-01 and S-03
Relay-000010	Relay Power Point	5	3	Relay to SPC-01 and S-03

Click Milestone Description Table--Click to Hide

Description of Milestones to achieve Seismic Compliance:
This table shows detailed, building-level milestone information reported by the hospital. Each building may have up to ten milestones that describe the steps the hospital plans to take—and the timelines for taking them—to achieve seismic compliance. Any HCA comments on the reported milestones are included in the table.

Report ID	Report Date	Reportable	Completion Date Reported by	Comments
NR-17673	Conclusion Date	NR-17673 update - Conclusion Date	11/11/2022	The timeline is substantially longer than the NR-17673-2022-04-06.
		NR-17673 update - Conclusion Date	11/10/2022	
	Conclusion Milestone	NR-17673 update conclusion - 25% completion	11/09/2022	
		NR-17673 update conclusion - 25% completion	11/09/2022	
	Evaluation Report Subtotal	NR-17673 Evaluation to SCI	11/09/2022	
NR-17674	Internal Testing Report Subtotal	NR-17674 evaluation assessment document	11/09/2022	10 critical incidents are reported.
	NR-17674 Conclusion Document	NR-17674 update 10x incidents to Regs.	11/09/2022	The deadline for this incident is 11/10/2022.
	NR-17674 Internal Document	Passed by NR-17674-2022	10/11/2022	
	Internal Testing Report Subtotal	NR-17674 update 10x incidents to Regs.	11/09/2022	
	Conclusion Date	NR-17674 update - Conclusion Date	11/10/2022	
NR-17675		NR-17675 update - Conclusion Date	11/10/2022	
	Conclusion Milestone	NR-17675 update conclusion - 25% completion	11/09/2022	
		NR-17675 update conclusion - 25% completion	11/09/2022	
	Evaluation Report Subtotal	NR-17675 Evaluation to SCI	11/09/2022	
	Internal Testing Report Subtotal	NR-17675 evaluation assessment document	11/09/2022	The deadline for this incident is 11/10/2022.
NR-17676	NR-17676 Conclusion Document	NR-17676 update 10x incidents to Regs.	11/09/2022	
	NR-17676 Internal Document	Passed by NR-17676-2022	10/11/2022	
	Internal Testing Report Subtotal	NR-17676 update 10x incidents to Regs.	11/09/2022	
	Conclusion Date	NR-17676 update - Conclusion Date	11/10/2022	
		NR-17676 update - Conclusion Date	11/10/2022	The timeline is substantially longer than the NR-17676-2022-04-06.

Facility's Request for Delay - Click to Hide

The Facility has requested a delay of the January 1, 2030 deadline to January 1, 2032 for Seismic Compliance Application status in process. WCAI Comments have been issued:
[Link to AS 002 Letters](#)

Who owns this facility? **WHD/Pioneers Memorial Hospital**
 What type of entity owns this facility? **District**
 Who manages the hospital? **WHD/Pioneers Memorial Hospital**
 What type of entity manages this hospital? **District**
 Who is financially responsible for the seismic upgrades? **WHD/Pioneers Memorial Hospital**
 Other contact financially obligated for infrastructure improvements: **None**

[Click to Download PDF](#)