

This page is organized into several sections that explain how the hospital plans to achieve seismic compliance across its campus. Each section presents a different level of detail, from high-level timelines to building-specific information.

Regulatory Deadlines per 2023 CAC Chapter 9, Article 1, Section 1.2.2:
March 1, 2026: Deadline to submit construction documents for NPG 6162, NPG 3, Demolition, and Removal of Acute Care Service projects
March 1, 2028: Deadline for permits to be obtained for NPG 6162, NPG 3, Demolition, and Removal of Acute Care Service projects
January 1, 2030: Deadline for all seismic compliance projects to be completed

"Not Approved" indicates that the submitted Compliance Plan has been reviewed and is not approved at this time. This facility reports that it will meet all applicable NRC deadlines. The Compliance Plan also indicates that the facility will not be externally compliant by the January 1, 2020 deadline and needs additional time. This Compliance Plan has been reviewed in conjunction with an AG 602 delay application with a request to delay the facility's final seismic compliance up to February 1, 2032. However, the Office has identified comments that must be addressed before approval can be granted. See comments below. An amended Compliance Plan shall be submitted to address and resolve these comments; the Office is available to discuss any comments with the facility and to provide support in resolving the outstanding issues.

This section provides a visual timeline for each building on the hospital's campus, showing the reported plan for achieving seismic compliance. Milestones are represented by circles on the timeline—hover over a circle to see additional details. All milestones and dates are reported by the

[Summary Schedule Legend](#)[illegible]

This table lists each building on the hospital's campus and the method the hospital has reported it will use to achieve seismic compliance. Any comments or clarifications provided by HCA are included alongside the hospital's reported information.

Refilling No.	Building Name	NPC	C	Designation Type (Required by Hospital)	Remarks (Required by Hospital)
BLD-07226	Original Building	2	2	Outpatient services to NPHI building(s)	The owner is building new Hospital that will need NPC 5. New building Catalina Island Medical Center BLD-07226 Hospital BLD-07227, BSR
BLD-07228	Rail Addition	6	2	Petitioner services to NPHI building(s)	Owner is building a new Hospital that will need NPC 5

Building Milestone Description Table--Click to Hide

This table shows detailed, building-level milestone information reported by the hospital. Each building may have up to ten milestones that describe the steps the hospital plans to take—and the timelines for taking them—to achieve seismic compliance. Any WQRI comments on the reported milestones are included in the table.

[illegible]

Facility's Request for Delay - Click to Hide

The Facility has requested a delay of the January 1, 2020 deadline to March 5, 2022 for Seismic Compliance Application status is process. HCAI Comments have been issued:
[Link to AR 802 Letters](#)

Who owns this facility? Catalina Island Medical Center

[Click to Download PDF](#)