

This page is organized into several sections that explain how the hospital plans to achieve seismic compliance across its campus. Each section presents a different level of detail, from high-level timelines to building-specific

Regulatory Deadlines per 2028 CAC Chapter 8, Article 1, Section 1.8.2:

- March 1, 2026:** Deadline to submit construction documents for NPC 6102, NPC 8, Demolition, and Removal of Acute Care Service projects.
- March 1, 2028:** Deadline for permits to be obtained for NPC 6102, NPC 8, Demolition, and Removal of Acute Care Service projects.
- January 1, 2030:** Deadline for all seismic compliance projects to be completed.

Seismic Compliance Plan for 12004 St. Francis Medical Center

"Not Approved" indicates that the submitted Compliance Plan has been reviewed and is not approved. This facility reports that it will meet all applicable NRC deadlines and achieve seismic compliance by the January 1, 2030, deadline. However, the Office has determined that the Compliance Plan has insufficient details that must be addressed before approval can be granted. See the following comments. An amended Compliance Plan shall be submitted to address and resolve these comments; the Office is available to discuss any comments with the facility and to provide support in resolving the outstanding issues.

Summary Schedule - Click to Hide

Summary Schedule

Milestones are represented by circles on the timeline—however, only a circle is shown if additional details are reported by the hospital. If a circle is shown, it is marked as such.

Business Schedule Legend

- Wholesaler
- Retail Wholesaler
- Mixed Wholesaler
- Mixed Retail Wholesaler
- Retail Wholesaler
- Mixed Wholesaler

Compliance Type Tables - Click to Hide

Compliance Method:

This table lists each building on the hospital's campus and the method the hospital has reported it will use to achieve seismic compliance. Any comments or clarifications provided by HCA are included alongside the hospital's reported information.

Compliance Type (Reported by Resident)					Narrative Reported by Resident
Building No.	Wing Number	SPC	NPC	Compliance Type	
0-2-01077	Fairly Life Center	3	2	SPC Partial	Fire sprinkler and fire indicators only.
0-2-01078	Health Services Pavilion	3	2	SPC Partial	Fire sprinkler and fire indicators only and upgrade to SPC3
0-2-01079	Central Plant	4	2	SPC Partial	Fire sprinkler and fire indicators only
0-2-01080	New Hospital Tower	3	2	SPC Partial	Fire sprinkler and fire indicators only and upgrade to SPC3

Building Milestone Description Table--Click to Hide

Description of Milestones to achieve Islamic Compliance:

This table shows detailed, building-level earthquake information reported by the hospital. Each building may have up to ten milestones that describe the steps the hospital plans to take—and the timelines for taking them—to achieve seismic compliance. Any HCN comments on the reported milestones are included in the table.

[illegible]

Facility's Request for Delay - Click to Hide

HCAL has not received an application for delay from this facility. Applications for a delay to the January 1, 2020 seismic compliance deadline under AB 869 were due on January 1, 2020 per 2025 CAC Chapter 6, Article 1, Section 1.5.2

Who owns this facility? **PRIME HEALTHCARE SERVICES - ST FRANCIS, LLC**
 What type of entity owns this facility? **Private (Investor - Limited Liability Company)**
 Who manages the hospital? **PRIME HEALTHCARE SERVICES - ST FRANCIS, LLC**
 What type of entity manages this hospital? **Private (Investor - Limited Liability Company)**
 Who is financially responsible for the seismic upgrades? **PRIME HEALTHCARE SERVICES - ST FRANCIS, LLC**
 Other contact financially obligated for infrastructure improvements: **None**