

This page is organized into several sections that explain how the hospital plans to achieve seismic compliance across its campus. Each section presents a different level of detail, from high-level timelines to building-specific

Regulatory Deadlines per 2020 CAC Chapter 8, Article 1, Section 1.3.2:
March 1, 2020: Deadline to submit construction documents for NPC 6102, NPC 3, Demolition, and Removal of Acute Care Service projects
March 1, 2020: Deadline for permits to be obtained for NPC 6102, NPC 3, Demolition, and Removal of Acute Care Service projects
January 1, 2020: Deadline for all seismic compliance projects to be completed

Seismic Compliance Plan for 12127 Ronald Reagan UCLA Medical Center

"Not Approved" indicates that the submitted Compliance Plan has been reviewed and is not approved because the facility is reporting that it will be non-compliant with the January 1, 2020 deadline. See the following comments. An amended Compliance Plan shall be submitted to address and resolve these comments; the Office is available to discuss any comments with the facility and to provide support in resolving the outstanding issues.

Summary Schedule - Click to Hide

Summary Schedule

This section provides a visual timeline for each building on the hospital's campus, showing the reported plan for achieving seismic compliance. Milestones are represented by circles on the timeline—hover over a circle to see additional details. All milestones and dates are reported by the hospital. If HCAI has verified that a milestone was met, it is marked as met.

[illegible]

Compliance Type Tables - Click to Hide

Compliance Method:

This table lists each building on the hospital's campus and the method the hospital has reported it will use to achieve seismic compliance. Any comments or clarifications provided by HCA are included alongside the hospital's reported information.

Building No.	Building Name	MPC	NPC	Compliance Type (Reported by Hospital)	Remedial (Reported by Hospital)
BLD-02086	Resident Reagent UGLA Medical Center	0	4	MPC Petrol	Providing additional water and steam capacity is being facility to MPC's Compliance
BLD-02026	Emergency Services Building	0a	1	Petroleum Services to NRSC building(s)	Provide one dedicated Central Plant Building and switch every supply of utilities to be used for the same use to avoid prioritization.

Building Milestone Description Table--Click to Hide

Description of Milestones to achieve Islamic Compliance:

This table shows detailed, building-level milestone information reported by the hospitals. Each building may have up to ten milestones that describe the steps the hospital plans to take—and the timelines for taking them—to achieve seismic compliance. Any HCRU comments on the reported milestones are included in the table.

[illegible]

Facility's Request for Delay - Click to Hide

HCAI has not received an application for delay from this facility. Applications for a delay to the January 1, 2020 seismic compliance deadline under AB 659 were due on January 1, 2026 per 2025 CAC Chapter 6, Article 1, Section 1.5.2

Who owns this facility? UC Regents

What type of entity owns this facility? University of California
Who manages the facility? UAC Research

What type of entity manages this hospital? *University of Calif*

Who is financially responsible for the seismic upgrades? UC Regents

Other contact financially obligated for infrastructure improvements: None

[Click to Download PDF](#)