

This page is organized into several sections that explain how the hospital plans to achieve seismic compliance across its campus. Each section presents a different level of detail, from high-level timelines to building-specific

Seismic Compliance Plan for  
Status: Not Approved

"Not Approved" indicates that the submitted Compliance Plan has been reviewed and is not approved because the facility is reporting that it will be non-compliant with the January 1, 2030 deadline for BLD-02081, BLD-02082, BLD-02083, BLD-03580 and BLD-03581. Moreover, the plan does not include a sufficiently detailed path to resolve all areas of non-compliance. See the following comments. An amended Compliance Plan shall be submitted to address and resolve these comments; the Office is available to discuss any comments with the facility and to provide support in resolving the outstanding issues.

## Summary Schedule - Click to Hide

This section provides a visual timeline for each building on the hospital's campus, showing the reported plan for achieving seismic compliance. Milestones are represented by circles on the timeline—hover over a circle to see additional details. All milestones and dates are reported by the

hospital. If HCIA has verified that a milestone was met, it is marked as met.

[illegible]

## Compliance Type Tables - Click to Hide

**Compliance Method:**  
This table lists each building on the hospital's campus and the method the hospital has reported it will use to achieve seismic compliance. Any comments or clarifications provided by HCAI are included alongside the hospital's reported information.

[illegible]

## Building Milestone Description Table--Click to Hide

**Description of Milestones to achieve seismic compliance:**  
This table shows detailed, building-level milestone information reported by the hospital. Each building may have up to ten milestones that describe the steps the hospital plans to take—and the timelines for taking them—to achieve seismic compliance. Any HCIN comments on the reported milestones are included in the table.

| SL No.  | Activity/ Milestone           | Responsible                              | Completion Date Required by | EC Comments                                                                       |
|---------|-------------------------------|------------------------------------------|-----------------------------|-----------------------------------------------------------------------------------|
| 9.1.1.1 | Technical Milestone           | MP02 E-1 / MPC-1 & upgrader installation | 27/03/2022                  | Present on Evaluation Report Ref.                                                 |
|         | Construction Completion       | MP02 E-1 / MPC-1 & upgrader installation | 27/03/2022                  | Present on Construction Milestone                                                 |
|         | Construction Final            | MP02 E-1 / MPC-1 & upgrader installation | 27/03/2022                  |                                                                                   |
|         | Stationing Report Submitted   | MP02 E-1 (2) upgrader project            | 27/03/2022                  | Present on MP02 E-1 (2) upgrader project                                          |
|         | MP02 E-1 (2) upgrader project | MP02 E-1 (2) upgrader project            | 27/03/2022                  | Nothing being reported on this milestone as it is not in the scope of the project |
| 9.1.1.2 | Technical Milestone           | MP02 E-1 / MPC-1 & upgrader installation | 27/03/2022                  | Present on Evaluation Report Ref.                                                 |
|         | Construction Completion       | MP02 E-1 / MPC-1 & upgrader installation | 27/03/2022                  | Present on Construction Milestone                                                 |
|         | Construction Final            | MP02 E-1 / MPC-1 & upgrader installation | 27/03/2022                  |                                                                                   |
|         | Stationing Report Submitted   | MP02 E-1 (2) upgrader project            | 27/03/2022                  | Nothing being reported on this milestone as it is not in the scope of the project |
|         | MP02 E-1 (2) upgrader project | MP02 E-1 (2) upgrader project            | 27/03/2022                  | Nothing being reported on this milestone as it is not in the scope of the project |
| 9.1.1.3 | Technical Milestone           | MP02 E-1 / MPC-1 & upgrader installation | 27/03/2022                  | Present on Evaluation Report Ref.                                                 |
|         | Construction Completion       | MP02 E-1 / MPC-1 & upgrader installation | 27/03/2022                  | Present on Construction Milestone                                                 |
|         | Construction Final            | MP02 E-1 / MPC-1 & upgrader installation | 27/03/2022                  |                                                                                   |
|         | Stationing Report Submitted   | MP02 E-1 (2) upgrader project            | 27/03/2022                  | Nothing being reported on this milestone as it is not in the scope of the project |
|         | MP02 E-1 (2) upgrader project | MP02 E-1 (2) upgrader project            | 27/03/2022                  | Nothing being reported on this milestone as it is not in the scope of the project |

## Facility's Request for Delay - Click to Hide

HICAI has not received an application for delay from this facility. Applications for a delay to the January 1, 2020 seismic compliance deadline under AQ 969 were due on January 1, 2026 per 2025 CAC Chapter 6, Article 1, Section 1.5.2

Who owns this facility? **Shaw HealthCare**

Who owns this facility? **Sharp Healthcare**  
What type of entity owns this facility? **Non-profit Corporation (incl. Church-related)**  
Who manages the facility? **Sharp Healthcare**

Who manages the hospital? **Sharp Healthcare**  
What type of entity manages this hospital? **Non-profit Corporation (incl. Church-related)**

Other contact financially obligated for infrastructure improvements: None

Other common financing strategies for infrastructure improvements: none

[Click to Download PDF](#)