

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Instrument Calibration Report

Document Information

Document UUID	B2777BD6
Document Number	CAL_EVT-004
Event ID	EVT-004
Chain ID	CH-002
Equipment ID	P-101
Department	Maintenance
Generated On	15-Jul-2026 14:12
Confidentiality	Internal Use Only

Document Control

Document Number	CAL_EVT-004
Issue Date	15-Jan-2026
Revision	Rev-1.0
Prepared By	Karan Gupta
Approved By	Suresh Kumar
Status	Approved

Calibration Information

Calibration Number	CAL_-004
Event ID	EVT-004
Equipment ID	P-101
Instrument Name	Feed Pump
Department	Maintenance
Assigned Technician	Karan Gupta
Status	Closed

Equipment Details

Equipment ID	P-101
Equipment Name	Feed Pump
Area	Tank Farm

Department	Maintenance
Shift	Morning
Reported From	Tank Farm
Asset Criticality	High
Failure Category	Mechanical
Downtime	2 Hours

Calibration Objective

Calibration check performed for:

P-101

Purpose was to verify instrument accuracy and detect measurement deviation.

Calibration Findings

Calibration findings:

Equipment:

Feed Pump

Observed Condition:

Mechanical seal leakage

Deviation Analysis

Calibration deviation identified.

Possible Cause:

Seal wear

Adjustment Performed

Adjustment performed.

Corrective Action:

Seal replaced

Calibration Verification

Post-adjustment verification completed.

Instrument accuracy restored successfully.

Previous Equipment History

Event	Date	Failure	Status
EVT-001	2026-01-06	Bearing wear	Closed
EVT-002	2026-01-09	Follow-up	Closed
EVT-003	2026-01-12	Routine PM	Closed
EVT-004	2026-01-15	Seal wear	Closed

Calibration Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☐ PPE Worn — Pending
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Check lubrication schedule.

Linked Documents

- WO_EVT-004.docx
- MNT_EVT-004.docx
- INS_EVT-004.docx
- EMAIL_EVT-004.txt

Approval

Prepared By	Karan Gupta
Approved By	Suresh Kumar