

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Calibration Failure Analysis Report

Document Information

Document UUID	0DC0952C
Document Number	CAL_EVT-009
Event ID	EVT-009
Chain ID	CH-003
Equipment ID	R-101
Department	Inspection
Generated On	15-Jul-2026 14:12
Confidentiality	Internal Use Only

Document Control

Document Number	CAL_EVT-009
Issue Date	30-Jan-2026
Revision	Rev-1.0
Prepared By	Vikram Rao
Approved By	Anjali Desai
Status	Approved

Calibration Information

Calibration Number	CAL_-009
Event ID	EVT-009
Equipment ID	R-101
Instrument Name	Chemical Reactor
Department	Inspection
Assigned Technician	Vikram Rao
Status	Closed

Equipment Details

Equipment ID	R-101
Equipment Name	Chemical Reactor
Area	Reactor Area

Department	Inspection
Shift	Night
Reported From	CCR
Asset Criticality	Critical
Failure Category	Mechanical
Downtime	1 Hours

Calibration Objective

Detailed calibration assessment performed after abnormal instrument reading.

Calibration Findings

Calibration investigation:

Failure Category:

Mechanical

Description:

Agitator noise

Deviation Analysis

Deviation analysis:

Root Cause:

Bearing wear

Adjustment Performed

Corrective calibration action:

Bearing replaced

Calibration Verification

Instrument tested after calibration activity.

Performance verified successfully.

Previous Equipment History

Event	Date	Failure	Status
EVT-006	2026-01-21	Control tuning	Closed
EVT-007	2026-01-24	Routine	Closed
EVT-008	2026-01-27	Follow-up	Closed
EVT-009	2026-01-30	Bearing wear	Closed

Calibration Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Schedule detailed equipment health assessment.

Linked Documents

- WO_EVT-009.docx
- MNT_EVT-009.docx
- INS_EVT-009.docx
- EMAIL_EVT-009.txt

Approval

Prepared By	Vikram Rao
Approved By	Anjali Desai