

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Calibration Failure Analysis Report

Document Information

Document UUID	CE62BB4F
Document Number	CAL_EVT-016
Event ID	EVT-016
Chain ID	CH-006
Equipment ID	P-101
Department	Operations
Generated On	15-Jul-2026 14:12
Confidentiality	Internal Use Only

Document Control

Document Number	CAL_EVT-016
Issue Date	20-Feb-2026
Revision	Rev-1.0
Prepared By	Neha Singh
Approved By	Arun Nair
Status	Approved

Calibration Information

Calibration Number	CAL_-016
Event ID	EVT-016
Equipment ID	P-101
Instrument Name	Feed Pump
Department	Operations
Assigned Technician	Neha Singh
Status	Closed

Equipment Details

Equipment ID	P-101
Equipment Name	Feed Pump
Area	Tank Farm

Department	Operations
Shift	Morning
Reported From	Control Room
Asset Criticality	High
Failure Category	Mechanical
Downtime	4 Hours

Calibration Objective

Detailed calibration assessment performed after abnormal instrument reading.

Calibration Findings

Calibration investigation:

Failure Category:

Mechanical

Description:

Leakage detected

Deviation Analysis

Deviation analysis:

Root Cause:

Seal failure

Adjustment Performed

Corrective calibration action:

Seal replaced

Calibration Verification

Instrument tested after calibration activity.

Performance verified successfully.

Previous Equipment History

Event	Date	Failure	Status
EVT-001	2026-01-06	Bearing wear	Closed
EVT-002	2026-01-09	Follow-up	Closed
EVT-003	2026-01-12	Routine PM	Closed
EVT-004	2026-01-15	Seal wear	Closed
EVT-005	2026-01-18	Follow-up	Closed
EVT-016	2026-02-20	Seal failure	Closed

Calibration Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Perform vibration analysis after one week.

Linked Documents

- WO_EVT-016.docx
- MNT_EVT-016.docx
- INS_EVT-016.docx
- EMAIL_EVT-016.txt

Approval

Prepared By	Neha Singh
Approved By	Arun Nair