

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Instrument Calibration Report

Document Information

Document UUID	D2B9E016
Document Number	CAL_EVT-024
Event ID	EVT-024
Chain ID	CH-008
Equipment ID	T-101
Department	Operations
Generated On	15-Jul-2026 14:12
Confidentiality	Internal Use Only

Document Control

Document Number	CAL_EVT-024
Issue Date	16-Mar-2026
Revision	Rev-1.0
Prepared By	Neha Singh
Approved By	Arun Nair
Status	Approved

Calibration Information

Calibration Number	CAL_-024
Event ID	EVT-024
Equipment ID	T-101
Instrument Name	Raw Material Tank
Department	Operations
Assigned Technician	Neha Singh
Status	Closed

Equipment Details

Equipment ID	T-101
Equipment Name	Raw Material Tank
Area	Tank Farm

Department	Operations
Shift	Night
Reported From	Boiler House
Asset Criticality	High
Failure Category	Mechanical
Downtime	6 Hours

Calibration Objective

Calibration check performed for:

T-101

Purpose was to verify instrument accuracy and detect measurement deviation.

Calibration Findings

Calibration findings:

Equipment:

Raw Material Tank

Observed Condition:

Leakage detected

Deviation Analysis

Calibration deviation identified.

Possible Cause:

Seal failure

Adjustment Performed

Adjustment performed.

Corrective Action:

Seal replaced

Calibration Verification

Post-adjustment verification completed.

Instrument accuracy restored successfully.

Previous Equipment History

Event	Date	Failure	Status
EVT-024	2026-03-16	Seal failure	Closed

Calibration Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Check lubrication schedule.

Linked Documents

- WO_EVT-024.docx
- MNT_EVT-024.docx
- INS_EVT-024.docx
- EMAIL_EVT-024.txt

Approval

Prepared By	Neha Singh
Approved By	Arun Nair