

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Calibration Failure Analysis Report

Document Information

Document UUID	D6000764
Document Number	CAL_EVT-026
Event ID	EVT-026
Chain ID	CH-009
Equipment ID	M-101
Department	Maintenance
Generated On	15-Jul-2026 14:12
Confidentiality	Internal Use Only

Document Control

Document Number	CAL_EVT-026
Issue Date	22-Mar-2026
Revision	Rev-1.0
Prepared By	Pooja Mehta
Approved By	Suresh Kumar
Status	Approved

Calibration Information

Calibration Number	CAL_-026
Event ID	EVT-026
Equipment ID	M-101
Instrument Name	Agitator
Department	Maintenance
Assigned Technician	Pooja Mehta
Status	Closed

Equipment Details

Equipment ID	M-101
Equipment Name	Agitator
Area	Reactor Area

Department	Maintenance
Shift	Evening
Reported From	Field Operator
Asset Criticality	High
Failure Category	Mechanical
Downtime	1 Hours

Calibration Objective

Detailed calibration assessment performed after abnormal instrument reading.

Calibration Findings

Calibration investigation:

Failure Category:

Mechanical

Description:

Abnormal vibration

Deviation Analysis

Deviation analysis:

Root Cause:

Bearing wear

Adjustment Performed

Corrective calibration action:

Bearing replaced

Calibration Verification

Instrument tested after calibration activity.

Performance verified successfully.

Previous Equipment History

Event	Date	Failure	Status
EVT-026	2026-03-22	Bearing wear	Closed

Calibration Checklist

☒ Lock Out / Tag Out (LOTO) Followed

☒ PPE Worn

☒ Visual Inspection Completed

☒ Lubrication Checked

☒ Leak Inspection Completed

☒ Alignment Verified

☒ Trial Run Successful

Recommendations

Check lubrication schedule.

Linked Documents

- WO_EVT-026.docx
- MNT_EVT-026.docx
- INS_EVT-026.docx
- EMAIL_EVT-026.txt

Approval

Prepared By	Pooja Mehta
-------------	-------------

Approved By	Suresh Kumar
-------------	--------------