

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Calibration Failure Analysis Report

Document Information

Document UUID	59BF268E
Document Number	CAL_EVT-034
Event ID	EVT-034
Chain ID	CH-012
Equipment ID	HE-101
Department	Quality
Generated On	15-Jul-2026 14:12
Confidentiality	Internal Use Only

Document Control

Document Number	CAL_EVT-034
Issue Date	15-Apr-2026
Revision	Rev-1.0
Prepared By	Vikram Rao
Approved By	Neha Singh
Status	Approved

Calibration Information

Calibration Number	CAL_-034
Event ID	EVT-034
Equipment ID	HE-101
Instrument Name	Heat Exchanger
Department	Quality
Assigned Technician	Vikram Rao
Status	Closed

Equipment Details

Equipment ID	HE-101
Equipment Name	Heat Exchanger
Area	Production

Department	Quality
Shift	Morning
Reported From	Control Room
Asset Criticality	High
Failure Category	Mechanical
Downtime	0 Hours

Calibration Objective

Detailed calibration assessment performed after abnormal instrument reading.

Calibration Findings

Calibration investigation:

Failure Category:

Mechanical

Description:

Abnormal vibration

Deviation Analysis

Deviation analysis:

Root Cause:

Bearing wear

Adjustment Performed

Corrective calibration action:

Bearing replaced

Calibration Verification

Instrument tested after calibration activity.

Performance verified successfully.

Previous Equipment History

Event	Date	Failure	Status
EVT-019	2026-03-01	Scheduled	Closed
EVT-034	2026-04-15	Bearing wear	Closed

Calibration Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Conduct thermography inspection next month.

Linked Documents

- WO_EVT-034.docx
- MNT_EVT-034.docx
- INS_EVT-034.docx
- EMAIL_EVT-034.txt

Approval

Prepared By	Vikram Rao
Approved By	Neha Singh