

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Calibration Failure Analysis Report

Document Information

Document UUID	08FB5B41
Document Number	CAL_EVT-042
Event ID	EVT-042
Chain ID	CH-014
Equipment ID	CV-101
Department	Operations
Generated On	15-Jul-2026 14:12
Confidentiality	Internal Use Only

Document Control

Document Number	CAL_EVT-042
Issue Date	09-May-2026
Revision	Rev-1.0
Prepared By	Arjun Singh
Approved By	Arun Nair
Status	Approved

Calibration Information

Calibration Number	CAL_-042
Event ID	EVT-042
Equipment ID	CV-101
Instrument Name	Control Valve
Department	Operations
Assigned Technician	Arjun Singh
Status	Closed

Equipment Details

Equipment ID	CV-101
Equipment Name	Control Valve
Area	Reactor Area

Department	Operations
Shift	Evening
Reported From	Tank Farm
Asset Criticality	High
Failure Category	Mechanical
Downtime	6 Hours

Calibration Objective

Detailed calibration assessment performed after abnormal instrument reading.

Calibration Findings

Calibration investigation:

Failure Category:

Mechanical

Description:

Abnormal vibration

Deviation Analysis

Deviation analysis:

Root Cause:

Bearing wear

Adjustment Performed

Corrective calibration action:

Bearing replaced

Calibration Verification

Instrument tested after calibration activity.

Performance verified successfully.

Previous Equipment History

Event	Date	Failure	Status
EVT-027	2026-03-25	Scheduled	Closed
EVT-042	2026-05-09	Bearing wear	Closed

Calibration Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Monitor bearing temperature daily.

Linked Documents

- WO_EVT-042.docx
- MNT_EVT-042.docx
- INS_EVT-042.docx
- EMAIL_EVT-042.txt

Approval

Prepared By	Arjun Singh
Approved By	Arun Nair