

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Incident Report

Document Information

Document UUID	3ABB2030
Document Number	INC_EVT-011
Event ID	EVT-011
Chain ID	CH-004
Equipment ID	B-101
Department	Inspection
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-011
Issue Date	05-Feb-2026
Revision	Rev-1.0
Prepared By	Vikram Rao
Approved By	Anjali Desai
Status	Approved

Incident Information

Incident Number	INC_-011
Event ID	EVT-011
Date	2026-02-05
Department	Inspection
Area	Utility
Shift	Evening
Reported By	Control Room
Status	Closed

Equipment Details

Equipment ID	B-101
Equipment Name	Steam Boiler

Area	Utility
Department	Inspection
Shift	Evening
Reported From	Control Room
Asset Criticality	Critical
Failure Category	Process
Downtime	6 Hours

Incident Description

An incident was reported involving

Steam Boiler

Description:

Low steam pressure

Impact Assessment

Severity	Medium
Priority	High
Downtime	6 Hours
Asset Criticality	Critical

Root Cause Analysis

Initial investigation indicates:

Scale buildup

Immediate Action Taken

Immediate corrective action taken:

Chemical cleaning

Safety Classification

Failure Category	Process
Severity	Medium
Follow-up Required	Yes

Safety Requirements

Equipment was electrically isolated before repair.

Recommendations

Conduct thermography inspection next month.

Previous Equipment History

Event	Date	Failure	Status
EVT-011	2026-02-05	Scale buildup	Closed

Linked Documents

- WO_EVT-011.docx
- MNT_EVT-011.docx
- INS_EVT-011.docx
- EMAIL_EVT-011.txt

Approval

Prepared By	Vikram Rao
Approved By	Anjali Desai