

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Failure Incident

Document Information

Document UUID	7EF7E92A
Document Number	INC_EVT-018
Event ID	EVT-018
Chain ID	CH-006
Equipment ID	R-101
Department	Operations
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-018
Issue Date	26-Feb-2026
Revision	Rev-1.0
Prepared By	Neha Singh
Approved By	Arun Nair
Status	Approved

Incident Information

Incident Number	INC_-018
Event ID	EVT-018
Date	2026-02-26
Department	Operations
Area	Reactor Area
Shift	Evening
Reported By	CCR
Status	Closed

Equipment Details

Equipment ID	R-101
Equipment Name	Chemical Reactor

Area	Reactor Area
Department	Operations
Shift	Evening
Reported From	CCR
Asset Criticality	Critical
Failure Category	Mechanical
Downtime	2 Hours

Incident Description

Equipment

Chemical Reactor

experienced an operational failure.

Reported Problem:

Abnormal vibration

Impact Assessment

Severity	Medium
Priority	Low
Downtime	2 Hours
Asset Criticality	Critical

Root Cause Analysis

Asset Criticality:

Critical

Root Cause:

Bearing wear

Immediate Action Taken

Corrective maintenance performed.

NovaChem Chemicals Pvt. Ltd. | Internal Use Only | Generated by Industrial Knowledge Intelligence

Action Details:

Bearing replaced

Safety Classification

Failure Category	Mechanical
Severity	Medium
Follow-up Required	No

Safety Requirements

Equipment was electrically isolated before repair.

Recommendations

Continue weekly inspection.

Previous Equipment History

Event	Date	Failure	Status
EVT-006	2026-01-21	Control tuning	Closed
EVT-007	2026-01-24	Routine	Closed
EVT-008	2026-01-27	Follow-up	Closed
EVT-009	2026-01-30	Bearing wear	Closed
EVT-010	2026-02-02	Follow-up	Closed
EVT-018	2026-02-26	Bearing wear	Closed

Linked Documents

- WO_EVT-018.docx
- MNT_EVT-018.docx
- INS_EVT-018.docx
- EMAIL_EVT-018.txt

Approval

Prepared By	Neha Singh
Approved By	Arun Nair