

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Failure Incident

Document Information

Document UUID	B0279CF2
Document Number	INC_EVT-030
Event ID	EVT-030
Chain ID	CH-010
Equipment ID	V-101
Department	Maintenance
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-030
Issue Date	03-Apr-2026
Revision	Rev-1.0
Prepared By	Pooja Mehta
Approved By	Suresh Kumar
Status	Approved

Incident Information

Incident Number	INC_-030
Event ID	EVT-030
Date	2026-04-03
Department	Maintenance
Area	Reactor Area
Shift	Evening
Reported By	Maintenance Workshop
Status	Closed

Equipment Details

Equipment ID	V-101
Equipment Name	Relief Valve

Area	Reactor Area
Department	Maintenance
Shift	Evening
Reported From	Maintenance Workshop
Asset Criticality	Critical
Failure Category	Instrumentation
Downtime	6 Hours

Incident Description

Equipment

Relief Valve

experienced an operational failure.

Reported Problem:

Minor spill

Impact Assessment

Severity	High
Priority	Medium
Downtime	6 Hours
Asset Criticality	Critical

Root Cause Analysis

Asset Criticality:

Critical

Root Cause:

Loose flange

Immediate Action Taken

Corrective maintenance performed.

Action Details:

Flange tightened

Safety Classification

Failure Category	Instrumentation
Severity	High
Follow-up Required	No

Safety Requirements

Permit To Work (PTW) was verified before maintenance.

Recommendations

Conduct thermography inspection next month.

Previous Equipment History

Event	Date	Failure	Status
EVT-030	2026-04-03	Loose flange	Closed

Linked Documents

- WO_EVT-030.docx
- MNT_EVT-030.docx
- INS_EVT-030.docx
- EMAIL_EVT-030.txt

Approval

Prepared By	Pooja Mehta
Approved By	Suresh Kumar