

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Failure Incident

Document Information

Document UUID	6D562B61
Document Number	INC_EVT-032
Event ID	EVT-032
Chain ID	CH-011
Equipment ID	P-102
Department	Operations
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-032
Issue Date	09-Apr-2026
Revision	Rev-1.0
Prepared By	Arjun Singh
Approved By	Arun Nair
Status	Approved

Incident Information

Incident Number	INC_-032
Event ID	EVT-032
Date	2026-04-09
Department	Operations
Area	Production
Shift	Evening
Reported By	Field Operator
Status	Closed

Equipment Details

Equipment ID	P-102
Equipment Name	Transfer Pump

Area	Production
Department	Operations
Shift	Evening
Reported From	Field Operator
Asset Criticality	High
Failure Category	Mechanical
Downtime	3 Hours

Incident Description

Equipment

Transfer Pump

experienced an operational failure.

Reported Problem:

Leakage detected

Impact Assessment

Severity	Low
Priority	Medium
Downtime	3 Hours
Asset Criticality	High

Root Cause Analysis

Asset Criticality:

High

Root Cause:

Seal failure

Immediate Action Taken

Corrective maintenance performed.

Action Details:

Seal replaced

Safety Classification

Failure Category	Mechanical
Severity	Low
Follow-up Required	No

Safety Requirements

Area was barricaded before maintenance work.

Recommendations

Schedule detailed equipment health assessment.

Previous Equipment History

Event	Date	Failure	Status
EVT-017	2026-02-23	Routine schedule	Closed
EVT-032	2026-04-09	Seal failure	Closed

Linked Documents

- WO_EVT-032.docx
- MNT_EVT-032.docx
- INS_EVT-032.docx
- EMAIL_EVT-032.txt

Approval

Prepared By	Arjun Singh
Approved By	Arun Nair