

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Failure Incident

Document Information

Document UUID	5343F573
Document Number	INC_EVT-036
Event ID	EVT-036
Chain ID	CH-012
Equipment ID	C-101
Department	Maintenance
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-036
Issue Date	21-Apr-2026
Revision	Rev-1.0
Prepared By	Pooja Mehta
Approved By	Suresh Kumar
Status	Approved

Incident Information

Incident Number	INC_-036
Event ID	EVT-036
Date	2026-04-21
Department	Maintenance
Area	Utility
Shift	Night
Reported By	Production Floor
Status	Closed

Equipment Details

Equipment ID	C-101
Equipment Name	Air Compressor

Area	Utility
Department	Maintenance
Shift	Night
Reported From	Production Floor
Asset Criticality	High
Failure Category	Instrumentation
Downtime	3 Hours

Incident Description

Equipment

Air Compressor

experienced an operational failure.

Reported Problem:

Parameter deviation

Impact Assessment

Severity	High
Priority	High
Downtime	3 Hours
Asset Criticality	High

Root Cause Analysis

Asset Criticality:

High

Root Cause:

Calibration drift

Immediate Action Taken

Corrective maintenance performed.

Action Details:

Recalibrated

Safety Classification

Failure Category	Instrumentation
Severity	High
Follow-up Required	No

Safety Requirements

All PPE requirements were complied with.

Recommendations

Check lubrication schedule.

Previous Equipment History

Event	Date	Failure	Status
EVT-021	2026-03-07	Routine	Closed
EVT-036	2026-04-21	Calibration drift	Closed

Linked Documents

- EMAIL_EVT-036.txt

Approval

Prepared By	Pooja Mehta
Approved By	Suresh Kumar